



Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

This certificate is issued to:

APPLICANT Prysmian Group Netherlands B.V.
Abel Tasmanstraat 1
7821 AN Emmen
The Netherlands

PLACES OF PRODUCTION Prysmian Group Netherlands B.V.
Abel Tasmanstraat 1
7821 AN Emmen
The Netherlands

DESCRIPTION Halogenfree, low smoke, flame retardant power and control cable.

TYPE HUSK-FR BFXI power cable 0,6/1 kV, stranded circular conductors (class 2 and class 5), XLPE/mica insulated, filler or polyester tape wrapping, SHF1 sheathed.
HUSO-FR BIOI power cable 0,6/1 kV, stranded circular conductors (class 2 and class 5), XLPE/mica insulated, filler or polyester tape wrapping, SHF1 inner sheath, armour/screen braiding of plain or tinned copper wires, galvanised steel wires, phosphor bronze wires, SHF1 outer sheathed.

SPECIFIED STANDARDS Fixed wiring on ships and offshore installations
IEC 60092-350 ed4.0/-351 ed3.0/-353 ed4.0/-359 ed1.2
IEC 60332-1, ed1.1
IEC 60332-3-22, Cat. A , ed2.0
IEC 60754, ed3.0
IEC 61034, ed3.1
IEC 60228, ed3.0
HD 308 (2001)
IEC60331-21 ed1.0

Certificate No. 18/30037

Issue Date 11 February 2019

Expiry Date 17 July 2023

Sheet 1 of 2



A.W. van der Velden
Type Approval Department
Lloyd's Register EMEA

Lloyd's Register EMEA, Rotterdam Technology Support Office, K.P.v.d.Mandelelaan 41a, 3062 MB Rotterdam, The Netherlands

Lloyd's Register EMEA
Is a subsidiary of Lloyd's Register Group

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

**RATINGS**

0,6/ 1 kV

RANGEConductor cross sectionNumber of cores1,5 - 300 mm²

1

1,5 - 35 mm²

2

1,5 - 240 mm²

3

1,5 - 25 mm²

4

1,5 - 2,5 mm²

5 up to 12, 19

1,5 mm²

16, 24

Note: Class 5/2 conductor is a flexible conductor according to IEC 60228 class 5, but with a conductor resistance according to IEC 60228 class 2.

OPERATIONAL LIMITATIONS

Maximum conductor temperature: 90°C

"This Certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid certificate."

The Design Appraisal Document No. 1830037 and its supplementary Type Approval Terms and Conditions form part of this Certificate.

"When Rules and Standards mentioned in this certificate are changed within the validity of this certificate, than this certificate becomes no longer valid."

Certificate No.

18/30037

Issue Date

11 February 2019

Expiry Date

17 July 2023

Sheet

2 of 2



A.W. van der Velden
Type Approval Department
Lloyd's Register EMEA

Lloyd's Register EMEA, Rotterdam Technology Support Office, K.P.v.d.Mandelelaan 41a, 3062 MB Rotterdam, The Netherlands

Lloyd's Register EMEA
Is a subsidiary of Lloyd's Register Group

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.