

产品认证证书

II型自愿认证

证书编号: CQC2019010304193150

发证日期: 2021年03月19日

有效期至: 2024年06月13日

委托人名称 ABB Stotz-Kontakt GmbH
及注册地址 Eppelheimer Strasse 82 69123 Heidelberg Germany

制造商名称 ABB Stotz-Kontakt GmbH
及注册地址 Eppelheimer Strasse 82 69123 Heidelberg Germany

生产企业名称 ABB Bulgaria EOOD – Rakovski branch
及生产地址 BULGARIA, 4142 Village of Stryama, Region of Plovdiv, Municipality of Rakovski,
Rakovski Industrial Zone, 14 Industrial Road 1, nr,14-18

产品名称和系列、规格、型号 辅助触头
MARL,MACL ;
Ui:750V;Uimp:4kV;AC-15:Ue/Ie:120V/6A,220/240V/6A,380/400V/3A,500V/2A,660/690
V/1A;DC-13:Ue/Ie:24V/4A,48V/2A,125V/0.7A,250V/0.3A,440V/0.15A;Ith:16A;IP20 ; 型号
解释详见附件

产品标准和技术要求 GB/T 14048.5-2017

认证模式 产品型式试验+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站(www.cnca.gov.cn)查验证书信息



授权签字人: 主任:

陈昕 陆楠

中国质量认证中心



PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2019010304193150

Valid from: Mar.19,2021

Valid until: Jun.13,2024

NAME AND REGISTERED ADDRESS OF THE APPLICANT	ABB Stotz-Kontakt GmbH Eppelheimer Strasse 82 69123 Heidelberg Germany
NAME AND REGISTERED ADDRESS OF THE MANUFACTURER	ABB Stotz-Kontakt GmbH Eppelheimer Strasse 82 69123 Heidelberg Germany
NAME AND LOCATION OF THE FACTORY	ABB Bulgaria EOOD – Rakovski branch BULGARIA, 4142 Village of Stryama, Region of Plovdiv, Municipality of Rakovski, Rakovski Industrial Zone, 14 Industrial Road 1, nr,14-18
PRODUCT NAME, MODEL AND SPECIFICATION	Auxiliary Contact MARL,MACL ; Ui:750V;Uimp:4kV;AC-15:Ue/Ie:120V/6A,220/240V/6A,380/400V/3A,500V/2A,660/690V/1A;DC-13:Ue/Ie:24V/4A,48V/2A,125V/0.7A,250V/0.3A,440V/0.15A;Ith:16A;IP20 ; See the Appendix
THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS	GB/T 14048.5-2017
TYPE OF CERTIFICATION SCHEMES	Type Testing of Product + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.
The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNED BY:

PRESIDENT:

CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86 10 83886666

C(2) 0017299

产品认证证书

II型自愿认证

证书编号: CQC2019010304193150

第 1 页 共 2 页

本证书及附件应同时使用, 信息查验说明见证书页

纸号: 17299

型号解释:

MA	C	L	1	10	A	T	S
Product series	Terminal Marking	Mounting	Number of Poles	Auxiliary Contact Configuration	Brand	Terminal Type	Terminal Marking

Product Series: MA = Auxiliary blocks for M series contactors and auxiliary contactors

Terminal Marking: R or C (see table)

Mounting: L = Lateral mounting

Number of Poles = 1

Auxiliary contact configuration:

10 = 1 Normally open

01 = 1 Normally Closed

Brand: A = ABB

Terminal Type: T = screw, R = ring

Terminal marking: None or S (see table)

MA	C	L	1	1	0	A	T	S
迷你接触器和接触器式继电器产品线	适用产品线	安装位置	极数	常开触头对数	常闭触头对数	品牌	接线端子类型	端子标记

附件



中国质量认证中心

产品认证证书

II型自愿认证

证书编号: CQC2019010304193150

第 2 页 共 2 页

本证书及附件应同时使用, 信息查验说明见证书页

纸号: 17299

中文型号解释 Chinese Version

迷你接触器和接触器式继电器产品线: MA

适用产品线: C=适用 MC 接触器产品线; R=适用 MCR 接触器式继电器产品线

安装位置: L=侧面安装

极数: 1=1 极

常开触头对数: 0=0...1=1

常闭触头对数: 1=1...0=0

品牌: A=ABB

接线端子类型: T=螺纹端子, R=环形端子

端子标记: 空白或 S(见下表)

Model 型号	Terminal Marking 端子标记	
	Mounted on right side 右装	Mounted on Left Side 左装
MACL110A*	23-24	33-34
MACL101A*	21-22	31-32
MARL110A*	53-54	63-64
MARL101A*	51-52	61-62
MACL110A*S	13-14	13-14
MACL101A*S	21-22	21-22
MARL110A*S	93-94	03-04
MARL101A*S	91-92	01-02

Where* = T or R

附件



中国质量认证中心