

IEC SYSTEM FOR CONFORMITY TESTING  
AND CERTIFICATION OF ELECTRICAL  
EQUIPMENT (IECEE)  
CB SCHEME

SYSTÈME CEI D'ESSAIS DE CONFORMITÉ  
ET DE CERTIFICATION DES EQUIPEMENTS  
ELECTRIQUES (IECEE)  
METHODE OC

CB TEST CERTIFICATE  
CERTIFICAT D'ESSAI OC

Product  
*Produit*

Electromechanical control circuit devices and switching element,  
Auxiliary contact block.

Name and address of the applicant  
*Nom et adresse du demandeur*

ABB CONTROL SA  
BP 114, FR-69685 Chasieu Cedex  
France

Name and address of the manufacturer  
*Nom et adresse du fabricant*

Same as above

Name and address of the factory  
*Nom et adresse de l'usine*

Linaset a. s.  
Ceskoslovenské armády 362, 747 87 Budisob nad Budisovkou  
Czech Republik

Rating and principal characteristics  
*Valeurs nominales et caractéristiques principales*

U<sub>i</sub> = 690V, U<sub>imp</sub> = 6 KV, I<sub>th</sub> = 16A, f = 40-60 Hz, IP20  
AC - 15 : 6A, 127V. 4A, 240V. 3A, 440V. 2A, 690V.  
DC - 13 : 6A, 24V. 2,8A, 48V. 1A, 72A. 0,3A, 250V

Trade mark (if any)  
*Marque de fabrique (si elle existe)*

ABB

Model/type Ref.  
*Ref. de type*

CAL5-11

Additional information (if necessary)  
*Information complémentaire (si nécessaire)*

NO+NC

A sample of the product was tested and  
found to be in conformity with  
*Un échantillon de ce produit a été essayé et a été  
considéré conforme à la*

IEC 60947-1:1999  
IEC 60947-5-1:1997

as shown in the Test Report Ref. No.  
which forms part of this certificate  
*comme indiqué dans le Rapport d'essais numéro  
de référence  
qui constitue une partie de ce certificat*

200637-2

This CB Test Certificate is issued by the National Certification Body  
*Ce Certificat d'essai OC est établi par l'Organisme National de Certification*

11 July 2002

AMP/MMB

 **SEMKO**



 Intertek Testing Services  
ETL SEMKO

Postal address

Visiting address

Telephone

Telefax

**SEMKO AB**  
P.O. Box 1103  
SE-164 22 KISTA

Torshamnsgatan 43  
KISTA-STOCKHOLM

Int+ 46 8 750 00 00

Int+ 46 8 750 60 30