



中国国家强制性产品认证证书

证书编号：2024010305656671

认证委托人名称及地址

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

生产者名称及地址

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

生产企业名称及地址

ABB Bulgaria EOOD - branch Petrich
1, Varna Str., 2850 Petrich, Bulgaria

产品名称和系列、型号、规格

辅助触头

HK1-11, HK1-20, HK1-02, HK1-20L, HK1-11K, HK1-20K, HK1-02K, HK1-20LK, HK1-11A,
HK1-11B, HK1-20A; SK1-11, SK1-20, SK1-02, SK1-11AR, SK1-20AR, SK1-02AR,
SK1-11ARK, SK1-20ARK, SK1-02ARK, SK1-11K, SK1-20K, SK1-02K; CK1-11, CK1-20, CK1-02;
详见附页

产品标准和技术要求

GB/T 14048.5-2017

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》
(CNCA-C03-02:2024)的要求，特发此证。

发证日期：2025年11月25日 有效期至：2029年07月11日

本证书为变更证书，证书首次颁发日期：2024年07月12日
证书信息和有效性可扫描下方二维码或登录发证机构网站查验，
也可在认监委网站（www.cnca.gov.cn）查询。



签发：

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





中国国家强制性产品认证证书

证书编号：2024010305656671

证书附页：第 1 页 共 2 页

HK1-11, HK1-20, HK1-02, HK1-20L, HK1-11K, HK1-20K, HK1-02K, HK1-20LK,
HK1-11A, HK1-11B, HK1-20A; SK1-11, SK1-20, SK1-02, SK1-11AR, SK1-20AR,
SK1-02AR, SK1-11ARK, SK1-20ARK, SK1-02ARK, SK1-11K, SK1-20K, SK1-02K;
CK1-11, CK1-20, CK1-02;
Ui:690V;
Uimp:6kV;
Ith:6A;
AC-15:Ue/Ie: AC24V/6A, AC110-120V/6A, AC220-240V/4A, AC400V/3A,
AC690V/1A;
DC-13:Ue/Ie: DC24V/2A, DC110-125V/0.55A, DC250V/0.27A, DC400V/0.15A,
DC600V/0.15A;
IP20

本页为证书附页，应与证书主页同时使用。



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



中国国家强制性产品认证证书

证书编号: 2024010305656671

证书附页: 第 2 页 共 2 页

型号的解释(Explanation of model/ type):

HK1	-	20	AR	K
1		2	3	4

1	HK1: Auxiliary contacts for lateral mounting 辅助触头,侧面安装 SK1: Signaling contacts for lateral mounting 信号触头,脱扣报警, 侧面安装 CK1: Short-circuit Signaling contacts for lateral mounting 信号触头,短路报警, 侧面安装
2	Contact Configuration: 触点配置 11: 1 N.O. and 1 N.C. contact 1 常开, 1 常闭 20: 2 N.O. contact 2 常开 02: 2 N.C. contact 2 常闭
3	Blank: Standard product 空白 标准产品 AR: Auto reset, for SK1-xx and SK1-xxK only 自动复位仅对 SK1-xx 和 SK1-xxK A: terminal sequence numbers 1 and 2 终端标记 1 和 2 B: terminal sequence numbers 4 and 3 终端标记 3 和 4 L: with lead contacts, for HK1-20 only 引导型
4	Blank: standard version (screw terminals) 空白 标准产品螺纹端子 K: Push-in terminals, for HK1-..., SK1-... only 插接型端子仅对 HK1-..., SK1-...

本页为证书附页, 应与证书主页同时使用。



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2024010305656671

NAME AND ADDRESS OF THE APPLICANT

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

NAME AND ADDRESS OF THE MANUFACTURER

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

NAME AND LOCATION OF THE FACTORY

ABB Bulgaria EOOD - branch Petrich
1, Varna Str., 2850 Petrich, Bulgaria

PRODUCT NAME,MODEL AND SPECIFICATION

Auxiliary Contact

HK1-11, HK1-20, HK1-02, HK1-20L, HK1-11K, HK1-20K, HK1-02K, HK1-20LK, HK1-11A, HK1-11B, HK1-20A;
SK1-11, SK1-20, SK1-02, SK1-11AR, SK1-20AR, SK1-02AR, SK1-11ARK,SK1-20ARK, SK1-02ARK, SK1-11K,
SK1-20K, SK1-02K; CK1-11, CK1-20, CK1-02;See the Appendix

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.5-2017

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Nov.25,2025 **Valid until:** Jul.11,2029

Date of original issued: Jul.12,2024

The certificate information and validity could be checked by scanning the QR code below or logging in to
the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO. : 2024010305656671

Appendix: Page 1 of 1

HK1-11, HK1-20, HK1-02, HK1-20L, HK1-11K, HK1-20K, HK1-02K, HK1-20LK,
HK1-11A, HK1-11B, HK1-20A; SK1-11, SK1-20, SK1-02, SK1-11AR, SK1-20AR,
SK1-02AR, SK1-11ARK, SK1-20ARK, SK1-02ARK, SK1-11K, SK1-20K, SK1-02K;
CK1-11, CK1-20, CK1-02;

Ui:690V;

Uimp:6kV;

Ith:6A;

AC-15:Ue/Ie: AC24V/6A, AC110-120V/6A, AC220-240V/4A, AC400V/3A,

AC690V/1A;

DC-13:Ue/Ie: DC24V/2A, DC110-125V/0.55A, DC250V/0.27A, DC400V/0.15A,

DC600V/0.15A;

IP20



This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.