

Certificate of Conformity

Registered No.:

COCPPV03115/23E-03

File reference
PVP03115/23E-01

Test report No.
TRPVP03115/23E/01

Date of issue
2023-06-28

On the basis of the tests undertaken, the samples of the below product(s) have been found to comply with the essential requirements of the referenced specifications at the time the tests were carried out:

Applicant: **GoodWe Technologies Co., Ltd.**
No.90 ZiJin Rd., New District, Suzhou, 215011, China

Manufacturer: **GoodWe Technologies Co., Ltd.**
No.90 ZiJin Rd., New District, Suzhou, 215011, China

Factory 1: **GoodWe Technologies Co., Ltd.**
No.90 ZiJin Rd., New District, Suzhou, 215011, China

Factory 2: **GoodWe (GuangDe) Power Supply Technology Co., Ltd.**
No.208,Tong Rui East Road, Guangde, Anhui, China

Product: Hybrid Inverter & AC-Coupled Inverter

Type designation: AC-Coupled Inverter:
GW6000-BT-20, GW8000-BT-20, GW10K-BT-20, GW12K-BT-20,
GW15K-BT-20
Hybrid Inverter:
GW6000-ET-20, GW8000-ET-20, GW10K-ET-20, GW12K-ET-20,
GW15K-ET-20

Certification program: BOS-P-01 Rev. 00

Certification fundamental(s): EN 50549-1:2019+AC:2019-04 with deviations of grid protection settings according to C10/11:2019 edition 2.2 used for Belgium.
See test report for detailed information.

This document is based on the evaluation of the samples of the above mentioned product(s). It does not imply an assessment of the mass-production of the product(s), and it does not permit the use of a TÜV NORD mark. The holder of this document may use it in connection with the related test report(s).



Renewable Energy

BOS&ESS-T-002 COC



中国认可
产品
PRODUCT
CNAS C183-P

TÜV NORD (HANGZHOU) CO., LTD.
Member of TÜV NORD Group
Tel: +86-571-85386989
Fax: +86-571-85386986
www.tuv-nord.com/cn
P.R. China