

# 产品认证证书

## II型自愿认证

证书编号: GQC2003010304064035

发证日期: 2023年03月29日  
有效期至: 2032年06月17日

委托人名称	ABB Stotz-Kontakt GmbH
及注册地址	Eppelheimer Strasse 82 69123 Heidelberg Germany
制造商名称	ABB Stotz-Kontakt GmbH
及注册地址	Eppelheimer Strasse 82 69123 Heidelberg Germany
生产企业名称	ABB Stotz-Kontakt GmbH
及生产地址	Eppelheimer Strasse 82 69123 Heidelberg Germany
产品名称和系列、规格、型号	接触器式继电器及其配用辅助触头 K6, KC6, CA6, CAF6 : Ui:690V;Uimp:6kV;AC-15:Ue/Ie:240V/4A,440V/3A,500V/2A;DC-13:Ue/Ie:24V/2.5A,125V/0.7A,250V/0.4A;Ith:6A ; Us:24V,42V,48V,110-127V,220-240V,380-415V 40-450Hz,6V,12V,20V,24V,42V,48V,60V,110-125V,220-240V DC;外壳防护等级:IP20; 注:CA6,CAF6 为配用辅助触头;型号解释见附件
产品标准和技术要求	GB/T 14048.5-2017
认证模式	产品型式试验+初次工厂检查+获证后监督

上述产品符合 GQC12-000001-2020 认证规则的要求,特发此证。

本证书为变更证书,证书首次颁发日期:2020年09月02日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站(www.cnca.gov.cn)查验证书信息



授权签字人

签发

郑泉

谢肇煦

中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0223744

# CERTIFICATE OF PRODUCT CERTIFICATION

## TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2003010304064035

Valid from: Mar.29,2023

Valid until: Jun.17,2032

NAME AND REGISTERED ADDRESS OF THE APPLICANT	ABB Stotz-Kontakt GmbH Eppelheimer Strasse 82 69123 Heidelberg Germany
NAME AND REGISTERED ADDRESS OF THE MANUFACTURER	ABB Stotz-Kontakt GmbH Eppelheimer Strasse 82 69123 Heidelberg Germany
NAME AND LOCATION OF THE FACTORY	ABB Stotz-Kontakt GmbH Eppelheimer Strasse 82 69123 Heidelberg Germany
PRODUCT NAME, MODEL AND SPECIFICATION	Contactory relay and its auxiliary contacts K6,KC6,CA6,CAF6 : Ui:690V;Uimp:6kV;AC-15:Ue/Ie:240V/4A,440V/3A,500V/2A;DC-13:Ue/Ie:24V/2.5A,125V/0.7A,250V/0.4A;Ith:6A ; Us:24V,42V,48V,110-127V,220-240V,380-415V 40-450Hz,6V,12V,20V,24V,42V,48V,60V,110-125V,220-240V DC;IP20;注:CA6,CAF6 Auxiliary Contact
THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS	GB/T 14048.5-2017
TYPE OF CERTIFICATION SCHEMES	Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

Date of original issued: Sep.02,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



SIGN BY

郑泉

SIGNATURE

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE



# 产品认证证书

## II型自愿认证

附 录

第 1 页 共 2 页

证书编号: CQC2003010304064035

纸 号: 223744

型号解释:

Full type 型号		KC6-22Z-F-1.4-01									
		KC6	—	22	Z	—	F	—	1.4	—	01
		1		2	3		4		5		6
Position	Product 产品	√	√	√	√	√	√	√	√		
位置	package label 包装标签	√	√	√	√	√	√	√	√	√	√

- 1: 产品型号, K6: 交流线圈  
KC6: 直流线圈
- 2: 触点类型: 第一位常开触点数量, 第二位常闭触点数量  
40: 4NO, 31: 3NO+1NC, 22: 2NO+2NC
- 3: 接线端子标识代号: 40E, 22Z, 31Z
- 4: 接线端子类型: 空白: 螺钉端子 P: 焊接插针端子 F: 插片端子
- 5: 线圈类型: 空白: 标准产品  
数字: 低功耗线圈, 可由 PLC 信号直接驱动, 数字为线圈吸持功耗值

注: 此附录与证书同时使用时有效。



中国质量认证中心



# 产品认证证书

## II型自愿认证

附 录

第 2 页 共 2 页

证书编号: CQC2003010304064035

纸 号: 223744

6: 线圈代号:

Control Voltage ac (40-450Hz)	代码 □...□	Control Voltage dc	代码 □...□
24 V	0..1	6 V	0..6
42 V	0..2	12 V	0..7
48 V	0..3	20 V	0..9
110-127 V	8..4	24 V	0..1
220-240 V	8..0	42 V	0..2
380-415 V	8..5	48 V	1..6
		60 V	1..6
		110-125 V	1..6
		220-240 V	0..5

CA 6 -  $\frac{11}{2}$   $\frac{K}{3}$  -  $\frac{P}{4}$

1: 产品型号: CA6: 侧装, CAF6: 前装

2: 触点类型: 第一位常开触点数量, 第二位常闭触点数量

CA6: 11: 1NO+1NC

CAF6: 11: 1NO+1NC    20: 2NO    02: 2NC

3: 接线端子标识代号: 接触器或继电器配合代号

K: K6..KC6

E: B(C)6-40-00, B(C)7-40-00

M: B(C)6-30-10, B(C)7-30-10

N: B(C)6-30-01, B(C)7-30-01

4: 接线端子类型: 空白: 螺钉端子    P: 焊接插针端子    F: 插片端子

注: 此附录与证书同时使用时有效。



中国质量认证中心

