



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2015010304800518

NAME AND ADDRESS OF THE APPLICANT

ABB France
2 rue d'Arsonval 69680 Chassieu France

NAME AND ADDRESS OF THE MANUFACTURER

ABB France
2 rue d'Arsonval 69680 Chassieu France

NAME AND ADDRESS OF THE FACTORY

Linaset a.s.
Ceskoslovenske armady 362, Budisov 74787 nad Budisovkou Czech Republic

PRODUCT NAME, MODEL AND SPECIFICATION

Auxiliary contacts
CA5-***: Ui:690V;Uimp:6kV;AC-15:Ue/Ie:AC24-127V/6A,AC220-240V/4A,AC380- 440V/3A,AC 500-690V/2A;DC-13:Ue/Ie:DC24V/6A,DC48V/2.8A,DC72V/1A,DC110-125V/0.55A,DC220-250V/ 0.3A;Ith:16A;IP20

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.5-2017

This is to certify that the above mentioned product(s) complies with therequirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Aug.07,2020**Valid until:**Dec.16,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Aug.26,2015

The certificate information is available through CNCA's website: www.cnca.gov.cn

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附 录

第 1 页 共 2 页

证书编号: 2015010304800518

纸 号: 2658793

型号解释:

CA5-40	E	RT
I	II	III IV

I - Main designation: 系列代号 CA5 Auxiliary contact module, front mounted CA 辅助触头, 前装

II - Auxiliary Pole Construction 辅助触头配置

40 - 4 Normally Opened and 0 Normally Closed. 4 常开

31 - 3 Normally Opened and 1 Normally Closed. 3 常开, 1 常闭

22 - 2 Normally Opened and 2 Normally Closed. 2 常开, 2 常闭

13 - 1 Normally Opened and 3 Normally Closed. 1 常开, 2 常闭

04 - 0 Normally Opened and 4 Normally Closed. 4 常闭

11/11 - 1 Normally Opened and 1 Normally Closed / 1 Normally Opened leading contact and 1 Normally Closed lagging contact 1 常开+1 常闭/1 常开引导型+1 常闭延迟型

III - Marking 标识

E: for contactor 4 main poles (type 40-00 or 22-00) 用于 4 极接触器(型式 40-00 或 22-00)

M: for contactor 3 main poles (type 30-10) 用于 3 极接触器(型式 30-10)

U: for contactor 3 main poles (type 30-01) 用于 3 极接触器(型式 30-01)

N: for auxiliary contactor 用于辅助触头

IV - Connection type 接线方式

Blank: screw terminal 螺纹端子

RT: Ring tongue terminal 环形端子

注: 此附录与证书同时使用时有效。



主 任:

陆梅



中国质量认证中心



中国国家强制性产品认证证书

附 录

第 2 页 共 2 页

证书编号：2015010304800518

纸 号：2658793

List of type 型号清单

Designation
CA5-40E
CA5-31E
CA5-22E
CA5-04E
CA5-11/11E
CA5-40ERT
CA5-31ERT
CA5-22ERT
CA5-31M
CA5-22M
CA5-13M
CA5-04M
CA5-11/11M
CA5-31MRT
CA5-22MRT
CA5-40U
CA5-31U
CA5-22U
CA5-04U
CA5-40N
CA5-31N
CA5-22N
CA5-13N
CA5-04N
CA5-40NRT
CA5-31NRT
CA5-22NRT

注：此附录与证书同时使用时有效。



主 任：陆 楠



中国质量认证中心