



产品认证证书

证书编号: CQC2015010304800518

申请人名称及地址

ABB France
2 rue d'Arsonval 69680 Chassieu France

制造商名称及地址

ABB France
2 rue d'Arsonval 69680 Chassieu France

生产企业名称及地址

Linaset a. s. (V054073)
Geskoslovenske armady 362, Budisov 74787 nad Budisovkou Czech Republic

产品名称和系列、规格、型号

辅助触头

CA5-***: Ui:690V;Uimp:6kV;AC-15:Ue/Ie:AC24-127V/6A,AC220-240V/4A,AC380-440V/3A,AC500-690V/2A;DC-13:Ue/Ie:DC24V/6A,DC48V/2.8A,DC72V/1A,DC110-125V/0.55A,DC220-250V/0.3A;lth:16A;外壳防护等级:IP20; 型号解释见附件

产品标准和技术要求

GB/T 14048.5-2017

认证模式

型式试验+获证后监督

上述产品符合 CQC11-462142-2019 认证规则的要求, 特发此证。

发证日期: 2020年08月21日 有效期至: 2024年12月16日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

经中国合格评定国家认可委员会认可 CNAS C001-P

主任: _____

陆梅



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C 0355317



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2015010304800518

NAME AND ADDRESS OF THE APPLICANT

ABB France
2 rue d'Arsonval 69680 Chassieu France

NAME AND ADDRESS OF THE MANUFACTURER

ABB France
2 rue d'Arsonval 69680 Chassieu France

NAME AND ADDRESS OF THE FACTORY

Linaset a.s. (V054073)
Ceskoslovenske armady 362, Budisov 74787 nad Budisovkou Czech Republic

PRODUCT NAME, MODEL AND SPECIFICATION

Auxiliary contacts
CA5-***: Ui:690V;Uimp:6kV;AC-15:Ue/Ie:AC24-127V/6A,AC220-240V/4A,AC380-440V/3A,AC500-690V/2A;DC-13:Ue/Ie:DC24V/6A,DC48V/2.8A,DC72V/1A,DC110-125V/0.55A,DC220-250V/0.3A;Ith:16A;IP20

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.5-2017

TYPE OF CERTIFICATION SCHEMES

Type testing+Follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462142-2019 .

Valid from: Aug.21,2020

Valid until: Dec.16,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

President: _____

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0355317



产品认证证书

第 1 页 共 2 页

附 录

证书编号: CQC2015010304800518

纸 号: 355317

型号解释:

CA5-40	E	RT
I	II	III IV

I - Main designation: 系列代号 CA5 Auxiliary contact module, front mounted CA 辅助触头, 前装
 II - Auxiliary Pole Construction 辅助触头配置

40 - 4 Normally Opened and 0 Normally Closed. 4 常开
 31 - 3 Normally Opened and 1 Normally Closed. 3 常开, 1 常闭
 22 - 2 Normally Opened and 2 Normally Closed. 2 常开, 2 常闭
 13 - 1 Normally Opened and 3 Normally Closed. 1 常开, 2 常闭
 04 - 0 Normally Opened and 4 Normally Closed. 4 常闭
 11/11 - 1 Normally Opened and 1 Normally Closed / 1 Normally Opened leading contact and 1 Normally Closed lagging contact 1 常开+1 常闭/1 常开引导型+1 常闭延迟型

III - Marking 标识

E: for contactor 4 main poles (type 40-00 or 22-00) 用于 4 极接触器(型式 40-00 或 22-00)
 M: for contactor 3 main poles (type 30-10) 用于 3 极接触器(型式 30-10)
 U: for contactor 3 main poles (type 30-01) 用于 3 极接触器(型式 30-01)
 N: for auxiliary contactor 用于辅助触头

IV - Connection type 接线方式

Blank: screw terminal 螺纹端子
 RT: Ring tongue terminal 环形端子

注: 此附录与证书同时使用时有效。

主任: _____

陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>



产品认证证书

附录

第 2 页 共 2 页

证书编号: CQC2015010304800518

纸号: 355317

List of type 型号清单

Designation
CA5-40E
CA5-31E
CA5-22E
CA5-04E
CA5-11/11E
CA5-40ERT
CA5-31ERT
CA5-22ERT
CA5-31M
CA5-22M
CA5-13M
CA5-04M
CA5-11/11M
CA5-31MRT
CA5-22MRT
CA5-40U
CA5-31U
CA5-22U
CA5-04U
CA5-40N
CA5-31N
CA5-22N
CA5-13N
CA5-04N
CA5-40NRT
CA5-31NRT
CA5-22NRT

注: 此附录与证书同时使用时有效。

主任: _____

陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>