Specifications



Photo is representative





Eaton 210072

Eaton Moeller® series Z5 Overload relay, Ir= 95 - 125 A, 1 N/O, 1 N/C, For use with: DILM250

| General specifications | |
|-------------------------|---|
| PRODUCT NAME | Eaton Moeller® series Z5 Thermal overload relay |
| CATALOG NUMBER | 210072 |
| MODEL CODE | Z5-125/FF250 |
| EAN | 4015082100728 |
| PRODUCT LENGTH/DEPTH | 146 mm |
| PRODUCT HEIGHT | 167 mm |
| PRODUCT WIDTH | 128 mm |
| PRODUCT WEIGHT | 1.731 kg |
| CERTIFICATIONS | IEC/EN 60947 IEC/EN 60947-4-1 CE UL CSA File No.: 012528 CSA Class No.: 3211-03 CSA-C22.2 No. 60947-4-1- 14 UL File No.: E29184 CSA UL 60947-4-1 UL Category Control No.: NKCR VDE 0660 |
| GLOBAL CATALOG | 210072 |



| Product specification | S |
|---|---|
| FEATURES | Phase-failure sensitivity (according to IEC/EN 60947, VDE 0660 Part 102) Reset pushbutton manual/auto Test/off button Trip-free release |
| 10.10 TEMPERATURE RISE | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 SHORT-CIRCUIT RATING | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.12 ELECTROMAGNETIC COMPATIBILITY | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.13 MECHANICAL FUNCTION | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |
| 10.2.2 CORROSION RESISTANCE | Meets the product standard's requirements. |
| 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES | Meets the product standard's requirements. |
| 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT | Meets the product standard's requirements. |
| 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS | Meets the product standard's requirements. |
| 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION | Meets the product standard's requirements. |
| 10.2.5 LIFTING | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 MECHANICAL IMPACT | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 INSCRIPTIONS | Meets the product standard's requirements. |

| Resources | |
|-------------------------------|---|
| CATALOGS | Product Range Catalog Switching and protecting motors |
| | eaton-product-overview- for-machinery-catalogue- ca08103003zen-en-us.pdf |
| CHARACTERISTIC CURVE | eaton-tripping-z5- overload-relay- characteristic-curve.eps |
| | eaton-tripping-z5- overload-relay- characteristic-curve- 004.eps |
| DECLARATIONS OF CONFORMITY | eaton-thermal-overload- relay-declaration-of- conformity- uk251268en.pdf |
| | eaton-thermal-overload- relay-declaration-of- conformity- eu250785en.pdf |
| DRAWINGS | eaton-tripping-devices- overload-relay-z5- overload-relay- dimensions-002.eps |
| | eaton-tripping-devices- overload-relay-z5- overload-relay-3d- drawing.eps |
| ECAD MODEL | ETN.210072.edz |
| | <u>IL03407081Z</u> |
| INSTALLATION | <u>IL03407140Z2010 10</u> |
| INSTRUCTIONS | eaton-overload-relays-z5- zb150-il03407006z.pdf |
| MANUALS AND USER GUIDES | DA-MN-h1476dgb |
| MCARMORE | DA-CS-z5_ff250 |
| MCAD MODEL | <u>DA-CD-z5 ff250</u> |
| SPECIFICATIONS AND DATASHEETS | Eaton Specification Sheet - 210072 |
| WIRING DIAGRAMS | eaton-tripping-devices- overload-relay-zeb- overload-relay-wiring- diagram.eps |
| | eaton-general-release-zeb- overload-relay-wiring- diagram.eps |

| 10.3 DEGREE OF PROTECTION OF ASSEMBLIES | Does not apply, since the entire switchgear needs to be evaluated. |
|--|--|
| 10.4 CLEARANCES AND CREEPAGE DISTANCES | Meets the product standard's requirements. |
| 10.5 PROTECTION AGAINST ELECTRIC SHOCK | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS | ls the panel builder's responsibility. |
| 10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS | ls the panel builder's responsibility. |
| 10.9.2 POWER- FREQUENCY ELECTRIC STRENGTH | ls the panel builder's responsibility. |
| 10.9.3 IMPULSE WITHSTAND VOLTAGE | ls the panel builder's responsibility. |
| 10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL | ls the panel builder's responsibility. |
| POLLUTION DEGREE | 3 |
| CLASS | CLASS 10 A |
| CLIMATIC PROOFING | Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30 |
| RATED IMPULSE WITHSTAND VOLTAGE (UIMP) | 8000 V AC 4000 V (auxiliary and control circuits) |
| RATED OPERATIONAL CURRENT (IE) AT AC-15, 220 V, 230 V, 240 V | 1.5 A |
| RATED OPERATIONAL CURRENT (IE) AT AC-15, 380 V, 400 V, 415 V | 0.9 A |
| RATED OPERATIONAL CURRENT (IE) AT DC-13, 110 V | 0.4 A |
| RATED OPERATIONAL CURRENT (IE) AT DC-13, 220 V, 230 V | 0.2 A |
| RATED OPERATIONAL CURRENT (IE) AT DC-13, 24 V | 0.9 A |
| RATED OPERATIONAL CURRENT (IE) AT DC-13, 60 V | 0.75 A |
| | 125 A |

| CURRENT FOR SPECIFIED HEAT DISSIPATION (IN) | |
|---|---|
| STATIC HEAT DISSIPATION, NON- CURRENT-DEPENDENT PVS | 0 W |
| STRIPPING LENGTH (CONTROL CIRCUIT CABLE) | 8 mm |
| VOLTAGE RATING - MAX | 600 VAC |
| PRODUCT CATEGORY | Overload relay Z5 |
| PROTECTION | With terminal cover, Protection against direct contact when actuated from front (EN 50274) |
| ADJUSTABLE CURRENT RANGE - MAX | 125 A |
| ADJUSTABLE CURRENT RANGE - MIN | 95 A |
| AMBIENT OPERATING TEMPERATURE - MAX | 60 °C |
| AMBIENT OPERATING TEMPERATURE - MIN | -25 °C |
| AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MAX | 40 °C |
| AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MIN | 25 °C |
| CONVENTIONAL THERMAL CURRENT ITH OF AUXILIARY CONTACTS (1-POLE, OPEN) | 6 A |
| EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT PVID | 25.5 W |
| HEAT DISSIPATION CAPACITY PDISS | 0 W |
| HEAT DISSIPATION PER POLE, CURRENT- DEPENDENT PVID | 8.5 W |
| NUMBER OF AUXILIARY CONTACTS (CHANGE- OVER CONTACTS) | 0 |
| NUMBER OF AUXILIARY CONTACTS (NORMALLY CLOSED CONTACTS) | 1 |
| NUMBER OF AUXILIARY CONTACTS (NORMALLY OPEN CONTACTS) | 1 |
| NUMBER OF CONTACTS (NORMALLY CLOSED | 1 |

| CONTACTS) | |
|--|---|
| NUMBER OF CONTACTS (NORMALLY OPEN CONTACTS) | 1 |
| OVERLOAD RELEASE CURRENT SETTING - MAX | 125 A |
| OVERLOAD RELEASE CURRENT SETTING - MIN | 95 A |
| RATED OPERATIONAL VOLTAGE (UE) - MAX | 1000 V |
| RATED OPERATIONAL CURRENT (IE) AT AC-15, 120 V | 1.5 A |
| ELECTRICAL CONNECTION TYPE OF MAIN CIRCUIT | Screw connection |
| RESET FUNCTION | Push-button Automatic |
| SCREWDRIVER SIZE | 1 x 6 mm, Terminal screw, Control circuit cables, Standard screwdriver 2, Terminal screw, Control circuit cables, Pozidriv screwdriver |
| MOUNTING METHOD | Direct attachment Direct mounting Separate mounting |
| DEGREE OF PROTECTION | IP00 |
| OVERVOLTAGE CATEGORY | III |
| SAFE ISOLATION | 440 V, Between auxiliary contacts and main contacts, According to EN 61140 500 V AC, Between main circuits, According to EN 61140 240 V AC, Between auxiliary contacts, According to EN 61140 |
| SCREW SIZE | M3.5, Terminal screw, Control circuit cables M10 x 35, Terminal screw, Main connections |
| SHOCK RESISTANCE | 10 g, Mechanical, Sinusoidal, Shock duration 10 ms |
| SHORT-CIRCUIT CURRENT RATING (BASIC RATING) | 10 kA, SCCR (UL/CSA) 500 A, max. CB, SCCR (UL/CSA) 500 A Class J, max. Fuse, SCCR (UL/CSA) |
| SWITCHING CAPACITY | B600 at opposite polarity, |
| | |

| AC operated (UL/CSA) R300, DC operated (UL/CSA) B300 at opposite polarity, AC operated (UL/CSA) |
|---|
| 315 A gG/gL, Fuse, Type "1" coordination 250 A gG/gL, Fuse, Type "2" coordination Max. 6 A gG/gL, fuse, Without welding, Auxiliary and control circuits |
| Branch circuits, (UL/CSA) |
| ≤ 0.25 %/K, residual error for T > 40° Continuous |
| 25 mm width, Main connection |
| 185 mm² |
| 2 x (0.75 - 2.5) mm², Control circuit cables 1 x (0.75 - 2.5) mm², Control circuit cables |
| 1 x (0.75 - 4) mm², Control circuit cables 2 x (0.75 - 4) mm², Control circuit cables |
| |
| 2/0 - 500 MCM, Main cables 2 x (18 - 14), Control circuit cables |
| cables 2 x (18 - 14), Control circuit |
| cables 2 x (18 - 14), Control circuit cables |
| |

| PROJECT NAME: | |
|-----------------|--|
| PROJECT NUMBER: | |
| PREPARED BY: | |
| DATE: | |



Eaton Corporation plc Eaton House 30 Pembroke Road Dublin 4, Ireland Eaton.com

© 2025 Eaton. All Rights Reserved.

Follow us on social media to get the latest product and support information.









