



according to Regulation (EU) No. 305/2011

Number DOP1000024

1.	Unique product identification code	CCT599501, CCT599502
		Wiser Smoke Alarm 230 V
2.	Intended use or uses of the construction product in accordance	fire protection
	with the applicable harmonised technical specification as fore- seen by the manufacturer	
	seem by the manaracturer	
3.	Name, registered trade name or registered trademark and con-	Trade name: Schneider Electric
	tact address of the manufacturer as required pursuant to arti-	Schneider Electric Industries SAS
	cle 11 (5)	35 Rue Joseph Monier
		92500 RUEIL MALMAISON
		France
4.	Where applicable name and contact address of the authorized	Merten GmbH
	representative whose mandate covers the tasks specified in ar-	Fritz-Kotz-Str. 8
	ticle 12 (2)	51674 Wiehl, Germany
5.	System or systems of assessment and verification of constancy	System 1 / AVCP1
	of performance of the construction product as set out in Annex	
	V	
6.	Construction product covered by harmonised standard	EN 14604: 2005 + AC: 2008
	Performed type testing and an inspection of the manufacturing	Notified body:
	plant and of factory production control under AVCP 1 and is-	1116
	sued following certificate of constancy of performance	1116-CPR-176
		CNPP Cert.
7.	European Technical Assessment has been issued	not applicable

Version 1.0 1/2





Number DOP1000024

8. Declared performance

Essential characteristics	Performance	Harmonized technical specification
		EN 14604: 2005 + AC:2008
Operational reliability	pass	4.1-4.2, 4.5-4.7, 4.9-4.10, 4.15-
		4.17, 4.19, 5.11, 5.16, 5.24
Nominal activation conditions / sensitivity / response	pass	4.12, 4.18, 5.2-5.6, 5.15, 5.17-
delay (response time) and performance under fire		5.20
conditions		
Tolerance of supply voltage	pass	5.21, 5.23
Durability of operational reliability: temperature	pass	5.7, 5.8
resistance		
Durability of operational reliability: vibration resistance	pass	5.12, 5.13
Durability of operational reliability: humidity resistance	pass	5.9
Durability of operational reliability: corrosion resistance	pass	5.10
Durability of operational reliability: electrical stability	pass	5.14

9. The performance of the product identified in 1. and 2. This is in conformity with the declared performance in 8. This declaration of performance is issued under the sole responsibility of the manufacturer identified in 3.

Signed for and on behalf of the manufacturer by: 11.05.2023

Docusigned by:

Marta USULE

Marta Asack (VP, Home & Distribution Customer Satisfaction & Quality)

Version 1.0 2/2