

CERTIFICATE

Issued to:
Applicant:
Niko N.V.
Industriepark West 40
9100 Sint-Niklaas, Belgium

Licensee:
Niko N.V.
Industriepark West 40
9100 Sint-Niklaas, Belgium

Product : two-pole socket-outlets with side earthing contacts
Trade name(s) : NIKO
Type(s)/model(s) : -3.1+7**-368** and -3.3+7**-368**

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard NEN 1020:2019, NEN-IEC 60884-1:2019, NEN-IEC 60884-1:2019/A1:2019 and NEN-IEC 60884-1:2019/A2:2019
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 900367

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 7 May 2020 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-113251

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



M. Triulzi
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: two-pole socket-outlets with side earthing contacts
Trade name(s)	: NIKO
Type(s)/model(s)	: -3.1+7**-368** and -3.3+7**-368**
Rated current	: 16 A
Rated voltage	: 250 V~
Method of mounting	: surface type
Cover	: housing of thermoplastic material
Degree of protection	: IP55 completely closed IP44 with IP44 plug inserted
Design	: safety socket-outlet
Programm	: HYDRO
Markings	: -tradenam, series-indication and electrical ratings on the base -tradenam and suffix for the housing on this part

Product data – type -3.1+7-368****

Terminals : screw terminals

Product data – type -3.3+7-368****

Terminals : screwless terminals

TESTS**Test requirements**

NEN 1020:2019
NEN-IEC 60884-1:2019
NEN-IEC 60884-1:2019/A1:2019
NEN-IEC 60884-1:2019/A2:2019

Test result

The test results are laid down in DEKRA test file 224284900.

Additional information

This certificate is also based on the SGS CEBEC Certificate BE-8195

The products in this certificate mentioned types should be used in combination with the housings as mentioned in our KEMA-KEUR certificate 71-113236

This certificate replaces certificate 2140888.01 which we herewith declare invalid and

This certificate replaces certificate No. 2135290.01 which we herewith declare invalid.

Conclusion

The examination proved that all requirements were met.

Factory location

Niko N.V.
Industriepark West 40
9100 Sint-Niklaas, Belgium