



Ref. Certif. No.

FR_724636

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Socket-outlet for fixed-electrical installations

Name and address of the applicant

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX
FRANCE

Name and address of the manufacturer

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX
FRANCE

Name and address of the factory

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX
FRANCE

Note: When more than one factory, please report on page 2

☐ Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

PLEXO serie
0 904 72 (GREEN'UP)

Additional information (if necessary may also be reported on page 2)

/ ☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60884-1:2022

As shown in the Test Report Ref. No. which forms part of this Certificate

31416986-822523

This CB Test Certificate is issued by the National Certification Body



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 15/06/2026

Signature:



ANNEX

Mechanisms

Trademark	Type Reference	Function	Characteristics	Type of Terminals	IP	Mounting	Specificities
LEGRAND	0 904 72	2P+E	16A 250V~	Screw type (rigid and flexible)	IP55	/	Electric vehicle charging with accessory 0 904 78

Classification

Standard sheet	V (CEE7)
Rated current (A)	16A
Rated voltage (V)	250V~
Degree of protection	IP55
Provision for earthing	With earthing contact
Method of connecting the cable	Rewirable
Type of terminals	Screw-type
Color	Grey
Pins	Not solid
Degree of protection against electric shock	Increased protection
Existence of shutters	With shutters
Method of mounting	Surface-type
Method of installation	Design A

Accessories

Type Reference	References	Designation
/	0 904 78	Hook of attachment
/	0 904 91	Modular box



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 15/06/2026

Signature:

