OVE Austrian Electrotechnical Association

Eschenbachgasse 9 | 1010 Wien | Austria ZVR: 327279890 | www.ove.at

ZVIN. 321219090 | WWW

OVE CertificationKahlenberger Str. 2A | 1190 Wien | Austria T +43 1 370 58 06 | certification@ove.at

Validity of ÖVE-Certificates can be checked at www.ove.at



Page 1 of 3

ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: **9460-015-09** Valid from: 2022 10 07

until: 2024 10 07

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Company: NIKO N.V.

Industriepark-West 40 9100 Sint-Niklaas Belgium

Product: Two pole socket outlet with side earthing contacts, Series HYDRO

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the applicant holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s).: 3445-1568/10-NA1

Österreichischer Verband für Elektrotechnik

Head of OVE Certification


Digitally signed by T. Neumayer Email=t neumayer@ove.at

Dipl.-Ing. T. Neumayer



Wien, 2022 12 12









Certificate No.: 9460-015-09

Date: 2022 12 12 Page 2 of 3

Manufacturer:

NIKO N.V. Industriepark-West 40 9100 Sint-Niklaas Belgium

Factory location(s):

NIKO N.V. Industriepark-West 40 9100 Sint-Niklaas Belgium

Tested and certified according to:

ÖVE/ÖNORM IEC 60884-1:2005-09-01 ÖVE/ÖNORM E 8684-1:2010-03-01

Product: Two pole socket outlet with side earthing contacts, Series HYDRO

| Type designation: | Trademark: |
|-------------------|------------|
|-------------------|------------|

Rating:

-3.3+7**-368** Rated voltage: AC 250 V

Rated current: 16 A

IP55

socket-outlet insert with screwless terminals and shutter

NIKO







Certificate No.: 9460-015-09

Date: 2022 12 12 Page 3 of 3

Boxes:

7** can refer to the following colours:

700: grey701: white761: black

