

CERTIFICATE

Number: 2135290.01

Issued to:
Applicant:



Niko N.V.
Industriepark West 40
9100, Sint-niklaas, Belgium

Manufacturer/Licensee:
Niko N.V.
Industriepark West 40
9100, Sint-niklaas, Belgium

Product(s) : socket-outlets (2-pole)
Trade name(s) : NIKO
Type(s)/model(s) : -3.1+7**-368**

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

KEMA Quality hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard IEC 60884-1:2002 + A1:006, NEN 1020:1987 + A2:2004
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 900367

KEMA Quality hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: 27 May 2010 and expires upon withdrawal of one of the above mentioned standards.

KEMA Quality B.V.

drs. G.J. Zoetbrood
Managing Director

J.C. Hendriksen
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY
THE DUTCH COUNCIL
FOR ACCREDITATION



SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

| | |
|----------------------|--|
| product | : socket-outlets (2-pole) |
| trade name | : NIKO |
| type | : -3.1+7**-368** |
| method of mounting | : surface type |
| cover | : housing of thermoplastic material |
| terminals | : screw terminals |
| rated current | : 16 A |
| rated voltage | : 250 V~ |
| degree of protection | : IP55 completely closed IP44 with IP44 plug inserted |
| earthing | : with side earthing-contacts |
| design | : safety socket-outlet |
| programm | : HYDRO |
| markings | : -tradename, series-indication and electrical ratings on the base -tradename and suffix for the cover on this part |

Additional information

The in this certificate mentioned type should be used in combination with the housings as mentioned in our KEMA certificate 2135290.06.

TESTS

Test requirements

IEC 60884-1:2002 + A1:2006
NEN 1020:1987 + A2:2004

Test result

The test results are laid down in KEMA Quality test file 2135290.01.

Remarks

This certificate is also based on the CEBEC CB Test Certificate BE-2296.

Conclusion

The examination proved that all test requirements were met.

Tested by : CEBEC

Checked by : H.R.M. Barends

Factory locations

Niko N.V.
Industriepark West 40, 9100, Sint-niklaas
Belgium

LICENCE N° 2135290.01


HOW TO READ THIS CERTIFICATION LICENCE?

As *end product references* (cfr. catalogues, website, packaging, ...) aren't identical to *certification references* (cfr. certification licences), you'll find below an explanatory table.

Niko declares that the *end product references* in the left column correspond with the *certification references* in the right column.

| End product reference | Certification reference |
|--|-------------------------|
| 700-36800, 700-37842, 700-37848, 701-36800, 701-37842, 701-37848, 761-36800, 761-37842, 761-37848, 761-47849 | -3.1+7**-368** |

Sint-Niklaas, 15/12/2014



Rony Haentjens
Certification & Standardization Officer