



Ref. Certif. No.

FR_724706

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Portable socket-outlet
Rewirable portable socket-outlets

Name and address of the applicant

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX - France

Name and address of the manufacturer

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX - France

Name and address of the factory

NINGBO BANMEN ELECTRIC APPLIANCE CO., LTD.
East Industrial Zone, Guanhaiwei, Cixi City,
315314, Zhejiang Province - China

Note: When more than one factory, please report on page 2

☐ Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)

legrand

Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

RNC11X series (6 945 03)
RNC11UX series (6 945 04)

Additional information (if necessary may also be reported on page 2)

☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60884-1:2022

As shown in the Test Report Ref. No. which forms part of this Certificate

ABND-ESH-P23041433

This CB Test Certificate is issued by the National Certification Body



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 23/06/2026

Signature: Julien GAUTHIER



ANNEX

References, ratings and main characteristics:

RATING AND MAIN CHARACTERISTICS

Model	Reference	Number of socket-outlets	With USB charger	Color of enclosure
RNC11X	6 945 03	4	N	WHITE
RNC11UX	6 945 04	3	Y	ALUMINIUM PAINTED WHITE

CLASSIFICATION

standard Sheet:	Standard sheet III of CEE 7
rated current (A)	16A
rated load (W)	-
rated voltage (V)	250V
household voltage (V)	-
degree of protection	IP20
provision for earthing	with earthing contact
method of connecting the cable	rewirable
type of terminals	screw-type
type of connections	-
colour	See table above
socket-outlets	
multiple socket-outlets	16A : 4
number of socket-outlets	
degree of protection against electric shock	normal protection
existence of shutters	with shutters
method of application - mounting	portable type
method of installation	-
plugs:	
class of equipment	-
entry of cable	-



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 23/06/2026

Signature:


LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
RCS Nanterre B 305 263 174
F - 92266 FONTENAY AUX ROSES