



UKCA MIR DECLARATION OF CONFORMITY

We: MANUFACTURER

Schneider Electric Industries SAS
35 rue Joseph Monier
Rueil Malmaison 92500 – France

UK REPRESENTATIVE

Schneider Electric Limited
Stafford Park 5
Telford, TF3 3BL - United Kingdom

Trademark	Schneider Electric
Product, Type	iEM24xx Series & EM2214 Meter (MIR Versions)
List of reference and options	Refer to Annex 1

Are in conformity with the requirements of the following regulation and conformity was checked in accordance with the following standards.

Regulation	Designated standard / Notified body reference
The Electromagnetic Compatibility Regulations SI 2016 No. 1091	- BS EN 62052-11:2003 - BS EN 62053-21:2003 - BS EN 62053-23:2003 - BS EN 62052-31:2015
The Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012 SI 2012 No. 3032	BS EN IEC 63000:2018
Measuring Instruments Regulations 2016 SI 2016 No 1153	- BS EN 50470-1:2006+A1:2018 - BS EN 50470-3:2006+A1:2018

Subject to correct installation, maintenance and use conforming to its intended purpose, to the applicable regulations and standards, to the supplier's instructions and to accepted rules of the art.

This declaration becomes invalid in the case of any modification to the products not authorized by us.

Person in charge of the documentation (Manufacturer):

DINESHBABU PALANISAMY

Avinya Campus, Argon North Tower,
 Bagmane Solarium City, Bengaluru,
 Karnataka, 560037, India.

Issued at Telford - United Kingdom (Representative): Date & Signature – 2nd June -2026

Signed by:

 A578D60923D7459...

Name: **David WILLIAMS**
 VP Transactional Business & Major Pursuits UK&I
 Zone UK & Ireland



UKCA MIR DECLARATION OF CONFORMITY

	The iEM24xx & EM2214 is a range of single-phase digital energy meters designed for the sub-metering of both active & reactive energies; featuring: MID, Modbus, M-Bus & Tariffs. The offer complies with Class 1 accuracy standards and features quality & reliability at a reasonable cost. The Acti9 enclosure of the iEM24xx supports integrations along with other Acti9 components in Schneider Electric system solutions.
---	--

Annex 1: Applied Designated British Standards

Commercial name	Commercial references	UKCA marking initial application date	Applicable standards
iEM24xx	A9MEM2455 A9MEM2435	2022	As Sub-Meter: - BS EN 62052-11:2003 - BS EN 62053-21:2003 - BS EN 62053-23:2003 - BS EN 62052-31:2015 As MIR Electricity-Meter: - BS EN 50470-1:2006+A1:2018 - BS EN 50470-3:2006+A1:2018 RoHs: - BS EN IEC 63000:2018
EM2214	METSEEM2214	2026	As Sub-Meter: - BS EN 62052-11:2003 - BS EN 62053-21:2003 - BS EN 62053-23:2003 - BS EN 62052-31:2015 As MIR Electricity-Meter: - BS EN 50470-1:2006+A1:2018 - BS EN 50470-3:2006+A1:2018 RoHs: BS EN IEC 63000:2018
The electricity meter types described above are in conformity with the relevant statutory requirements of the UK Measuring Instruments Regulations 2016 No.1153 as amended by SI 2019-696. Refer to UKCA Type Examination Certificate Number: T12314-UK issued by NMi Certain UK (TIC) Ltd., (Approved body No. 8506) and Module D Certificate Number: UKCA-403 issued by NMi Certain UK (TIC) Ltd., (Approved body No. 8506).			