

1708001	DATA SHEET	
valid from: 2026-06-16	J-Y(ST)Y...LG Fire Alarm Cable	

Application

J-Y(ST)Y...LG Fire Alarm Cable is used to transmit signals and can be used for fixed installation on and under plaster, in dry and damp rooms.

For outdoor use this cable should be installed under plaster only.

Design

Design	acc. to VDE 0815, Table 4 Type J-Y(ST)Y...LG
Certification	Classification of fire behaviour according to EN 13501-6 and EN 50575 (article/dimension range see www.lappkabel.com/cpr)
Outer sheath	Colour of the sheath: flame red (similar RAL 3000)

Electrical properties at 20 °C

Loop resistance	max. 73.2 Ω/km
Insulation resistance	min. 100 MΩ/km
Mutual capacitance	max. 100 nF/km (at 800 Hz)
Inductance	ca. 0.65 mH/km
Capacitive coupling	max. 300 pF/100 m (at 800 Hz)
Maximum operating voltage	300 V (not intended to be used in conjunction with low impedance sources, such as power grids)
Test voltage	C/C: 800 V C/S: 800 V

Mechanical and thermal properties

Minimum bending radius	fixed installation: 10 x outer diameter
Temperature range	occasional flexing: -5 °C up to +50 °C max. conductor temperature fixed installation: -30 °C up to +70 °C max. conductor temperature
Flammability	flame retardant acc. to IEC 60332-1-2 resp. EN 60332-1-2

Tests	acc. to DIN VDE 0815, Type J-Y(ST)Y...LG Electrical properties acc. to table 10 Tests at the cable acc. to table 21
--------------	---

General requirements	These cables are conform to EU-Directive 2014/35/EU (Low Voltage Directive) and to EU-Directive 2011/65/EU (RoHS, Restriction of the use of certain hazardous substances). These cables (see www.lappkabel.com/cpr) are classified in accordance with the EU-Regulation no. 305/2011 (CPR).
-----------------------------	--

Environmental information	These cables meet the substance-specific requirements of the EU Directive 2011/65/EU (RoHS).
----------------------------------	--

Note	Trade product, no LAPP product
-------------	--------------------------------

Creator: PES A/PDC	Document: DB1708001EN	Page 1 of 1
Released: ALTE/PDC	Version: 03	