S5033900 POMPMOTOR UPMO 15-60 130 3U

Vervangt / replaces / ersetzt / remplace / sostituisce :

S4108100	UPR 15-60 130 ZLS
S4741900	UP 15-50
S4749300	UP 15-60
S4774400	UPER 15-60 E

1





2



3

UPER 15-60 E

PWM




4
GRUNDFOS
UPM0
PWM SIGNAL OFF
OPERATING PANEL
CONTROL MODE
1
CONSTANT CURVE 1
2
CONSTANT CURVE 2
3
CONSTANT CURVE 3 =MAX
ALARM STATUS
FAULT
BLOCKED
LOW VOLTAGE
ELECTRICAL ERROR
PWM SIGNAL ON
OPERATING PANEL
CONTROL MODE
0
PWM SIGNAL ON
Factory setting UPMO 20-60 = Curve 1 (4m)
UPR 15-60 > UPMO 20-60 = Curve 3 (6m)
UP 15-50 > UPMO 20-60 = Curve 2 (5m)
UP 15-60 > UPMO 20-60 = Curve 3 (6m)
UPER 15-60 > UPMO 20-60 = n.a. (PWM)


5
FAULT
OPERATING PANEL
REMEDY
OFF
0 V
A
B
C
ON
230 V
1
2
5 mm
No.2
ON
<160 V
ON
230 V
1
2
3
4

FR