

—
INSTALLATION INSTRUCTION

DC switch disconnectors

OTDC800...1000F_/OTDC800...1000UF_



Table of contents

03	Use of symbols
04	Receiving, handling and storage
05	Read this safety instructions carefully before using this product
06	Circuits
07 – 08	Enclosure dimensioning
09	Mounting OTDC_F_
010 – 11	Busbars and compression lugs
012 – 13	Connection bar kit OTDCKIT800FS11 Connection bar kit OTDCKIT800FS12
014	Mechanical lug kit OZXA804
015	Direct handle kit OTDV400FK_
016	Auxiliary contacts OA_
017 – 019	Dimension drawings
019	Warning sheet

Use of symbols



Hazardous voltage

Warns about a situation where a hazardous voltage may cause physical injury to a person or damage to equipment.



General warning

Warns about a situation where something other than electrical equipment may cause physical injury to a person or damage to equipment.



Caution

Provides important information or warns about a situation that may have a detrimental effect on equipment.



Information

Provides important information about the equipment.

Receiving, handling and storage



Warning

HAZARD OF EQUIPMENT OVERTURNING

When moving with a forklift, do not remove the shipping package until the device is in its final location.

Failure to follow this instruction will result in personal injury or equipment damage.

Receiving and handling

Upon receipt, carefully inspect the switch for damage that may have occurred during transit. If damage is evident, or there is visible indication of rough handling, immediately file a damage claim with the transportation company, and notify your local ABB sales office.

Do not remove the shipping package until ready to install the switch.

Storage

If the unit will not be placed into service immediately, store the switch on its original package in a clean, dry location. To prevent condensation, maintain a uniform temperature. Store the unit in a heated building, allowing adequate air circulation and protection from dirt and moisture. Storing the unit outdoors could cause harmful condensation inside the switch enclosure.

Read these safety instructions carefully before using this product!




Danger

HAZARD OF ELECTRIC SHOCK, EXPLOSION, OR ARC FLASH

- Apply appropriate personal protective equipment and follow safe electrical work practices.
- This equipment must only be installed and serviced by qualified electrical personnel.
- Before performing visual inspections, tests, or maintenance on the equipment, disconnect all sources of electric power. Assume that all circuits are live unless they are completely deenergized, tested, grounded, and tagged. Pay particular attention to the design of the power system. Consider all sources of power, including the possibility of backfeeding.
- Turn off switch before removing or making load side connections.
- Always use a properly rated voltage sensing device at all line and load to confirm switch is off.
- Turn off power supplying switch before doing any other work on or inside switch.


Failure to follow these instructions could result in death or serious injury.

Circuit 6c, 6g



OTDC800...1000F22, _FV22 + OTDCKIT800FS11
OTDC800...1000UF22, _UFV22 + OTDCKIT800FS11

Circuit 6N



OTDC800UF23
OTDC800UFV23

Enclosure dimensioning


Clearances per UL98 / IEC 60947

mm / in



Warning

A minimum distance of 25,4 mm (1 in) from current carried parts to any conductive part.



Dimensions apply to all switch types.

Minimum clearance to any conductive part

From pole	From terminal blade	From mechanism shaft
C1	C2	C3
35 / 1.38	141,9 / 5.59	50,8 / 2.00

Minimum enclosure size or equivalent volume UL98

Switch size	No. of poles	H	W	D
OTDC800F, OTDC1000	4	1000 / 39	800 / 32	330 / 13


Enclosure dimensioning

Clearances per UL98 / IEC 60947

mm / in



Warning
A minimum distance of 25,4 mm (1 in) from current carried parts to any conductive part.



Dimensions apply to all switch types.

Minimum clearance to any conductive part


From pole	From terminal blade	From mechanism shaft
C1	C2	C3
35 / 1.38	141,9 / 5.59	50,8 / 2.00

Minimum enclosure size or equivalent volume UL98


Switch size	No. of poles	H	W	D
OTDC800UF_23	5	500 / 23.64	700 / 27.58	200 / 7.88

Mounting

OTDC_F_




TORX T20
2,2 Nm
20 lb.in





Warning

Magnetic field exceeds 5 Gauss within 15 cm / 6 in of surface. Can erase credit cards. Avoid medical Implant Device proximity.



Busbars and compression lugs




Busbars and compression lugs

Busbar width	[mm / in]
max	80 / 3.14

Minimum Busbar cross-section acc. to UL98B	[mm²]
800 A	520
1000 A	640

Compression Lug dimensions	[mm]
A: Maximum height	34
B: Recommended maximum width	36
C: Maximum length	105
D: Recommended bolt slot	10,5...14,3



Caution

Ensure cable suitability for compression lugs and application requirements. Use max. 2 pcs of compression lugs per switch terminal.




Warning

A minimum distance of 25,4 mm (1 in) from current carried parts to any conductive part.

Connection bar kit


OTDCKIT800FS11



M12 50...75 Nm
443-664 lb.in



OTDCKIT800FS11



Circuit 6c, 6g
OTDC800F22
OTDC800FV22
OTDC800UF22
OTDC800UFV22
OTDC1000F22
OTDC1000FV22
OTDC1000UF22
OTDC1000UFV22




Caution


Installation only as shown in drawings.

Connection bar kit


OTDCKIT800FS12



M12 50...75 Nm
443-664 lb.in



OTDCKIT800FS12



Circuit 6N
OTDC800UF23
OTDC800UFV23




Caution

Installation only as shown in drawings.

Mechanical lug kit

OZXA804




Caution

Always use counter torque when tightening terminals!

M12x25


54,2 Nm

480 lb.in



56,5 Nm

500 lb.in



Warning

A minimum distance of 25,4 mm (1 in) from current carried parts to any conductive part.



Caution


Installation only as shown in drawings.

Single lug cable cross section 2 x AWG 2-600 MCM.




Direct handle kit

OTDV400FK_

OTDV400FK_



OTDV400FK2




Information

Use protection against direct contact. For example, see picture above.

Auxiliary contacts

OA_




Remove


Test contact max. 4 pcs



NO: OA1G10
NC: OA3G01




Test indication contact
max. 4 pcs



Dimension drawings

OTDC800-1000_F_22




*Minimum depth for shaft installation.

Pos.	Accessory	Description
1	Connection bar	OTDCKIT800FS11

Dimension drawings

OTDC800-1000_F_23

mm / in




*Minimum depth for shaft installation.


Pos.	Accessory	Description
1	Connection bar	OTDCKIT800FS12

Dimension drawings

Connection bar kit



OTDCKIT800FS11



OTDCKIT800FS12



BG Внимание! Опасно напряжение! Да се монтира само от лице с електротехническа квалификация.

CN 警告！电压危险！只能由专业电工进行安装。

CZ Varování! Nebezpečné napětí! Montáž smí provádět výhradně elektrotechnik!

DA Advarsel! Farlig elektrisk spænding! Installation må kun foretages af personer med elektroteknisk ekspertise.

DE Warnung! Gefährliche Spannung! Installation nur durch elektrotechnische Fachkraft.

EL Προειδοποίηση! Υψηλή τάση! Η εγκατάσταση πρέπει να γίνεται μόνο από εξειδικευμένους ηλεκτροτεχνικούς.

EN Warning! Hazardous voltage! Installation by person with electrotechnical expertise only.

ES ¡Advertencia! ¡Tensión peligrosa! La instalación deberá ser realizada únicamente por electricistas especializados.

ET Hoiatus! Ohtlik pinge. Paigaldada võib ainult elektrotehnika-alane ekspert.

FI Varoitus! Vaarallinen jännite! Asennuksen voi tehdä vain sähköalan ammattihenkilö.

FR Avertissement! Tension électrique dangereuse! Installation uniquement par des personnes qualifiées en électricité.

HR Upozorenje! Opasan napon! Postavljati smije samo elektrotehnički stručnjak.

HU Figyelmeztetés! Veszélyes feszültség! Csak elektrotechnikai tapasztalattal rendelkező szakember helyezheti üzembe.

IE Rabhadh! Voltas guaiseach! Ba chóir do dhuine ag a bhfuil saineolas leictreiteicniúil, agus an té sin amháin, é seo a shuiteáil.

IT Avvertenza! Tensione pericolosa! Fare installare solo da un elettricista qualificato.

LT Dėmesio! Pavojinga įtampa! Dirbti leidžiama tik elektrotechnikų patirties turintiems asmenims.

LV Uzmanību! Bīstami - elektrība! Montāžas darbus drīkst veikt tikai personas, kurām ir atbilstošas elektrotehniskās zināšanas.

MT Twissija! Vultaġġ perikoluż! Għandu jiġi installat biss minn persuna b'kompetenza elettroteknika.

NL Waarschuwing! Gevaarlijke spanning! Mag alleen geïnstalleerd worden door een deskundige elektrotechnicus.

NO Advarsel! Farlig spenning! Montering skal kun utføres av kvalifiserte personer med elektrokompetanse.

PL Ostrzeżenie! Niebezpieczne napięcie! Instalacji może dokonać wyłącznie osoba z fachową wiedzą w dziedzinie elektrotechniki.

PT Aviso! Tensão perigosa! A instalação só deve ser realizada por um electricista especializado.

RO Avertizare! Tensiune periculoasă! Instalarea trebuie efectuată numai de către o persoană cu experiență în electrotehnică.

RU Осторожно! Опасное напряжение! Монтаж должен выполняться только специалистом-электриком.

SE Varning! Farlig spänning! Installation får endast utföras av en elektriker.

SK Varovanie! Nebezpečné napätie! Montáž môže vykonávať iba skúsený elektrotechnik.

SL Opozorilo! Nevarna napetost! Vgradnjo lahko opravi le oseba z elektrotehničnim strokovnim znanjem.



Contact us

ABB Oy

Muottitie 2A, 65320

Vaasa, Finland

abb.com/lowvoltage