



中国国家强制性产品认证证书

证书编号：2024010304710390

认证委托人名称及地址

ABB France

11 Rue d' Arsonval 69680, Chassieu, FRANCE

生产者名称及地址

ABB France

11 Rue d' Arsonval 69680, Chassieu, FRANCE

生产企业名称及地址

ABB 新会低压开关有限公司

广东省江门市新会区今古洲工业开发区

产品名称和系列、型号、规格

切换电容器接触器

UAF65-**-**RA-**, UAF70-**-**RA-** ; 见附页

产品标准和技术要求

GB/T 14048.4-2020

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》
(CNCA-C03-02:2024) 的要求，特发此证。

发证日期：2025 年 01 月 02 日 有效期至：2030 年 01 月 01 日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验，
也可在认监委网站 (www.cnca.gov.cn) 查询。



签发：

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





中国国家强制性产品认证证书

证书编号: 2024010304710390

证书附页: 第 1 页 共 2 页

UAF65-**-**RA-**, UAF70-**-**RA-**

Ui: 1000V

Uimp: 8kV;

Ith: 1.35 Ie;

UAF65-**-**RA-**:

AC-6b: Ue/Ie: 230-240V/94.1A, 400-415V/93.8A, 500-550V/90.6A, 690V/90.8A;

Qe: 37.5kvar(AC230-240V), 65kvar(AC400-415V), 78.5kvar(AC500-550V),

108.5kvar(AC690V);

UAF70-**-**RA-**:

AC-6b: Ue/Ie: 230-240V/100.4A, 400-415V/101A, 500-550V/98.2A, 690V/100.4A;

Qe: 40kvar(AC230-240V), 70kvar(AC400-415V), 85kvar(AC500-550V),

120kvar(AC690V);

Us: 24-60V 50/60Hz, 20-60V DC; 48-130V 50/60Hz/DC; 100-250V 50/60Hz/DC;

250-500V 50/60Hz/DC;

极数: 3P;

频率: 50/60Hz;

外壳防护等级: IP10;

本页为证书附页, 应与证书主页同时使用。



中国质量认证中心

CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



中国国家强制性产品认证证书

证书编号: 2024010304710390

证书附页: 第 2 页 共 2 页

型号解释:

Example 例如: UAF65-30-00RA-xx

UAF	65	-30	-00	RA	-11
I	II	III	IV	V	VI

I - Name of series 系列名称

UAF 系列 UAF series

II -400V AC-6b 应用下的额定功率 AC-6b Rated power in 400V

65: 65kVar, 70:70kVar

III -Main Pole Construction 主触点对数

30 - 3 常开和 0 常闭 3 normally opened and 0 normally closed main poles.

IV -Auxiliary Pole Construction 辅助触点对数

00 -无辅助触头 0 normally closed auxiliary pole provided.

V -电阻线组件 Block of damping resistor

RA=有电阻线组件 RA = with block of damping resistor

VI- Coil code 线圈代号

Control Voltage 控制电压		Coil code 线圈代号
50/60Hz	DC	
24-60V	20-60V	11
48-130V	48-130V	12
100-250V	100-250V	13
250-500V	250-500V	14

本页为证书附页, 应与证书主页同时使用。



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2024010304710390

NAME AND ADDRESS OF THE APPLICANT

ABB France
11 Rue d'Arsonval 69680, Chassieu, FRANCE

NAME AND ADDRESS OF THE MANUFACTURER

ABB France
11 Rue d'Arsonval 69680, Chassieu, FRANCE

NAME AND LOCATION OF THE FACTORY

ABB Xinhui Low Voltage Switchgear Co.,Ltd.
Jinguzhou Industrial Development Zone, Xinhui District, Jiangmen City, Guangdong Province,
P.R.China

PRODUCT NAME,MODEL AND SPECIFICATION

Contactors for capacitor switching
UAF65-**-**RA-**, UAF70-**-**RA-** ; See the Appendix

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.4-2020

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Jan.02,2025

Valid until: Jan.01,2030

The certificate information and validity could be checked by scanning the QR code below or logging in to
the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO. : 2024010304710390

Appendix: Page 1 of 2

UAF65-**-**RA-**, UAF70-**-**RA-**

Ui: 1000V

Uimp: 8kV;

Ith: 1.35 Ie;

UAF65-**-**RA-**:

AC-6b: Ue/Ie: 230-240V/94.1A, 400-415V/93.8A, 500-550V/90.6A, 690V/90.8A;

Qe: 37.5kvar(AC230-240V), 65kvar(AC400-415V), 78.5kvar(AC500-550V),

108.5kvar(AC690V);

UAF70-**-**RA-**:

AC-6b: Ue/Ie: 230-240V/100.4A, 400-415V/101A, 500-550V/98.2A, 690V/100.4A;

Qe: 40kvar(AC230-240V), 70kvar(AC400-415V), 85kvar(AC500-550V),

120kvar(AC690V);

Us: 24-60V 50/60Hz, 20-60V DC; 48-130V 50/60Hz/DC; 100-250V 50/60Hz/DC;

250-500V 50/60Hz/DC;

3P;

50/60Hz;

IP10;

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2024010304710390

Appendix: Page 2 of 2

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

Type explanation:

Example 例如: UAF65-30-00RA-xx

UAF	65	-30	-00	RA	-11
I	II	III	IV	V	VI

I - Name of series 系列名称

UAF 系列 UAF series

II -400V AC-6b 应用下的额定功率 AC-6b Rated power in 400V

65: 65kVar, 70:70kVar

III -Main Pole Construction 主触点对数

30 - 3 常开和 0 常闭 3 normally opened and 0 normally closed main poles.

IV -Auxiliary Pole Construction 辅助触点对数

00 -无辅助触头 0 normally closed auxiliary pole provided.

V -电阻线组件 Block of damping resistor

RA=有电阻线组件 RA = with block of damping resistor

VI- Coil code 线圈代号

Control Voltage 控制电压		Coil code 线圈代号
50/60Hz	DC	
24-60V	20-60V	11
48-130V	48-130V	12
100-250V	100-250V	13
250-500V	250-500V	14

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.