

EcoStruxure™ Control Engineering Converter

User Guide

Original instructions

EIO0000004425.06

11/2023

Legal Information

The information provided in this document contains general descriptions, technical characteristics and/or recommendations related to products/solutions.

This document is not intended as a substitute for a detailed study or operational and site-specific development or schematic plan. It is not to be used for determining suitability or reliability of the products/solutions for specific user applications. It is the duty of any such user to perform or have any professional expert of its choice (integrator, specifier or the like) perform the appropriate and comprehensive risk analysis, evaluation and testing of the products/solutions with respect to the relevant specific application or use thereof.

The Schneider Electric brand and any trademarks of Schneider Electric SE and its subsidiaries referred to in this document are the property of Schneider Electric SE or its subsidiaries. All other brands may be trademarks of their respective owner.

This document and its content are protected under applicable copyright laws and provided for informative use only. No part of this document may be reproduced or transmitted in any form or by any means (electronic, mechanical, photocopying, recording, or otherwise), for any purpose, without the prior written permission of Schneider Electric.

Schneider Electric does not grant any right or license for commercial use of the document or its content, except for a non-exclusive and personal license to consult it on an "as is" basis.

Schneider Electric reserves the right to make changes or updates with respect to or in the content of this document or the format thereof, at any time without notice.

To the extent permitted by applicable law, no responsibility or liability is assumed by Schneider Electric and its subsidiaries for any errors or omissions in the informational content of this document, as well as any non-intended use or misuse of the content thereof.

Table of Contents

Safety Information.....	5
Before You Begin.....	5
Start-up and Test.....	6
Operation and Adjustments.....	7
About the Book.....	8
Introduction to EcoStruxure Control Engineering - Converter.....	15
Registration, Login, My Account, Licenses and Sessions.....	16
Registration.....	16
Login.....	18
My account Page.....	19
Licenses.....	21
Sessions.....	22
Creating Projects and Programs.....	23
Introduction to Projects and Programs.....	23
Creating Projects and Programs.....	24
Program Creation Wizard.....	26
Accessing a Shared Program.....	29
Sharing Programs with Other Users.....	30
Converting Controller Applications.....	32
Estimation.....	32
Conversion.....	35
Post-Conversion Steps.....	37
Manufacturer-Specific File Export Procedures.....	39
Allen Bradley PLC5 (.PC5, .SY6 Export Files).....	39
Allen Bradley SLC 500 (.SLC and .SY6 Export Files).....	40
April SMC80, SMC600 (Native Application Files).....	41
April Orphee 1000 Series (FTA Export File).....	42
GE Fanuc Intelligent Platforms Proficy Machine Edition V9.5 (.SWXCF File Export).....	43
Mitsubishi GX Works3 (PLCopen .XML File Export).....	44
Rockwell Automation® RSLogix 5000® or Studio 5000 (.L5K File Export).....	45
Siemens SIMATIC STEP 5 (.S5D, Z0.INI Native Files).....	46
Siemens SIMATIC STEP 7 (.ASC, .AWL, .GR7 and .SCL File Export).....	47
Telemecanique TSX 7 Series (.BIN, .CDB Native Files).....	56
Manufacturer-Specific File Import Procedures.....	57
Unity Pro (XEF Import Format).....	57
3S CODESYS V3 (EXPORT Import Format).....	58
Siemens TIA Portal SIMATIC STEP 7 (.ZIP Import Format).....	60

Safety Information

Important Information

Read these instructions carefully, and look at the equipment to become familiar with the device before trying to install, operate, service, or maintain it. The following special messages may appear throughout this documentation or on the equipment to warn of potential hazards or to call attention to information that clarifies or simplifies a procedure.



The addition of this symbol to a “Danger” or “Warning” safety label indicates that an electrical hazard exists which will result in personal injury if the instructions are not followed.



This is the safety alert symbol. It is used to alert you to potential personal injury hazards. Obey all safety messages that follow this symbol to avoid possible injury or death.

DANGER

DANGER indicates a hazardous situation which, if not avoided, **will result in** death or serious injury.

WARNING

WARNING indicates a hazardous situation which, if not avoided, **could result in** death or serious injury.

CAUTION

CAUTION indicates a hazardous situation which, if not avoided, **could result in** minor or moderate injury.

NOTICE

NOTICE is used to address practices not related to physical injury.

Please Note

Electrical equipment should be installed, operated, serviced, and maintained only by qualified personnel. No responsibility is assumed by Schneider Electric for any consequences arising out of the use of this material.

A qualified person is one who has skills and knowledge related to the construction and operation of electrical equipment and its installation, and has received safety training to recognize and avoid the hazards involved.

Before You Begin

Do not use this product on machinery lacking effective point-of-operation guarding. Lack of effective point-of-operation guarding on a machine can result in serious injury to the operator of that machine.

⚠ WARNING

UNGUARDED EQUIPMENT

- Do not use this software and related automation equipment on equipment which does not have point-of-operation protection.
- Do not reach into machinery during operation.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

This automation equipment and related software is used to control a variety of industrial processes. The type or model of automation equipment suitable for each application will vary depending on factors such as the control function required, degree of protection required, production methods, unusual conditions, government regulations, etc. In some applications, more than one processor may be required, as when backup redundancy is needed.

Only you, the user, machine builder or system integrator can be aware of all the conditions and factors present during setup, operation, and maintenance of the machine and, therefore, can determine the automation equipment and the related safeties and interlocks which can be properly used. When selecting automation and control equipment and related software for a particular application, you should refer to the applicable local and national standards and regulations. The National Safety Council's Accident Prevention Manual (nationally recognized in the United States of America) also provides much useful information.

In some applications, such as packaging machinery, additional operator protection such as point-of-operation guarding must be provided. This is necessary if the operator's hands and other parts of the body are free to enter the pinch points or other hazardous areas and serious injury can occur. Software products alone cannot protect an operator from injury. For this reason the software cannot be substituted for or take the place of point-of-operation protection.

Ensure that appropriate safeties and mechanical/electrical interlocks related to point-of-operation protection have been installed and are operational before placing the equipment into service. All interlocks and safeties related to point-of-operation protection must be coordinated with the related automation equipment and software programming.

NOTE: Coordination of safeties and mechanical/electrical interlocks for point-of-operation protection is outside the scope of the Function Block Library, System User Guide, or other implementation referenced in this documentation.

Start-up and Test

Before using electrical control and automation equipment for regular operation after installation, the system should be given a start-up test by qualified personnel to verify correct operation of the equipment. It is important that arrangements for such a check are made and that enough time is allowed to perform complete and satisfactory testing.

⚠ WARNING

EQUIPMENT OPERATION HAZARD

- Verify that all installation and set up procedures have been completed.
- Before operational tests are performed, remove all blocks or other temporary holding means used for shipment from all component devices.
- Remove tools, meters, and debris from equipment.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

Follow all start-up tests recommended in the equipment documentation. Store all equipment documentation for future references.

Software testing must be done in both simulated and real environments.

Verify that the completed system is free from all short circuits and temporary grounds that are not installed according to local regulations (according to the National Electrical Code in the U.S.A, for instance). If high-potential voltage testing is necessary, follow recommendations in equipment documentation to prevent accidental equipment damage.

Before energizing equipment:

- Remove tools, meters, and debris from equipment.
- Close the equipment enclosure door.
- Remove all temporary grounds from incoming power lines.
- Perform all start-up tests recommended by the manufacturer.

Operation and Adjustments

The following precautions are from the NEMA Standards Publication ICS 7.1-1995:

(In case of divergence or contradiction between any translation and the English original, the original text in the English language will prevail.)

- Regardless of the care exercised in the design and manufacture of equipment or in the selection and ratings of components, there are hazards that can be encountered if such equipment is improperly operated.
- It is sometimes possible to misadjust the equipment and thus produce unsatisfactory or unsafe operation. Always use the manufacturer's instructions as a guide for functional adjustments. Personnel who have access to these adjustments should be familiar with the equipment manufacturer's instructions and the machinery used with the electrical equipment.
- Only those operational adjustments required by the operator should be accessible to the operator. Access to other controls should be restricted to prevent unauthorized changes in operating characteristics.

About the Book

Document Scope

The present user guide describes the functionality provided by EcoStruxure Control Engineering - Converter.

Validity Note

This document has been updated for the release of EcoStruxure Control Engineering V23.2.

Available Languages of this Document

This document is available in these languages:

- English (EIO0000004425)
- French (EIO0000004773)

Related Documents

Title of documentation	Reference number
EcoStruxure Control Engineering - Documentation - User Guide	EIO0000004426 (eng) EIO0000004774 (fre)
EcoStruxure Control Engineering - Verification - User Guide	EIO0000004424 (eng) EIO0000004772 (eng)
EcoStruxure Control Engineering - Monitoring - User Guide	EIO0000004427 (eng) EIO0000004775 (fre)
Cybersecurity Best Practices	CS-Best-Practices-2019-340
EDI2200, Manuel de référence	1590595K01000 (fre)
EcoStruxure Control Engineering, Hardening Guide	EIO0000004982 (eng)

To find documents online, visit the Schneider Electric download center (www.se.com/ww/en/download/).

Product Related Information

▲ WARNING

LOSS OF CONTROL

- Perform a Failure Mode and Effects Analysis (FMEA), or equivalent risk analysis, of your application, and apply preventive and detective controls before implementation.
- Provide a fallback state for undesired control events or sequences.
- Provide separate or redundant control paths wherever required.
- Supply appropriate parameters, particularly for limits.
- Review the implications of transmission delays and take actions to mitigate them.
- Review the implications of communication link interruptions and take actions to mitigate them.
- Provide independent paths for control functions (for example, emergency stop, over-limit conditions, and error conditions) according to your risk assessment, and applicable codes and regulations.
- Apply local accident prevention and safety regulations and guidelines.¹
- Test each implementation of a system for proper operation before placing it into service.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

¹ For additional information, refer to NEMA ICS 1.1 (latest edition), *Safety Guidelines for the Application, Installation, and Maintenance of Solid State Control* and to NEMA ICS 7.1 (latest edition), *Safety Standards for Construction and Guide for Selection, Installation and Operation of Adjustable-Speed Drive Systems* or their equivalent governing your particular location.

▲ WARNING

UNINTENDED EQUIPMENT OPERATION

- Perform a risk assessment as per ISO 12100 and/or other equivalent assessment in view of your use of EcoStruxure Control Engineering.
- In your risk assessment, consider all applicable regulations and standards that apply to your development process and to your machine/process.
- Verify that your use of EcoStruxure Control Engineering is fully covered in the definition of your software development process and that your software development process meets all applicable regulations and standards.
- After modifications of any type whatsoever to the source code of your application resulting from your use of EcoStruxure Control Engineering, commission or recommission the machine/process in compliance with all regulations, standards, and process definitions applicable to your machine/process.
- During commissioning or recommissioning of the machine/process, verify the correct operation and effectiveness of all safety-related functions and non-safety-related functions by performing comprehensive tests for all operating states, for the defined safe state of your machine/process, and for all potential error situations.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

EcoStruxure Control Engineering - Converter converts the application logic, database, structure, and behavior of controller applications. Infrastructure-specific code (for example, code relating to hardware, communication infrastructure, configuration, axes, counters) is not converted or may only be partially converted, for example, because the tool cannot be aware of the configuration and requirements of your target system. Therefore, certain code parts will miss from the converted code, or have only been partially converted.

You must subject the entire code converted by EcoStruxure Control Engineering - Converter to a full review, verification and validation.

In this process, you must, among other things, adapt the code to your target infrastructure. The information on post-conversion steps provided in the present user guide is not exhaustive, because only you, the user of EcoStruxure Control Engineering - Converter, can be aware of all requirements relating to your target controller application.

⚠ WARNING

UNINTENDED EQUIPMENT OPERATION

- In your risk assessment, consider all potential effects of using EcoStruxure Control Engineering - Converter, including, but not limited to, inappropriate, incorrect or incomplete input code as well as inappropriate, incorrect or incomplete converted output code.
- Verify that the converted code is properly adapted to all requirements of your target system.
- Subject the converted code to a full review, verification and validation by appropriately qualified personnel; and according to all applicable regulations, standards, and process definitions.
- Do not rely on the conversion report provided by EcoStruxure Control Engineering - Converter as the sole source of information in reviewing, verifying, validating, or otherwise assessing or using the converted code.
- Ensure that your overall machine/process for which EcoStruxure Control Engineering - Converter has been used is properly certified and/or approved according to all standards, regulations, and directives applicable at the installation site of the machine/process.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

EcoStruxure Control Engineering - Converter is neither certified nor intended for conversion of safety-related code.

⚠ WARNING

INSUFFICIENT AND/OR INEFFECTIVE SAFETY-RELATED FUNCTIONS

- Do not convert safety-related code with EcoStruxure Control Engineering - Converter.
- Re-design any and all converted code in compliance with all applicable safety-related regulations, standards, and certification requirements if, after the conversion, you decide to use any part of such converted code for safety-related purposes.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

No tool can provide analysis procedures for all potential types of code and methods of creating code. For example, a code block in your source code may be semantically invalid, but syntactically correct. The tool may not be able to detect such a condition.

Software development environments may provide code protection features intended to, for example, block access to intellectual property. Unlock such protected code blocks in your software development environment before creating export files to be used with EcoStruxure Control Engineering.

▲ WARNING

INCORRECT OR INCOMPLETE SOURCE CODE ANALYSIS

- In your risk assessment, consider all potential effects of inappropriate, incorrect, or incomplete input files used with EcoStruxure Control Engineering.
- Verify that the source code exported from your software development environment and to be used by EcoStruxure Control Engineering is complete and up to date.
- After modifications of any type whatsoever to the source code of your application resulting from your use of EcoStruxure Control Engineering, verify the correctness of the modified source code.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

Machines, controllers, and related equipment are usually integrated into networks. Unauthorized persons and malware may gain access to the machine as well as to other devices on the network/fieldbus of the machine and connected networks because of insufficiently secure access to software and networks.

Schneider Electric adheres to industry best practices in the development and implementation of control systems. This includes a "Defense-in-Depth" approach to secure an Industrial Control System. This approach places the controllers behind one or more firewalls to restrict access to authorized personnel and protocols only.

⚠ WARNING

UNAUTHENTICATED ACCESS AND SUBSEQUENT UNAUTHORIZED MACHINE OPERATION

- Evaluate whether your environment or your machines are connected to your critical infrastructure and, if so, take appropriate steps in terms of prevention, based on Defense-in-Depth, before connecting the automation system to any network.
- Limit the number of devices connected to a network to the minimum necessary.
- Isolate your industrial network from other networks inside your company.
- Protect any network against unintended access by using firewalls, VPN, or other, proven security measures.
- Monitor activities within your systems.
- Prevent subject devices from direct access or direct link by unauthorized parties or unauthenticated actions.
- Prepare a recovery plan including backup of your system and process information.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

For more information on organizational measures and rules covering access to infrastructures, refer to ISO/IEC 27000 series, Common Criteria for Information Technology Security Evaluation, ISO/IEC 15408, IEC 62351, ISA/IEC 62443, NIST Cybersecurity Framework, Information Security Forum - Standard of Good Practice for Information Security, and refer to Cybersecurity Guidelines for EcoStruxure Machine Expert, Modicon and PacDrive Controllers and Associated Equipment.

For reasons of Internet security, for those devices that have a native Ethernet connection, TCP/IP forwarding is disabled by default. Therefore, you must manually enable TCP/IP forwarding. However, doing so may expose your network to possible cyberattacks if you do not take additional measures to protect your enterprise. In addition, you may be subject to laws and regulations concerning cybersecurity.

⚠ WARNING

UNAUTHENTICATED ACCESS AND SUBSEQUENT NETWORK INTRUSION

- Observe and respect any and all pertinent national, regional and local cybersecurity and/or personal data laws and regulations when enabling TCP/IP forwarding on an industrial network.
- Isolate your industrial network from other networks inside your company.
- Protect any network against unintended access by using firewalls, VPN, or other, proven security measures.

Failure to follow these instructions can result in death, serious injury, or equipment damage.

Consult the Schneider Electric Cybersecurity Best Practices for additional information.

Information on Non-Inclusive or Insensitive Terminology

As a responsible, inclusive company, Schneider Electric is constantly updating its communications and products that contain non-inclusive or insensitive terminology. However, despite these efforts, our content may still contain terms that are deemed inappropriate by some customers.

Terminology Derived from Standards

The technical terms, terminology, symbols and the corresponding descriptions in the information contained herein, or that appear in or on the products themselves, are generally derived from the terms or definitions of international standards.

In the area of functional safety systems, drives and general automation, this may include, but is not limited to, terms such as *safety*, *safety function*, *safe state*, *fault*, *fault reset*, *malfunction*, *failure*, *error*, *error message*, *dangerous*, etc.

Among others, these standards include:

Standard	Description
IEC 61131-2:2007	Programmable controllers, part 2: Equipment requirements and tests.
ISO 13849-1:2023	Safety of machinery: Safety related parts of control systems. General principles for design.
EN 61496-1:2013	Safety of machinery: Electro-sensitive protective equipment. Part 1: General requirements and tests.
ISO 12100:2010	Safety of machinery - General principles for design - Risk assessment and risk reduction
EN 60204-1:2006	Safety of machinery - Electrical equipment of machines - Part 1: General requirements
ISO 14119:2013	Safety of machinery - Interlocking devices associated with guards - Principles for design and selection
ISO 13850:2015	Safety of machinery - Emergency stop - Principles for design
IEC 62061:2021	Safety of machinery - Functional safety of safety-related electrical, electronic, and electronic programmable control systems
IEC 61508-1:2010	Functional safety of electrical/electronic/programmable electronic safety-related systems: General requirements.
IEC 61508-2:2010	Functional safety of electrical/electronic/programmable electronic safety-related systems: Requirements for electrical/electronic/programmable electronic safety-related systems.
IEC 61508-3:2010	Functional safety of electrical/electronic/programmable electronic safety-related systems: Software requirements.
IEC 61784-3:2021	Industrial communication networks - Profiles - Part 3: Functional safety fieldbuses - General rules and profile definitions.
2006/42/EC	Machinery Directive
2014/30/EU	Electromagnetic Compatibility Directive
2014/35/EU	Low Voltage Directive

In addition, terms used in the present document may tangentially be used as they are derived from other standards such as:

Standard	Description
IEC 60034 series	Rotating electrical machines
IEC 61800 series	Adjustable speed electrical power drive systems
IEC 61158 series	Digital data communications for measurement and control – Fieldbus for use in industrial control systems

Finally, the term *zone of operation* may be used in conjunction with the description of specific hazards, and is defined as it is for a *hazard zone* or *danger zone* in the *Machinery Directive (2006/42/EC)* and *ISO 12100:2010*.

NOTE: The aforementioned standards may or may not apply to the specific products cited in the present documentation. For more information concerning the individual standards applicable to the products described herein, see the characteristics tables for those product references.

Introduction to EcoStruxure Control Engineering - Converter

EcoStruxure Control Engineering - Converter is a code conversion and re-engineering tool for controller applications. The tool supports modernization and migration projects by converting a controller application to a different controller brand, model, and/or programming language, maintaining the behavior and semantics of the source controller application.

EcoStruxure Control Engineering - Converter focuses on the conversion of the application logic, database, structure, and behavior. Infrastructure-specific code (for example, code relating to hardware, communication infrastructure and configuration) is not converted, for example, because the tool cannot be aware of the configuration and requirements of your target system.

EcoStruxure Control Engineering - Converter is a Software as a Service (SaaS) tool accessible using a web browser.

The number of source and target systems that EcoStruxure Control Engineering - Converter supports is increased on an ongoing basis. The supported systems are available at <https://ecostruxure-control-engineering.se.app/>.

Registration, Login, My Account, Licenses and Sessions

Registration

Overview

The EcoStruxure Control Engineering tools are accessible using the cloud version or using a dedicated server for your organization.

The URL of the cloud version is <https://ecostruxure-control-engineering.se.app/>.

If a dedicated server has been set up for your organization, the URL is available from your system administrator.

In both cases, you must create a user account to use the tools.

Browser Compatibility

The following web browsers are supported:

- Mozilla Firefox from version 11
- Google Chrome from version 16
- Microsoft Edge from version 12
- Microsoft Internet Explorer from version 10
- Apple Safari from version 7

Account Types

The following types of accounts are available:

- For the cloud version: Schneider Electric Account
- For the dedicated server version: EcoStruxure Control Engineering Account

Registration with the Cloud Version

Registration procedure:

Step	Action
1	Go to https://ecostruxure-control-engineering.se.app/ .
2	Click Use a Schneider Electric Account .
3	Click Register .
4	Enter your registration information and complete the registration by following the on-screen instructions.

Registration with the Dedicated Server Version


Registration procedure:

Step	Action
1	In your browser, go to the URL of the dedicated server.
2	Click Sign up .
3	Fill in the form with your first and last names, your phone number, your e-mail address (which is used as your identifier) and select a password. Password requirements: <ul style="list-style-type: none">• At least one uppercase character• At least one lowercase character• At least one numerical character• At least one special character (such as "{", "!", "\$")• Password length between 8 and 32 characters
4	Read the <i>Terms and Conditions</i> and, if you agree, select I agree to the Terms and Conditions .
5	Click Sign Up . Result: A verification e-mail is sent to you.
6	The verification e-mail sent to you contains a link that you need to follow. Result: Your account is activated within a period of 48 working hours.

Contact your system administrator for further details on the registration procedure.


Login

Logging into the Cloud Version Using a Schneider Electric Account

Step	Action
1	When your registration on the Schneider Electric account is completed and your account is ready, go to https://ecostruxure-control-engineering.se.app/ .
2	Click Use a Schneider Electric Account .
3	<p>Enter your email address, click Next and then enter your password.</p> <p>Result: After validation, you are redirected to your dashboard.</p> 

NOTE: If you use an EcoStruxure Control Engineering account but want to migrate to a Schneider Electric account, create a Schneider Electric user account that uses the same email address as your EcoStruxure Control Engineering account. After the first login with a Schneider Electric account, subsequent logins must be completed using your Schneider Electric account. For more information on Schneider Electric accounts, contact your local Schneider Electric service representative.


Logging into the Dedicated Server Version Using an EcoStruxure Control Engineering Account

Step	Action
1	In your browser, go to the URL of the dedicated server.
2	Enter your email address and password.
3	<p>Click Login.</p> <p>Result: After validation, you are redirected to your dashboard.</p> 

My account Page

My account Page When Using a Schneider Electric Account

The **My account** page helps you to access the personal information of the account and the global EcoStruxure Control Engineering platform settings.

Step	Action
1	In Dashboard window, click  . Result: A context menu appears.
2	Click My account . Result: My account window appears.

The **Schneider Electric Profile** tab lists the user personal information such as the identity, phone number, country. To update this information, you need to edit your Schneider Electric profile, which is accessible with the link provided in the **Schneider Electric Profile** tab.

The **Third-Party Apps Settings** tab allows you to generate an applicative password to connect your application to EcoStruxure Control Engineering when your application does not support the Schneider Electric account authentication.

From the **Notifications** tab, you can configure the type of email notifications sent to you by the web platform. For example, you can choose to receive a confirmation email at the end of a controller code analysis.

The **View Settings** tab allows you to choose between the different views available on the web platform.


The **Privacy** tab provides general information, actions and instructions about privacy practices and cookies policy. It enables you to understand how private data are used, what are the services that can access it and for which purpose, and to exercise your rights toward the retention and information on your private data.

You can delete the personal information if:

- you are using dedicated server and the server is configured to send the emails.
- you are using cloud version (Not applicable for Monitoring)

My account Page When Using an EcoStruxure Control Engineering Account

The **My account** page helps you to access the personal information of the account and the global EcoStruxure Control Engineering platform settings.

Step	Action
1	In Dashboard window, click  . Result: A context menu appears.
2	Click My account . Result: My account window appears.

The **Profile** tab lists the user personal information such as the identity, phone number, country, etc. You can update this information at any time.

The **Password** tab provides the password change form. You can change your password at any time.

From the **Notifications** tab, you can configure the type of email notifications sent to you by the web platform. For example, you can choose to receive a confirmation email at the end of a controller code analysis.

The **View Settings** tab allows you to choose between different views available on the web platform.

The **Privacy** tab provides general information, actions and instructions about privacy practices and cookies policy. It enables you to understand how private data are used, what are the services that can access it and for which purpose, and to exercise your rights toward the retention and information on your private data.

You can delete the personal information if:

- you are using dedicated server and the server is configured to send the emails.
- you are using cloud version (Not applicable for Monitoring)

Licenses

Overview

Schneider Electric offers various license plans for EcoStruxure Control Engineering tools.

Paid License Plans

Contact your local Schneider Electric representative for details on the available license plans for EcoStruxure Control Engineering tools. A selection of licenses is also directly available from Schneider Electric Exchange at <https://exchange.se.com/shop>.

Sessions

Automatic Log-Out (Session Time-Out)

After 11 minutes of inactivity in an EcoStruxure Control Engineering session, you are automatically logged out. If you work with multiple browser tabs, the most recent activity in any of the tabs applies. For example, if you work in tab 1, but not in tab 2, tab 2 does not disconnect you because there is activity in tab 1.

You are about to be logged out

There has been no activity on your account for the last 10 minute(s). With no action on your side, we will log you out in 1 minute(s).

Stay Logged In

Multiple Sessions

If your credentials are used in multiple sessions, you receive a notification. For example, if you are logged in and another session is established with the same credentials, you receive the following message:

You are authenticated several times

Your credentials have been used to open several sessions of the EcoStruxure Control Engineering web platform. As this may be unintended, here is the list of open sessions with your credentials. You may choose to close any simultaneous sessions.

If you did not authenticate several times, then this situation may be due to your account being compromised. You should close all other sessions and change your password. If the problem persists, then you need to contact your local Schneider Electric representative for support.

<input type="checkbox"/>	Date	IP Address	Operating System	Web Browser
<input type="checkbox"/>	2022-08-19 14:18:47	10.0.2.2	linux	Mozilla Firefox
<input type="checkbox"/>	2022-08-19 16:19:54	10.0.2.2	linux	Mozilla Firefox

Close Session(s)
Close

The information on the connection date and time, the IP address, the operating system and browser help you to determine whether or not a sessions is legitimate. You can select and close a session with **Close Session(s)**.

Creating Projects and Programs

Introduction to Projects and Programs

Overview

EcoStruxure Control Engineering provides projects and programs for you to organize your work.

A project is a type of container that can hold programs. A project is not specific to an EcoStruxure Control Engineering tool.

When you register with EcoStruxure Control Engineering, the platform provides one default project for you.

A program is assigned to a project. A program is created in conjunction with one of the tools provided by EcoStruxure Control Engineering. A program typically comprises metadata you entered during its creation, the uploaded source code of a controller application, and the results generated with the EcoStruxure Control Engineering tools.

The EcoStruxure Control Engineering tools are launched from within a program. Whether or not a specific EcoStruxure Control Engineering tool is available for a program depends on the source controller/development environment you select during the creation of the program (**PLC Brand** or **PLC source brand**).

Programs can be shared with other users.

Example

Assume you have been assigned the task of improving a machine ABC with two controllers X and Y. In a first step, you want to better understand the code of the two controller applications. You create a project "Machine ABC". Then you add two programs to this project: "Controller X" and "Controller Y".

In both of these programs, you run EcoStruxure Control Engineering - Documentation to visualize the data flow and the control flow.


In a subsequent step, your task is extended to managing the creation of a new version of the controller applications. You start by running EcoStruxure Control Engineering - Verification in your programs to verify the existing code. You share the two programs with the developers so they can access the results of the code verification for assistance in updating the code.

In subsequent steps, you can upload intermediate versions of the updated code into your program and re-run EcoStruxure Control Engineering - Documentation and EcoStruxure Control Engineering - Verification to document the progress and verify that your coding rules have been properly implemented.

Creating Projects and Programs

Creating Projects

Procedure for creating a project:

Step	Action
1	Select PROJECTS in the top menu to display the Projects page.
2	Select Actions > New project . 
3	Provide a unique name for your project. Lowercase and uppercase are ignored which means that, for example, the name of a project to be created cannot be "Controller xyz" if you already have a project with the name "Controller XYZ". Click Add to create it.
4	Click Add to create the project. Result: The project is added to your list of projects on the Open projects tab.

Clicking a project in the list displays two tabs. The **Overview** tab provides general information on the project. The **Programs** tab contains the list of programs assigned to this project.

Creating Programs

There are three ways to start the creation of a program:

- From outside of a project select **TOOLS** on the main menu
- From the dashboard click **New ...**
- From inside a project on its **Programs** tab select **Actions > New program**


Creating a program from outside of a project:

Step	Action
1	From the main menu, select TOOLS .
2	Select the tool you want to use for the program. Result: EcoStruxure Control Engineering starts the program creation wizard.

Creating a program from the dashboard:

Step	Action
1	From the main menu, select DASHBOARD .
2	Click the New ... button for the tool you want to use for the program. Result: EcoStruxure Control Engineering starts the program creation wizard.

Creating a program from inside a project:

Step	Action
1	From the main menu, select PROJECTS .
2	Select the required project from the list.
3	Display the Programs tab of the project.
4	Select Actions > New program .  Result: EcoStruxure Control Engineering prompts you for the tool to be used for the program and starts the program creation wizard.

Program Creation Wizard

Overview

A wizard guides you through the different steps required to create your program and launch the execution of the selected EcoStruxure Control Engineering tool.

The project to which the new program is assigned depends on how the wizard is started. If the wizard is started from outside of a project or from the dashboard, the program is assigned to your default project. If the wizard started from inside a project, the program is assigned to this project. In both cases, the project assignment can be adjusted in step 1 of the wizard.

Refer to [Creating Programs](#), page 24 for details.

Step 1 - Start

The first step consists of providing setup information on the program.

1 Start
Setup program information

2 Parameters
Converter parameters

3 License
Associate license

4 Source file
Upload source files

5 Summary
Summary of your program

Application name* : converter-app

Customer name* : Schneider Electric

PLC site address :

PLC site city :

PLC reference :

PLC function :

Project : default - Default project

Validate And Next Step

Provide the following information:

- The fields **Application name** and **Customer name** are mandatory. The defined **Application name** is used to identify the program in the different views of EcoStruxure Control Engineering.
- Add additional information in the other fields so that you can identify this program in your project.

Continue with the next step by clicking **Validate And Next Step**.

Step 2 - Parameters

The second step consists of selecting the source development environment that was used to develop the controller application and the required target development environment for the converted code.

1 Start
Setup program information

2 Parameters
Converter parameters

3 License
Associate license

4 Source file
Upload source files

5 Summary
Summary of your program

PLC source brand*: Siemens - Simatic Step7 (S7-300, S7-400, C7)

PLC destination brand*: Schneider-Electric Unity Pro

PLC destination CPU type: M580

Previous Step

Validate And Next Step

Select the source development environment from the dropdown listbox **PLC source brand**. Then select the target development environment from the dropdown listbox **PLC destination brand** (the available options depend on your selection for the source development environment).

You can optionally specify the kind of controller used with your target development environment.

Continue with the next step by clicking **Validate And Next Step**.

Step 3 - License

The third step in creating an EcoStruxure Control Engineering program typically consists of selecting the EcoStruxure Control Engineering license to be used with your new program.

1 Start
Setup program information

2 Parameters
Converter parameters

3 License
Associate license

4 Source file
Upload source files

5 Summary
Summary of your program

This wizard will launch a free estimation of your chosen conversion and no license is required for this first step.
Once you have the estimation, you will be able to choose if you would like to go further and launch the full conversion. You will be asked to associate a license at this point in time.
To continue with the free estimation of your conversion, please click Validate and Next Step.

Previous Step

Validate And Next Step

An EcoStruxure Control Engineering - Converter program consists of the two main phases of estimation and actual conversion. The estimation is based on a code analysis that is started when you finish the wizard. It provides key metrics on the convertibility of your source code (refer to *Estimation*, page 32 for details). The estimation can be launched without a license. Based on the results of the estimation, you can decide whether you want to convert your code. If you opt for an actual conversion after the estimation, EcoStruxure Control Engineering - Converter prompts you for a license.

Click **Validate And Next Step** to continue.

Step 4 - Source file

The fourth step consists of uploading the file with the source code of the controller application that you have exported from the development environment (refer to *Manufacturer-Specific File Export Procedures*, page 39 for details). This source code is the input material for EcoStruxure Control Engineering. Depending on the EcoStruxure Control Engineering tool used for the program, you may be prompted to upload additional files.



This step is optional, you can choose to upload the source code files later.

DRAG YOUR FILES HERE

OR

Please provide a complete, up-to-date code export of your PLC code. If some code is missing in your program, this code will not be analyzed.

Supported files

- *.AWL
- *.GR7
- *.SCL
- *.ASC
- OR
- *.DIF
- *.CFG
- OR
- *.ZIP

[More about the allowed files for your PLC brand](#)
[How to get supported files?](#)

Drag and drop the files to the location indicated or click **Select Files...** to import the files. Then click **Validate And Next Step** to continue.

If the input files are not yet available when you create the program, you can skip the upload with **Validate And Next Step** and provide the files at a later point in time. Without the uploaded input files, the EcoStruxure Control Engineering tool selected for this program cannot be executed.

Step 5 - Summary

The fifth step displays a summary of the information you have provided in creating your program.



Application name	converter-app	Customer name	Schneider Electric
PLC site city	N/A	PLC reference	N/A
PLC site address	N/A	PLC function	N/A
PLC source brand	Siemens - Simatic Step7 (S7-300, S7-400, C7)		
PLC destination brand	Schneider-Electric Unity Pro		
PLC destination CPU type	M580		

In order to help you to understand the EcoStruxure Control Engineering - Converter usages and limitations, the important Safety information about the product is available through the link below. You are able to retrieve them in the dashboard and in your programs tabs. These messages are also available in the product documentation.

[Read the safety information summary](#)
[Download the user guide \(English\)](#)




Review the information. If you want to make modifications, click **Previous Step** to return to the step you want to modify.

If the information is correct, click **Create** to create the program or click **Launch** to create the program and to start the EcoStruxure Control Engineering tool selected for this program (this is possible if you have uploaded the required files).

Accessing a Shared Program

If a program is shared with you, or if access to the program is not restricted (refer to Sharing a Program, page 30), you can add it to your list of programs by providing its unique 6-digit key. The unique 6-digit key can be found in the program overview under **Application key**.

Procedure for adding a program to your list of programs using its unique 6-digit key:

Step	Action
1	<p>From the menu, select PROJECTS to access the Projects page.</p> 
2	<p>Click Shared applications to display the corresponding tab.</p> 
3	<p>Enter the unique 6-digit key of the program in the field below User personal accesses or in the field below One time access, depending on whether you want to add this program to your personal records for access at a later point in time, or whether you want to access it only once without adding it to your list of programs.</p> 
4	<p>Click Add To My Applications or One Time Access.</p>

Sharing Programs with Other Users

Overview


You can share your programs with other users so that a team can work on the same project. As the owner, you can share your program. Selected users with whom you share your program cannot delegate their access rights, that is, they cannot share this shared program with further users.

There are two ways of sharing a program:

- Share with selected users: You choose who can access your program. By default, other users cannot share this program because you are the owner.
- Share with everyone: Everyone can access your program.

Sharing with a Specific User

Procedure for sharing a program with selected users:

Step	Action
1	Navigate to the Program page.
2	Select Admin > Collaboration > Users access rights to display the User management .
3	Below Invited collaborators , select Actions > Add . 
4	Enter the name and the e-mail address of the user to be invited. You can enter the e-mail address the user specified for registration with EcoStruxure Control Engineering, or you can use any other e-mail address. You can also send an invitation notification to the user. On a dedicated server, the invitation notification function requires a mail server. Users added to the list of invited users can perform the same actions as you, except for sharing the program and modifying its settings. If you do not want invited users to perform any further actions, deactivate the program with the Active application checkbox in Admin > Settings . This sets your program to read-only.

NOTE: If your program uses the EcoStruxure Control Engineering - Verification tool, invited users may not be able to update the rules file and may not be able to work with the Justifications function. Refer to the EcoStruxure Control Engineering - Verification user guide for details.

You can revoke sharing by selecting the user(s) you want to remove from your program and selecting **Actions > Remove access**.

Sharing with Everyone

Procedure for sharing a program with everyone:

Step	Action
1	Navigate to the Program page.
2	Select Admin > Settings .
3	<p>Enable the checkbox Private application.</p> <p>Users accessing your program can perform the same actions as you, except for sharing the program and modifying its settings. If you do not want invited users to perform any further actions, deactivate the program with the Active application checkbox in Admin > Settings. This sets your program to read-only.</p>

NOTE: If your program uses the EcoStruxure Control Engineering - Verification tool, invited users may not be able to update the rules file and may not be able to work with the Justifications function.

You can disable sharing with everybody by deactivating the checkbox **Private application**. With this setting, only users explicitly invited can access your program.

Converting Controller Applications

Estimation

General Information

The estimation process is the first phase of a conversion. The objective is to collect information on the potential result of the conversion without actually carrying out the conversion. This provides an overview of the potential quantity and quality of converted code and lets you assess the remaining post-conversion effort.

This estimation is available after the program wizard has been run for the first time. It is possible to run several estimation processes for a given program, even with several target controller/development environments so you can assess different scenarios with your program.

The estimation report provides the following sections:


- **Summary**
- **Statistical Conversion Capability**
- **Conversion Highlight**

To access the estimation report, click **Converter > {target controller/development environment} > Estimation Report**.

Section Summary

The section **Summary** provides an overview of the key information concerning the convertibility of your source code.

Summary

Source			Destination	
PLC Brand :	Schneider-Electric		PLC Brand :	Schneider-Electric
IDE :	Telepace Studio 5.0		IDE :	Schneider Remote Connect
Number of Instructions :	511		Number of Instructions :	511
File Name :	get_set.tpj (147.19 kB)			

^ Less detail

Buy the converted code

Once you have read this estimation report and if you are satisfied with it, you can pay for a full conversion to be carried out. This will allow you to download the converted code.

[Proceed](#)

Download Report PDF

Export your conversion result into a sharable and archivable PDF file for your reference. This file contains the same information than this page.

[Download](#)

The upper part of the summary contains a table with information on the source and the destination controllers/development environments.

The lower part of the summary provides the following possibilities:

- Proceed to the conversion of the source code.
For details see Starting the Actual Conversion, page 34.
- Download the estimation report as a PDF file.


Section Statistical Conversion Capability

The section **Statistical Conversion Capability** provides percentage information on the amount of code that can be converted and the percentage of detected issues in the code to be converted.

Statistical Conversion Capability

These charts shows the amount of elements the EcoStruxure Control Engineering - Converter is able to convert. The process operated with 2 main operations:

- Converting the Instructions in your program. These instructions has been written for your company, and are the heart of your Intellectual Property and process operations. The more they are converted, the less you will have to re-write them in the converted code.
- Converting the External libraries used in your program. This code is a set of functionalities shipped with your old programming environment and that your program uses. As it provides valuable functionalities, it means to be mapped to an equivalent or a new implementation for your converted program to be able to behave as close as possible to the original one. The more they are converted, the less you will have to re-write then in the converted code.



Section Conversion Highlight

The section **Conversion Highlight** provide information on the elements found during the estimation of your source code.

Conversion Highlight

During the conversion process, some errors, inconsistencies or impediments can be detected by the EcoStruxure Control Engineering - Converter. These elements are highlighted in the table below for you to have a precise understanding of how the process has gone. Each one of the elements below needs a special attention once the code is converted as it may have an impact on the quality, the logic or the efficiency of the converted code. You can browse these messages by entities in your original code.

Message	Severity	Knowledge Base
0% of library telepace_remoteconnect_lib usage should be reviewed.	Info	-
0% of library telepace_remoteconnect_lib usage should manually be implemented	Info	-
100% of library telepace_remoteconnect_lib usage is correctly translated.	Info	-

The left side provides a menu structure similar to the internal structure of your source code.

The right side provides a list of detected issues you need to review and resolve in the converted code before the code can be used.


The column **Knowledge Base** may contain an article detailing the conversion process and various steps you need to take after having downloaded the converted code.

The list contains detected blocking issues for the code conversion. Conversion impediment conditions must be resolved in the original source code before the code conversion can be started. The list provides information on the causes that keep the code from being converted. Correct detected conversion impediments in your source code. Then, re-upload your corrected source code and run a new estimation with the updated program.


The list contains also detected issues that do not prevent the code from being converted, but that can affect the quality of the converted code in such a way that you may want to resolve them in the original code before starting the code conversion.

Starting the Actual Conversion

To start the conversion, click the **Proceed** button in the section **Summary**.



The following window appears:



Read the message and, if you agree, select the checkbox and click **Proceed**. This step requires a valid license.

If the estimation contains detected conversion impediments in your source code, you cannot start the actual conversion. Correct detected conversion impediments in your source code. Then, re-upload your corrected source code and run a new estimation with the updated program.

After the conversion is complete, you can access the conversion report using the menu of the program.

Conversion

General Information

The conversion process takes place in a second phase, after the estimation process.

A conversion report is available after the conversion process has been completed.

The conversion report provides the following sections:

- **Summary**
- **Statistical Conversion Capability**
- **Conversion Highlight**

To access the conversion report, click **Converter > {target controller/development environment} > Conversion Report**.

Section Summary

The section **Summary** provides an overview of the key metrics concerning your converted source code.

Summary

Source		Destination	
PLC Brand :	Schneider-Electric	PLC Brand :	Schneider-Electric
IDE :	Telepace Studio 5.0	IDE :	Schneider Remote Connect
Number of Instructions :	511	Number of Instructions :	511
File Name :	get_set.tpj (147,19 kB)		

^ Less detail

Converted Code
Your PLC code has been converted and the result is available for download from there, click on the button below to download it.

[Download](#)

Post-Conversion Guidelines
Guidelines about the operations to perform to finalize your conversion are available in our Knowledge DB, click on the button below to display them.

[View](#)

Download Report PDF
Export your conversion result into a sharable and archivable PDF file for your reference. This file contains the same information than this page.

[Download](#)

The upper part of the summary contains a table with information on the source and the destination controllers/development environments.

The lower part of the summary provides the following possibilities:

- Download the converted source code
- View post-conversion guidelines
- Download the conversion report as a PDF file


Section Statistical Conversion Capability

The section **Statistical Conversion Capability** provides percentage information on the amount of code that has been converted and the percentage of detected issues in the converted code.

Statistical Conversion Capability

These charts shows the amount of elements the EcoStruxure Control Engineering - Converter is able to convert. The process operated with 2 main operations:

- Converting the Instructions in your program. These instructions has been written for your company, and are the heart of your Intellectual Property and process operations. The more they are converted, the less you will have to re-write them in the converted code.
- Converting the External libraries used in your program. This code is a set of functionalities shipped with your old programming environment and that your program uses. As it provides valuable functionalities, it means to be mapped to an equivalent or a new implementation for your converted program to be able to behave as close as possible to the original one. The more they are converted, the less you will have to re-write then in the converted code.



Section Conversion Highlight

The section **Conversion Highlight** provide information on the elements found during the conversion of your source code.

Conversion Highlight

During the conversion process, some errors, inconsistencies or impediments can be detected by the EcoStruxure Control Engineering - Converter. These elements are highlighted in the table below for you to have a precise understanding of how the process has gone. Each one of the elements below needs a special attention once the code is converted as it may have an impact on the quality, the logic or the efficiency of the converted code. You can browse these messages by entities in your original code.

Unlocalised

Messages under the directory Unlocalised

Search :

Message	Severity	Knowledge Base
0% of library telepace_remotecomnect_lib usage should be reviewed.	Info	-
0% of library telepace_remotecomnect_lib usage should manually be implemented	Info	-
100% of library telepace_remotecomnect_lib usage is correctly translated.	Info	-

Show entries Page / 1

The left side provides a menu structure similar to the internal structure of your source code.

The right side provides a list of detected issues you need to review and resolve in the converted code before the code can be used.

The column **Knowledge Base** contains an article detailing the conversion process and various steps you need to take after having downloaded the converted code.

Post-Conversion Steps

General Information

EcoStruxure Control Engineering - Converter converts the application logic, database, structure, and behavior of controller applications. Infrastructure-specific code (for example, code relating to hardware, communication infrastructure, configuration, axes, counters) is not converted or may only be partially converted, for example, because the tool cannot be aware of the configuration and requirements of your target system. Therefore, certain code parts will miss from the converted code, or have only been partially converted.

You must subject the entire code converted by EcoStruxure Control Engineering - Converter to a full review, verification and validation.

In this process, you must, among other things, adapt the code to your target infrastructure. The information on post-conversion steps provided in the present user guide is not exhaustive, because only you, the user of EcoStruxure Control Engineering - Converter, can be aware of all requirements relating to your target controller application.

▲ WARNING
<p>UNINTENDED EQUIPMENT OPERATION</p> <ul style="list-style-type: none"> • In your risk assessment, consider all potential effects of using EcoStruxure Control Engineering - Converter, including, but not limited to, inappropriate, incorrect or incomplete input code as well as inappropriate, incorrect or incomplete converted output code. • Verify that the converted code is properly adapted to all requirements of your target system. • Subject the converted code to a full review, verification and validation by appropriately qualified personnel; and according to all applicable regulations, standards, and process definitions. • Do not rely on the conversion report provided by EcoStruxure Control Engineering - Converter as the sole source of information in reviewing, verifying, validating, or otherwise assessing or using the converted code. • Ensure that your overall machine/process for which EcoStruxure Control Engineering - Converter has been used is properly certified and/or approved according to all standards, regulations, and directives applicable at the installation site of the machine/process. <p>Failure to follow these instructions can result in death, serious injury, or equipment damage.</p>

EcoStruxure Control Engineering - Converter is neither certified nor intended for conversion of safety-related code.

▲ WARNING
<p>INSUFFICIENT AND/OR INEFFECTIVE SAFETY-RELATED FUNCTIONS</p> <ul style="list-style-type: none"> • Do not convert safety-related code with EcoStruxure Control Engineering - Converter. • Re-design any and all converted code in compliance with all applicable safety-related regulations, standards, and certification requirements if, after the conversion, you decide to use any part of such converted code for safety-related purposes. <p>Failure to follow these instructions can result in death, serious injury, or equipment damage.</p>

The conversion report generated by EcoStruxure Control Engineering - Converter can be used as a starting point for the post-conversion activities to be performed. It contains various types of messages:

- Feature detection from source controller
- Unsupported feature on the target controller for each unsupported system block
- One message for each instance/usage of an unsupported system block

Hardware-Related Logic

The following section provides information on some of the steps to perform on the hardware-related logic of the converted code. Only you, the user of EcoStruxure Control Engineering - Converter can determine the entirety of measures to be taken because they depend on your target controller application which EcoStruxure Control Engineering - Converter cannot be aware of.

- Configuration of racks/modules:
 - Select the modules (depending on the controller application, you may also be able to use tools such as EcoStruxure Migration Expert).
 - Define the appropriate mapping of status bits.
- Communication infrastructure (such as fieldbus, SCADA, interPLCs), control, high-speed counters, motion (typically, this is skipped by the conversion):
 - Assign variables to the right memory location, if required
 - Configure the hardware
 - Replace the empty system blocks that were generated for the target controller with the appropriate code
- Information specific to the controller (system bits/words) related to hardware
- Task mapping on the target controller

Manual Conversion

EcoStruxure Control Engineering - Converter may not have converted certain system blocks from the source controller application to the target controller application, for example, because the code has an unresolvable complexity or is insufficiently documented. Instances and usage of such blocks are documented by messages in the details of the conversion report, page 36.

In such cases, EcoStruxure Control Engineering - Converter may also have included an invalid instruction in the generated code. Such an invalid instruction is intended to be detected as an error by the target software development environment to keep the corresponding code from being used without further processing.

Manually adapt the code blocks to the target controller.

Manufacturer-Specific File Export Procedures

EcoStruxure Control Engineering tools use the source code files of controller applications as input files. These files are exported from the corresponding software development environments. The following sections provide information on generating these export files in various software development environments.

Allen Bradley PLC5 (.PC5, .SY6 Export Files)

Export the Allen Bradley PLC5 controller application to a PC5 and a SYS6 export file in order to be processed with EcoStruxure Control Engineering tools.

Step	Action
1	Open the project in RSLogix500.
2	From the menu, select File > Save As > Type .
3	<p>Select Library Files (*.PC5).</p> <p>Result: RSLogix500 generates the following files:</p> <ul style="list-style-type: none"> • PC5 file • SY5 file • SY6 file • FIX file • FIX2 file

Only the PC5 and SY6 files are required for conversion.

The PC5 file contains the controller application:

- Hardware configuration
- Code
- Code comments
- Last values of variables

The SY6 files contains:

- Names of variables and comments

Allen Bradley SLC 500 (.SLC and .SY6 Export Files)

Export the Allen Bradley SLC500 controller application to a SCL and a SYS6 export file in order to be processed with EcoStruxure Control Engineering tools.

Step	Action
1	Open the project in RSLogix500.
2	From the menu, select File > Save As > Type .
3	Select Library Files (*.SLC) . Result: RSLogix500 generates the following files: <ul style="list-style-type: none">• SCL file• SY5 file• SY6 file• FIX file• FIX2 file

Only the SCL and SY6 files are required for conversion.

The SCL file contains the controller application:

- Hardware configuration
- Code
- Code comments
- Last values of variables

The SY6 files contains:

- Names of variables and comments

April SMC80, SMC600 (Native Application Files)

Controller applications for April SMC80 and April SMC600 are developed with VPeSOFT and EDIDOS.

The EcoStruxure Control Engineering tools that support April SMC use the native controller application files under MS-DOS. The name of the controller application corresponds to the name of the directory. This directory contains the required files. Depending on the SDT, the exact file names may be different.

VPeSOFT files:

- BOOL.DAT: Sequential code section
- CALC.DAT: Calcul code section
- MNEMO.DAT: Variables mnemonics and comments
- MNEMO.CLE : MNEMO.DAT index file
- PIPC.DAT: Sequential section mnemonics and comments
- PIPC.IDX: PIPC.DAT index file

Note: VPeSOFT did not support comments in the Calcul section.

EDIDOS files

- BOOL.SAV: Sequential code section
- CALC.SAV : Calcul code section
- MNEMO.SAV : Variables mnemonics and comments
- COMCAL.SAV: Mnemonics and calcul comments
- PIPC.SAV: Sequential section mnemonics and comments

April Orphee 1000 Series (FTA Export File)

Controller applications for the April Orphée 1000 controller series are developed with April Orphée. The native Orphée application files are contained in the directory C:\ORPHEE\SERVROOT\ of the hard drive. Each subdirectory contains a different controller application. EcoStruxure Control Engineering supports the exported format.

Use the tool ORPHEE-EDI2200 to export the controller application to an FTA text file. The tool is available on the ORPHEE installation disk. Download the corresponding user guide ([EDI2200](#), [Manuel de référence](#)) or contact your Schneider Electric representative for details.


GE Fanuc Intelligent Platforms Proficy Machine Edition V9.5 (.SWXCF File Export)

Export the Proficy Machine Edition controller application to a ZIP export file in order to be processed with EcoStruxure Control Engineering - Converter.

Step	Action
1	From the menu, select File > Save And Back Up
2	In the Save And Back Up dialog box, select the file type: Zip Files (*.zip) .
3	If required, modify the storage location.
4	Provide a name for the ZIP file.
5	Click Save .
6	After file has been stored, navigate to the storage location.
7	Extract the ZIP file to save the SWXCF file.

Mitsubishi GX Works3 (PLCopen .XML File Export)

Export the Mitsubishi GX Works3 controller application to an XML export file (PLCopen) in order to be processed with EcoStruxure Control Engineering tools.

Step	Action
1	<p>From the menu, select Project > Save Other Format File > XML Format...</p>  <p>The screenshot shows the 'Project' menu open in the software. The 'Save Other Format File' option is highlighted in yellow. A sub-menu is visible, showing 'XML Format...' as the selected option, also highlighted in yellow. Other menu items include New..., Open..., Close, Save, Save As..., Delete..., Project Verify..., Project Revision, Change Module Type/Operation Mode..., Data Operation, Intelligent Function Module, Open Other Format File, Library Operation, Security, Printer Setup..., Page Setup..., Print Preview..., Print..., Recent Projects(K), Start GX Works2, and Exit(Q).</p>
2	Provide a file name and a folder name as prompted.
3	Click Save .

Rockwell Automation® RSLogix 5000® or Studio 5000 (.L5K File Export)

Export the Rockwell Automation® RSLogix 5000® controller application to a L5K export file in order to be processed with EcoStruxure Control Engineering tools.

Step	Action
1	From the menu, select File > Save as....
2	In the Save as... dialog box, provide a name for the L5K file.
3	If required, modify the storage location.
4	Select the file type: RSLogix 5000 Import/Export File (*.L5K) .
5	Click Save .

Siemens SIMATIC STEP 5 (.S5D, Z0.INI Native Files)

EcoStruxure Control Engineering - Converter can process controller applications developed with Siemens STEP 5 for SIMATIC controllers. The following files are used as input for EcoStruxure Control Engineering - Converter:

1. S5D: Contains the logic and memory information. This file is required. More than one S5D file can be provided to EcoStruxure Control Engineering - Converter.
2. Z0.INI : Contains mnemonics used in the controller application. This file is optional. If the file is not provided, there are no mnemonics in the analyzed controller application.

NOTE: Verify that the version of the files S5D and Z0.INI .

Siemens SIMATIC STEP 7 (.ASC, .AWL, .GR7 and .SCL File Export)


Overview

The following steps are required to process a Siemens SIMATIC STEP 7 controller application with EcoStruxure Control Engineering tools:




- Set your SIMATIC STEP 7 workshop to German abbreviations (mnemonics).
- Create and export the symbols of the controller application to an **.ASC** file.
- Create and export the contact code (CONT) to an **.AWL** file.
- Create and export the graph blocks (GRAPH) to **.GR7** files.
- Compile the CFC code (if any) to create the corresponding **SCL** sources.
- Export structural codes (SCL) to **.SCL** files.

Setting German Mnemonics

Before creating the export files, set your SIMATIC STEP 7 workshop to German abbreviations (mnemonics):



Step	Action
1	From the menu, select Options > Customize...
2	Display the Language tab. 
3	Select German mnemonics.
4	Click OK .


Creating an ASC File

Step	Action												
1	<p>Right-click the symbols table in your program folder and select Open object.</p>  <table border="1" data-bbox="901 302 1437 757"> <thead> <tr> <th>Object name</th> <th>Symbolic name</th> <th>Type</th> </tr> </thead> <tbody> <tr> <td>Sources</td> <td>---</td> <td>Source Folder</td> </tr> <tr> <td>Blocs</td> <td>---</td> <td>Block Folder</td> </tr> <tr> <td>Mnémoniques</td> <td>---</td> <td>Symbol table</td> </tr> </tbody> </table>	Object name	Symbolic name	Type	Sources	---	Source Folder	Blocs	---	Block Folder	Mnémoniques	---	Symbol table
Object name	Symbolic name	Type											
Sources	---	Source Folder											
Blocs	---	Block Folder											
Mnémoniques	---	Symbol table											
2	<p>From the menu of the symbols editor, select Symbol Table > Export...</p> 												
3	<p>Select ASCII Format (*.ASC).</p> 												
4	Provide a name and select a directory for the .ASC export file.												
5	Click Save .												

Creating an AWL File

To create an **.AWL** file, first generate the LIST source for the code blocks developed in the languages CONT, LIST and LOG.


Step	Action
1	<p>Right-click a CONT, LIST or LOG source and select Open Object to open the CONT/LIST/LOG code editor.</p> 
2	<p>From the menu, select File > Close to close all open objects.</p>
3	<p>From the menu, select File > Generate source... to generate the program source.</p>
4	<p>Provide an object name and click OK.</p> 


Step	Action
5	<p>Click All to select all program blocks and select the options Sort according to program structure and Symbolic addresses.</p> 
6	Click OK to confirm.

If your controller application contains safety-related blocks, export those blocks in a separate **AWL** file. Refer to *Safety-Related Applications*, page 52 for details.

Creating GR7 Files

The **.GR7** sources have to be created for each GRAPH blocks separately. Repeat the following procedure for each GRAPH block to be exported.

Step	Action
1	<p>Right-click a GRAPH object and select Open Object.</p> 
2	From the menu, select File > Generate Source File .

Step	Action
3	<p>Provide a name for the GRAPH object.</p> 
4	Click OK to confirm.
5	Repeat the procedure for each GRAPH object to be exported.




Creating a CFG File

The CFG file is required for analyzing the communication and the hardware configuration of the station.

Step	Action
1	Double-click your controller links in the main window to open NetPro.
2	In the NetPro window, double-click the controller of the station to be exported open the HW Config utility.
3	From the Station menu, select Export... to export your station configuration (leave the default settings in the dialog box).

Creating a SCL File for CFC Codes

If the controller application contains CFC code, compile the code to generate the corresponding SCL source file which is the file to be processed with EcoStruxure Control Engineering tools.


Step	Action												
1	<p>Open the CFC code editor by clicking its icon in the toolbar of the main window.</p> 												
2	<p>Compile the code with the options Entire program and Generate SCL sources and click OK.</p> 												
3	<p>The generated SCL source file can then be exported like other source files (refer to Exporting Files, page 55).</p>  <table border="1" data-bbox="614 1164 1189 1276"> <thead> <tr> <th>Object name</th> <th>Symbolic name</th> <th>Type</th> </tr> </thead> <tbody> <tr> <td>DB11_Alarm_DB</td> <td>...</td> <td>STL Sourc</td> </tr> <tr> <td>MP34_Complete</td> <td>...</td> <td>STL Sourc</td> </tr> <tr> <td>@SCLFileFromCFC_SEC_1</td> <td>...</td> <td>SCL Sourc</td> </tr> </tbody> </table>	Object name	Symbolic name	Type	DB11_Alarm_DB	...	STL Sourc	MP34_Complete	...	STL Sourc	@SCLFileFromCFC_SEC_1	...	SCL Sourc
Object name	Symbolic name	Type											
DB11_Alarm_DB	...	STL Sourc											
MP34_Complete	...	STL Sourc											
@SCLFileFromCFC_SEC_1	...	SCL Sourc											


Safety-Related Applications

A safety-related controller application contains two code parts:

- The non-safety-related code part
- The safety-related code part


Procedure for exporting controller applications that contain safety-related code:


Step	Action
1	Export the .ASC file that contains the database for the safety-related code and for the non-safety-related code (refer to <i>Creating an ASC File</i> , page 48).
2	Generate the sources for the non-safety-related code parts (refer to <i>Creating an AWL File</i> , page 48 and <i>Creating a GR7 File</i> , page 50).
3	<p>Click All to select all program blocks and select the options Sort according to program structure and Symbolic addresses.</p>  <p>The screenshot shows the 'Generate source CONT_LIST_LOG' dialog box. The path is 'Ecluse1\SIMATIC 300(1)\CPU 314C-2 DP\...'. The 'Blocks Selected' list contains: FC6 Gestion_default, FC7 Autorisation, FC8 Demandes, FC9 Action_cmd, DB1 Cmd_yanne_remplissage, DB2 Cmd_yanne_vidange, DB3 Cmd_porte_ament, DB4 Cmd_porte_aval, and DB1 cycle. The 'All >' button is highlighted. The 'Sort according to program structure' checkbox is checked and highlighted. The 'Symbolic' radio button is selected and highlighted. The 'OK' button is highlighted.</p>
4	Click OK to confirm.
5	Follow the procedure for <i>Creating an AWL File</i> , page 48 until the dialog box Generate source Safety is displayed.

Step	Action
6	<p>Select the option User-created F-FBs, F-FCs and F-DBs and click OK to confirm.</p> 
7	<p>Create a .dif file (refer to Creating a dif File, page 54). The .dif file is used to determine whether code is safety-related.</p>

Creating a dif File


A **.dif** file is created in the SIMATIC Manager of SIMATIC STEP 7 in the following way:

Step	Action
1	<p>From the menu, select Options > Reference Data > Display.</p>
2	<p>In the Display S7 reference data dialog box, select the option regenerated? and click Yes.</p> 

Step	Action
3	In the Customize dialog box, select the option Program Structure and click OK to display the program structure. 
4	From the menu, select View > Export to open the Save dialog box.
5	Provide a name for the .dif and click Save .

Exporting Files

After you have created the files, export them from SIMATIC STEP 7:

Step	Action
1	Select the LIST, GRAPH (or .AWL and .GR7 files) and SCL sources that you have generated.
2	Right-click the sources and select Export source.... 
3	Select a file name and a storage location and click Save .

Telemecanique TSX 7 Series (.BIN, .CDB Native Files)

To work with controller applications of the Telemecanique TSX 7 series developed with XTEL versions 4 and 5, three types of files are required:

1. BIN

This file is mandatory. It contains the controller application with the hardware configuration, the database, the code, comments and further items.

The file is available in the subdirectory ...XPROPJ\PL7_3\APPLI ("appli" being the name of the controller application directory). The file name is PL7_3.BIN or appli.BIN ("appli" being the name of the controller application directory).

If the BIN file has the same name as the TSX task, rename the BIN file before uploading it.

2. CDB

This file is optional. It contains the names of the variables, comments and topological addresses of variables in the controller application.

The file is available in the subdirectory ...XPROPJ\SDBASE\APP\ . The file name is PL7_3.CBD or appli.CBD ("appli" being the name of the controller application directory).

If the file is not provided, the generated code does not have mnemonics and comments.

3. CNIORACK.BIN

This file is optional. It contains a more detailed hardware configuration than that contained in the file BIN file. The file is only available in versions higher than V4 of XTEL.




The file is available in the subdirectory ...V\CONF\IORACK\ CONFIO.

If the file is not provided, the generated code does not have mnemonics and comments.

Manufacturer-Specific File Import Procedures




Unity Pro (XEF Import Format)



EcoStruxure Control Engineering - Converter provides an export of a Unity Pro project in XEF format that can be imported into Unity Pro.

Step	Action
1	<p>From the menu, select File > Open.</p>  <p>The screenshot shows the 'File' menu open with 'Open...' highlighted. The menu items are: File, View, Tools, PLC, Help, New... (Ctrl+N), Open... (Ctrl+O), Exit, and Recent Projects.</p>
2	<p>Select Application Exchange File (*.XEF).</p>  <p>The screenshot shows a file type selection dialog with 'Application Exchange Files (*.XEF)' selected. Other options include: Files (*.STU), Full Application Exchange Files (*.ZEF), PL7 Projects (*.FEF), PL7 DFB Files (*.DFB), Concept Projects (*.ASC), Modsoft Projects (*.CFG), ProWORX32 Databases (*.PWX), ProWORX Next (*.DCF), Archived Application Files (*.STA), and PL7 DAT Files (*.DAT).</p>
3	<p>Select the XEF file in the appropriate folder and click Open.</p> <p>Result: The import process starts and progress information is displayed. When the import is finished, the project is available in Unity Pro.</p>  <p>The screenshot shows a progress bar for 'Import Project' at 42% completion, with the text 'Processing command'.</p>

3S CODESYS V3 (EXPORT Import Format)

EcoStruxure Control Engineering - Converter provides an export of a CODESYS project that can be imported into CODESYS.

Step	Action
1	<p>In CODESYS, create a project by selecting Start page > Basic Operations > New project....</p> 
2	<p>Select Empty project and provide a name and storage location for the new project. Result: CODESYS opens the new project.</p> 
3	<p>Select the root of the new project under Devices.</p>
4	<p>Select Project > Import....</p> 

Step	Action
5	<p>Select the EXPORT file in the appropriate folder and click Open.</p> <p>Result: CODESYS reads the file and provides a tree of the insertable items. By default, all items are selected.</p> 
6	<p>Select the required items and click OK to import the items.</p>
7	<p>CODESYS may notify you that a device contained in the project needs to be removed. This can occur because the code export contains another device. To continue, confirm with OK to overwrite the existing device.</p> <p>CODESYS</p> <p>One or more objects to import are already existing. Please select those objects which you want to be overwritten.</p>  <p>Result: CODESYS notifies you when the import is complete.</p>

By default, the EXPORT file generated by EcoStruxure Control Engineering - Converter is compatible with version 3.5 SP10, patch 10 of CODESYS. If you want to use the files with a different CODESYS version, import it into CODESYS version 3.5 SP10, patch 10 to create a project, and then open the project with the CODESYS version that you want to use. Contact your Schneider Electric representative for additional information.

Siemens TIA Portal SIMATIC STEP 7 (.ZIP Import Format)

EcoStruxure Control Engineering - Converter provides the generated code for Siemens TIA Portal SIMATIC STEP 7 in a ZIP file to be imported into a Siemens TIA Portal SIMATIC STEP 7 project.

The file can be imported automatically with the EcoStruxure Control Engineering Import/Export tool. Select **SUPPORT > DOWNLOADS**.

Refer to the user guide of the EcoStruxure Control Engineering Import/Export tool for details.

Schneider Electric
35 rue Joseph Monier
92500 Rueil Malmaison
France

+ 33 (0) 1 41 29 70 00

www.se.com

As standards, specifications, and design change from time to time,
please ask for confirmation of the information given in this publication.

© 2023 Schneider Electric. All rights reserved.

EIO0000004425.06