

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Rotary switch-disconnector

Name and address of the applicant

Sontheimer Elektroschaltgeräte GmbH
Wendelsteiner Strasse 5
D-91126 SCHWABACH
Germany

Name and address of the manufacturer

Sontheimer Elektroschaltgeräte GmbH
Wendelsteiner Strasse 5
D-91126 SCHWABACH
Germany

Name and address of the factory

Note: When more than one factory, please report on page 2

☐ Additional information on page 2
Sontheimer Elektroschaltgeräte GmbH
Wendelsteiner Strasse 5
D-91126 SCHWABACH
Germany

Ratings and principal characteristics

Ith max. 63 A, Ui 690 Vac, Uimp 6 kV, Icc 6 kA at 690 V and 10 kA at 440 V, 3P
AC-21A and AC-22A
690 Vac max. 63 A
AC-23A
230 Vac max. 11 kW / 38 A
400 Vac max. 22 kW / 41 A
690 Vac max. 18,5 kW / 21 A
AC-3
230 Vac max. 11 kW / 38 A
400 Vac max. 18,5 kW / 35 A
690 Vac max. 15 kW / 17 A
Refer to attachment for ratings per model/type

Trademark (if any)

SONTHEIMER

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

LO63, LO40, LO32, LO25, LO16

Additional information (if necessary may also be reported on page 2)

☐ Additional information on page 2
Testing was performed in 2017 and 2021. This CB replaces CB NL-69193 dated 2020-11-18.

A sample of the product was tested and found to be in conformity with

IEC 60947-3:2008, IEC 60947-3:2008/AMD1:2012, IEC 60947-3:2008/AMD2:2015

As shown in the Test Report Ref. No. which forms part of this Certificate

2256526.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands