



中国国家强制性产品认证证书

证书编号：2024010303660008

认证委托人名称及地址

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

生产者名称及地址

ABB Stotz-Kontakt GmbH
Hauptstrasse 14-16, D-78132 Hornberg, Germany

生产企业名称及地址

Relpol S. A.
ul. 11 Listopada 37, 68-200 Zary, Poland

产品名称和系列、型号、规格

继电器

CR-M; Uimp:4kV(2P,3P),2.5kV(4P); Ui:300V; Ith:12A(2P),10A(3P),6A(4P);
Ue/Ie:AC-15:AC240V/1.5A(2P,3P),AC240V/1.0A(4P); IP40(操作面); 型号解释详见
附页

产品标准和技术要求

GB/T 14048.5-2017

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》
(CNCA-C03-02:2024)的要求，特发此证。

发证日期：2024年07月18日 有效期至：2029年07月17日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验，
也可在认监委网站（www.cnca.gov.cn）查询。



签发：

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





中国国家强制性产品认证证书

证书编号: 2024010303660008

证书附页: 第 1 页 共 1 页

型号的解释:

CR-M 024DC 3 L

① ② ③ ④

① basic (基本型号)

② coil voltage (线圈电压)

012DC,024DC,048DC,060DC,110DC,125DC,220DC

024AC,048AC,110AC,120AC,230AC;

③ number of poles(极数): 2, 3, 4;

④ accessories: (附件)

NULL - general relay without any accessories 一般继电器, 不带任何附件

L - with LED 带 LED

LG: with LED and gold plated contacts 带 LED 和镀金触点

LD: with LED and freewheeling diode 带 LED 和续流二极管保护

本页为证书附页, 应与证书主页同时使用。



中国质量认证中心

CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2024010303660008

NAME AND ADDRESS OF THE APPLICANT

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

NAME AND ADDRESS OF THE MANUFACTURER

ABB Stotz-Kontakt GmbH
Hauptstrasse 14-16, D-78132 Hornberg, Germany

NAME AND LOCATION OF THE FACTORY

Relpol S.A.
ul.11 Listopada 37, 68-200 Zary, Poland

PRODUCT NAME, MODEL AND SPECIFICATION

Relays
CR-M; Uimp:4kV(2P,3P),2.5kV(4P); Ui:300V; Ith:12A(2P),10A(3P),6A(4P);
Ue/Ie:AC-15:AC240V/1.5A(2P,3P),AC240V/1.0A(4P); IP40(above operating surface)

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.5-2017

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Jul.18,2024

Valid until: Jul.17,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO. : 2024010303660008

Appendix: Page 1 of 1

型号的解释:

CR-M 024DC 3 L
① ② ③ ④

① basic (基本型号)

② coil voltage (线圈电压)

012DC,024DC,048DC,060DC,110DC,125DC,220DC

024AC,048AC,110AC,120AC,230AC;

③ number of poles(极数): 2, 3, 4;

④ accessories: (附件)

NULL - general relay without any accessories 一般继电器, 不带任何附件

L - with LED 带 LED

LG: with LED and gold plated contacts 带 LED 和镀金触点

LD: with LED and freewheeling diode 带 LED 和续流二极管保护

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心

CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.