AFITI LICOF Centre for Fire Testing and Research

Association for the Promotion of Research and Fire Safety Technology

Test Certificate

No: C9874/20-12

Applicant **ABB OY**
Muottitie 2A
65630 Vaasa (Finland)

Building element **Switch disconnector**

References:

OKA40S2B0F400	OKA63S2B0F400
OKA40S3B0F400	OKA63S3B0F400
OKA40S3B1F400	OKA63S3B1F400
OKA40S3B0F400N	OKA63S3B0F400N
OKA40S4B0F400	OKA63S4B0F400
OKA40S4B1F400	OKA63S4B1F400
OKA40S6B0F400	OKA63S6B0F400
OKA40S6B1F400	

Test/s Test protocol based on **EN 12101-3:2015** *"Smoke and heat control systems. Part 3: Specifications for powered smoke and heat exhaust ventilators"*

Test date 17th-Mar-20

Certificate for the reports Test report no. 9874/20-2 (issued by AFITI-LICOF on 9th-Jun-2020)

Fire resistance classification F_{400} 120

Classification taking as reference what is stated in the standard **EN 12101-3:2015**

Arganda del Rey, 28th of September of 2022

Digitally Signed Document

Signed: Carlos Burón Alonso
Technical director
Fire resistance laboratory

The results of this certificate refer solely and exclusively to the specimens tested, and not to the product in general.

The specified reports include important aspects of the test performance and development which have made it possible to obtain the aforementioned fire resistance classification. This certificate should be used together with the referenced reports.

Cancellation or modification of the aforementioned reports implies cancellation or modification of this certificate.

HEAD OFFICE & LABORATORIES Camino del Estrechillo, 8
E-28500 Arganda del Rey - Madrid (Spain)

CENTRAL OFFICE & LABORATORIES C/ Río Estenilla, s/n - P.I. Sta. Mª de Benquerencia
E-45007 Toledo (Spain)

+34 902 112 942
+34 901 706 587
licof@afiti.com
www.afiti.com