

GLV032-39	GOODWE	ESA Series	
C10/26 - DECLARATION OF CONFORMITY for power-generating units GLV ed2.1.4 (10/2025)			
for compliance with annex D "Technical basic requirements regarding the power-generation units" of the Synergrid prescription C10/11 ed2.4 (15/10/2025).			

The undersigned,	Manufacturer:	GoodWe Technologies Co., Ltd.	Represented by:	Yu Xiao
	Address:	No. 90 Zijin Rd., SND Suzhou	Country:	CHINA
	Country:	CHINA	email:	yu.xiao@goodwe.com
			Telephone:	0086 0150 5159 0076

Hereby declares that each production unit completed in the list in tab 2 '*list of power-generating units*' of this homologation application complies with the following conditions:

1. The power-generating unit complies with the relevant requirements set out in annex D "Technical basic requirements regarding the power-generation units" of **the Synergrid prescription C10/11 ed2.4 (15/10/2025)**.
2. In order to substantiate this, **a technical file** has been submitted **for each product series** of the '*C10/26 list of power-generating units*' of this homologation application. Each technical file shall be drawn up on the basis of a checklist Annex D, duly and correctly completed by the manufacturer, accompanied by all the required proof of conformity.
 - 2.1 For technical requirements for which the required proof of conformity (column J in checklist annex D) is **a declaration of honour** by the manufacturer, **no additional documents are needed**. By signing and dating this declaration of conformity, **the manufacturer declares** the correctness of the information (**compliant / non-compliant / not applicable**) provided by him or her in columns K, L and M of this checklist.
 - 2.2. For technical requirements for which the required proof of conformity (column J in checklist Annex D) is a test report or a certificate, the necessary test reports and/or certificates are available in the technical file:
 - Certificates have been issued by an EN 45011 (or ISO 17065:2012) certification body accredited for these materials.
 - Test reports have been established by an ISO 17025:2005 or ISO 17065:2012 laboratory accredited for these tests.

Manufacturer's signature: Digitally signed, see last page	Homologated by Synergrid on: 15/06/2026
	Synergrid signature: Digitally signed, see last page

POWER-GENERATING UNITS TO BE HOMOLOGATED FOR THE LIST C10/26 ACCORDING TO THE REQUIREMENTS OF ANNEX D OF THE TECHNICAL PRESCRIPTION C10/11 **ed2.4 (15/10/2025)**

2. C10/26 list with power-generating units in accordance with annex D of C10/11 ed2.4 (15/10/2025)

GLV032-39	GOODWE	ESA Series
-----------	--------	------------

checklist ed2.1.4 (10/2025)

1	2	3	4	5	6	7	8	9	10	11				12				13				14	15			
SYNERGRID reference number (GLVxxx-yy-zzzz)	BRAND NAME	Name of the product SERIES	REFERENCE of the model / type of the unit	FIRMWARE VERSION	ONLY for units (suitable for) energy storage: Name and reference of the power control system		POWER		1-phase or 3-phase	ADDITIONAL CHARACTERISTICS				LIMITATIONS				APPLICATION				Additional information	Synergrid homologation approval date			
					Only for “Small” storage PGU’s : Power control system type EnFluRI (name), and/or use of P1 port of smart meter of DSO (indication “P1”).	All other (bigger) storage PGU’s : Other power control system (name)	P _{act,r} rated (active) power (W)	S _{max} maximum apparent power (VA)		D.3	(…)	D.4.1 additional operating frequency range (51.5 Hz - 52.5 Hz)	D.6.2 power response to underfrequency	D.7.2 active power reduction (PU)	0 compliant power control system provided (e.g. EnFluRI)	D.7.1 only homologated for connection to HV-network generating installations*	D.9.1 only homologated for use in module < 800W	(…) only homologated as a backup power system according to §2.1.1	Solar energy	Wind energy	CHP (combined heat & power)			Energy storage	Backup power system	Other
GLV032-39-0001	GOODWE	ESA Series	GW5K-BTA-G20	010101 or higher	GMK330, GM330, In-built Power Sensor		5,000	5,000	3-phase	X			X	X	X					X	X		15/06/2026			
GLV032-39-0002	GOODWE	ESA Series	GW6K-BTA-G20	010101 or higher	GMK330, GM330, In-built Power Sensor		6,000	6,000	3-phase	X			X	X	X					X	X		15/06/2026			
GLV032-39-0003	GOODWE	ESA Series	GW8K-BTA-G20	010101 or higher	GMK330, GM330, In-built Power Sensor		8,000	8,000	3-phase	X			X	X	X					X	X		15/06/2026			
GLV032-39-0004	GOODWE	ESA Series	GW9.999K-BTA-G20	010101 or higher	GMK330, GM330, In-built Power Sensor		9,999	9,999	3-phase	X			X	X	X					X	X		15/06/2026			
GLV032-39-0005	GOODWE	ESA Series	GW10K-BTA-G20	010101 or higher	GMK330, GM330, In-built Power Sensor		10,000	10,000	3-phase	X			X	X	X					X	X		15/06/2026			
GLV032-39-0006	GOODWE	ESA Series	GW12K-BTA-G20	010101 or higher	GMK330, GM330, In-built Power Sensor		12,000	12,000	3-phase	X			X	X	X					X	X		15/06/2026			
GLV032-39-0007	GOODWE	ESA Series	GW15K-BTA-G20	010101 or higher	GMK330, GM330, In-built Power Sensor		15,000	15,000	3-phase	X			X	X	X					X	X		15/06/2026			
GLV032-39-0008	GOODWE	ESA Series	GW20K-BTA-G20	010101 or higher	GMK330, GM330, In-built Power Sensor		20,000	20,000	3-phase	X			X	X	X					X	X		15/06/2026			
GLV032-39-0009	GOODWE	ESA Series	GW25K-BTA-G20	010101 or higher	GMK330, GM330, In-built Power Sensor		25,000	25,000	3-phase	X			X	X	X					X	X		15/06/2026			
GLV032-39-0010	GOODWE	ESA Series	GW29.999K-BTA-G20	010101 or higher	GMK330, GM330, In-built Power Sensor		29,999	29,999	3-phase	X			X	X	X					X	X		15/06/2026			
GLV032-39-0011	GOODWE	ESA Series	GW30K-BTA-G20	010101 or higher	GMK330, GM330, In-built Power Sensor		30,000	30,000	3-phase	X			X	X	X					X	X		15/06/2026			
GLV032-39-0012	GOODWE	ESA Series	GW5K-ETA-G20	010101 or higher	GMK330, GM330, In-built Power Sensor		5,000	5,000	3-phase	X			X	X	X		X			X	X		15/06/2026			
GLV032-39-0013	GOODWE	ESA Series	GW6K-ETA-G20	010101 or higher	GMK330, GM330, In-built Power Sensor		6,000	6,000	3-phase	X			X	X	X		X			X	X		15/06/2026			

GLV032-39-0014	GOODWE	ESA Series	GW8K-ETA-G20	010101 or higher	GMK330, GM330, In-built Power Sensor		8,000	8,000	3-phase	X				X	X	X					X			X	X			15/06/2026
GLV032-39-0015	GOODWE	ESA Series	GW9.999K-ETA-G20	010101 or higher	GMK330, GM330, In-built Power Sensor		9,999	9,999	3-phase	X				X	X	X					X			X	X			15/06/2026
GLV032-39-0016	GOODWE	ESA Series	GW10K-ETA-G20	010101 or higher	GMK330, GM330, In-built Power Sensor		10,000	10,000	3-phase	X				X	X	X					X			X	X			15/06/2026
GLV032-39-0017	GOODWE	ESA Series	GW12K-ETA-G20	010101 or higher	GMK330, GM330, In-built Power Sensor		12,000	12,000	3-phase	X				X	X	X					X			X	X			15/06/2026
GLV032-39-0018	GOODWE	ESA Series	GW15K-ETA-G20	010101 or higher	GMK330, GM330, In-built Power Sensor		15,000	15,000	3-phase	X				X	X	X					X			X	X			15/06/2026
GLV032-39-0019	GOODWE	ESA Series	GW20K-ETA-G20	010101 or higher	GMK330, GM330, In-built Power Sensor		20,000	20,000	3-phase	X				X	X	X					X			X	X			15/06/2026
GLV032-39-0020	GOODWE	ESA Series	GW25K-ETA-G20	010101 or higher	GMK330, GM330, In-built Power Sensor		25,000	25,000	3-phase	X				X	X	X					X			X	X			15/06/2026
GLV032-39-0021	GOODWE	ESA Series	GW29.999K-ETA-G20	010101 or higher	GMK330, GM330, In-built Power Sensor		29,999	29,999	3-phase	X				X	X	X					X			X	X			15/06/2026
GLV032-39-0022	GOODWE	ESA Series	GW30K-ETA-G20	010101 or higher	GMK330, GM330, In-built Power Sensor		30,000	30,000	3-phase	X				X	X	X					X			X	X			15/06/2026

EXPLANATIONS FOR THE COMPLETION OF THE TABLE

Column	Title	Remarks
1	SYNERGRID reference number (GLVxxx-yy-zzzz)	In the case of a positive homologation, each C10/26-homologated power-generating unit is given a unique Synergrid reference number: xxx = unique reference or the manufacturer yy = serial number of manufacturer xxx's record xxx zzzz = unique unit reference for the manufacturer xxx Note : "GLV" is the internal Synergrid-abbreviation for Declaration of Conformity, based on the Dutch word "Gelijkvormigheidsverklaring".
2	Brand name	Brand name under which the unit is marketed on the Belgian market.
3	Name of the product series	Name of the product range. Note: For each separate product range (or each group of units with common characteristics) a separate checklist according to Appendix D is required (sheet 3) together with the corresponding conformity proof documents.
4	Reference of the model / type of the unit	Unique product name or reference. Units of the same product range must be unequivocally distinguished from each other through this name or reference.
5	Firmware version	Reference of the firmware version of the unit.
6	power control system type EnFluRi	This case is only applicable for units (suitable for) energy storage, provided with a power control system of type EnFluRi : Name and reference of the power control system of type EnFluRi, compliant to the requirements in C10/11 §4.1.7 and §7.11.2.1
7	other power control system	This case is only applicable for units (suitable for) energy storage, provided with a power control system of another type than EnFluRi : Name and reference of the power control system, compliant to the requirements in C10/11 §7.11.2.2
8	P _{ac,r} rated (active) power (W)	Active (electrical) power in W at the terminals of the unit, as stated on the technical sheet / data sheet / brochure and nameplate. (For photovoltaic inverters: see also definition in §3.2.5 of IEC 62894 2016-11)
9	S _{max} - maximum apparent power (VA)	Maximum apparent (electrical) power at the terminals of the unit, as stated on the certificate / the test report / the technical sheet / data sheet / brochure.
10	1-phase or 3-phase	Indicate whether the unit is single- or three-phase. This characteristic refers to the unit itself, not to the nature of the connection to the distribution network to which the unit can be connected.
11	Additional characteristics	In these columns optional additional characteristics of the units are indicated, following the information in checklist annex D and the corresponding technical file. Put an "X" at each relevant additional characteristic. Note: Only units < 1 MW that are "type B ready" may be applied in an installation ≥ 1 MW (installation "type B" according to the European Network Code RfG). A unit < 1 MW is only "type B ready" if it complies with <u>all</u> optional properties ticked in column I of the checklist Annex D.
12	Limitations	These columns specify limitations of the units to their application in certain types of installations, in accordance with the information in the checklist in annex D and the corresponding technical file. Put an "X" to each relevant limitation.
13	Application	Indicate the applications for which the unit is suitable. Include an "X" with each application for which the unit can be used.
14	Additional information	Additional information about the application of the unit(s): Plug&play, Suitable for V2G, Generator (gas), Generator (hydro), Generator (diesel), Generator (biomass), ...
15	Synergrid homologation approval date	Date on which the submitted homologation file was approved by Synergrid. - An approval will be granted as soon as Synergrid has a fully compliant homologation dossier. - A homologation only remains valid under the following conditions: - No changes that have an influence on the initial approval are made to (the production of) the units. - There is no new edition of prescription C10/11, or the homologation remains valid under the most recent edition of the prescription C10/11. - The validity date of the test reports in the technical file submitted for approval has not been exceeded. See also the general Synergrid procedure S1/01 for homologation of material, which is applicable. See also the general Synergrid procedure S1/01 for homologation of material, which is applicable.

PENNEO

The signatures in this document are legally binding. The document is signed using Penneo™ secure digital signature. The identity of the signers has been recorded, and are listed below.

"By my signature I confirm all dates and content in this document."

Yu Xiao

Signataire 1

Serial number: yu.xiao@goodwe.com

IP: 39.144.xxx.xxx

2026-06-16 01:04:18 UTC

Yu . Xiao

GAMARA Mohamed Amine

Signataire 2

Serial number: 60:95:5E:E9:42:80:68:34

IP: 94.104.xxx.xxx

2026-06-16 07:21:07 UTC



This document is digitally signed using [Penneo.com](https://penneo.com). The signed data are validated by the computed hash value of the original document. All cryptographic evidence is embedded within this PDF for future validation.

The document is sealed with a Qualified Electronic Seal. For more information about Penneo's Qualified Trust Services, visit <https://eutl.penneo.com>.

How to verify the integrity of this document

When you open the document in Adobe Reader, you should see that the document is certified by **Penneo A/S**. This proves that the contents of the document have not been modified since the time of signing. Evidence of the individual signers' digital signatures is attached to the document.

You can verify the cryptographic evidence using the Penneo validator, <https://penneo.com/validator>, or other signature validation tools.