

CERTIFICATE

Issued to:
Applicant:
Cooper Securite SAS
Parc Européen d'Entreprise RII Rue Beethoven -
BP 10184
63204 Riom, France

Licensee:
Cooper Securite SAS
Parc Européen d'Entreprise RII Rue Beethoven -
BP 10184
63204 Riom, France

Product : CGLine+ Web-Controller
Trade name(s) : EATON, EATON Crompton, EATON JSB, EATON LUMINOX or
EATON MENVIER
Type(s)/model(s) : Advanced CGLine+ Web-Controller - 40071777990,
CGLine+ Web-Controller - 40071361055,
CGLine+ Web-Controller - 40071361074,
CGLine+ Web-Controller - 40071361440,
CGLine+ Web-Controller - 40071361787,
CGLine+ Web-Controller - 40071777962,
CGLine+ Web-Controller Anschlussbox - 40071361430,
CGLine+ Web-Controller Anschlussbox - 40071361441 and
CGLine+ Web-Controller Anschlussbox - 40071361184

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard(s) EN IEC 62368-1:2020 and EN IEC 62368-1:2020/A11:2020
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 2193273


DEKRA hereby grants the right to use the ENEC certification mark.

The ENEC certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the ENEC certification agreement.

This certificate is issued on 3 November 2022 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-125499

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



MT Tonsi
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: CGLine+ Web-Controller
Trade name(s)	: EATON, EATON Crompton, EATON JSB, EATON LUMINOX or EATON MENVIER
Type(s)/model(s)	: Advanced CGLine+ Web-Controller - 40071777990, CGLine+ Web-Controller - 40071361055, CGLine+ Web-Controller - 40071361074, CGLine+ Web-Controller - 40071361440, CGLine+ Web-Controller - 40071361787, CGLine+ Web-Controller - 40071777962, CGLine+ Web-Controller Anschlussbox - 40071361430, CGLine+ Web-Controller Anschlussbox - 40071361441 and CGLine+ Web-Controller Anschlussbox - 40071361184
Rated voltage/nature of supply	: 220-240 Vac
Rated frequency	: 50/60 Hz
Rated current	: 280 mA
Rated input	: 34 W

Product data – type Advanced CGLine+ Web-Controller - 40071777990

Ambient temperature range	: ta: -10...+55 °C
Degree of protection	: IP20
Trade name	: Eaton

Product data – type CGLine+ Web-Controller - 40071361055

Ambient temperature range	: ta: -10...+55 °C
Degree of protection	: IP20
Trade name	: Eaton

Product data – type CGLine+ Web-Controller - 40071361074

Ambient temperature range	: ta: -10...+55 °C
Degree of protection	: IP20
Trade name	: Eaton JSB

Product data – type CGLine+ Web-Controller - 40071361440

Ambient temperature range	: ta: -10...+55 °C
Degree of protection	: IP20
Trade name	: Eaton Menvier

Product data – type CGLine+ Web-Controller - 40071361787

Ambient temperature range	: ta: -10...+55 °C
Degree of protection	: IP20
Trade name	: Eaton Crompton

Product data – type CGLine+ Web-Controller - 40071777962

Ambient temperature range	: ta: -10...+55 °C
Degree of protection	: IP20
Trade name	: Eacon Luminox

Product data – type CGLine+ Web-Controller Anschlussbox – 40071361184

Ambient temperature range : ta: 0...+35 °C
Degree of protection : IP65
Trade name : Eaton

Product data – type CGLine+ Web-Controller Anschlussbox - 40071361430

Ambient temperature range : ta: 0...+35 °C
Degree of protection : IP65
Trade name : Eaton JSB

Product data – type CGLine+ Web-Controller Anschlussbox - 40071361441

Ambient temperature range : ta: 0...+35 °C
Degree of protection : IP65
Trade name : Eaton Menvier

TESTS**Test requirements**

EN IEC 62368-1:2020
EN IEC 62368-1:2020/A11:2020

Test result

The test results are laid down in DEKRA test file 226964800.

Additional information

This product also complies to EN 62034:2012

This certificate replaces certificate No. 71-113457 which we hereby declare invalid.

The list of components is laid down in test report 2269648.50A.

Conclusion

The examination proved that all requirements were met.

Factory locations

EATON; CEAG Notlichtsysteme GmbH
Senator-Schwartz-Ring 26
59494 Soest, Germany

Tectron GmbH
Querstrasse 2
37339 Worbis, Germany

Cooper Securite SAS
Parc Européen d'Entreprise RII Rue Beethoven - BP 10184
63204 Riom, France