



Product Service

CERTIFICATE

No. Z2 076043 0101 Rev. 00

Holder of Certificate: Hengdian Group DMEGC Magnetics CO., LTD
Hengdian Industrial Zone
322118 Dongyang, Zhejiang
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product: Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
Smart Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062106807-00

Valid until: 2027-03-31

Date, 2022-04-01

(David Bo)



CERTIFICATE

No. Z2 076043 0101 Rev. 00

Model(s): DMxxxM6-72HBB-S, xxx = 415 to 455 in steps of 5
 DMxxxM6-72HSW-S, xxx = 415 to 455 in steps of 5
 DMxxxM6-60HBB-S, xxx = 345 to 380 in steps of 5
 DMxxxM6-60HSW-S, xxx = 345 to 380 in steps of 5
 xxx is standing for rated output power at STC

Parameters:

Construction:	PV module integrated with power optimizer, Framed, with Cable and Connectors.
Protection Class:	Class II
Maximum System Voltage:	1000 V DC
Fire Safety Class:	Class C according to UL790

Tested according to: IEC 61730-1:2016
 IEC 61730-2:2016
 IEC 62109-3:2020