

CERTIFICATE

Issued to:
Applicant:
Niko N.V.
Industriepark West 40
9100 Sint-Niklaas, Belgium

Licensee:
Niko N.V.
Industriepark West 40
9100 Sint-Niklaas, Belgium

Product : combination of rocker switches serie A, B, C, D, E, F and G
Trade name(s) : NIKO
Type(s)/model(s) : 170-726**/**-61505/- and 170-726**r/**-61505/-

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60669-1:2018
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 900367


DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 6 May 2020 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-113179

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



F.S. Strikwerda
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: combination of rocker switches serie A, B, C, D, E, F and G
Trade name(s)	: NIKO
Type(s)/model(s)	: 170-726**/**-61505/- and 170-726**r/**-61505/-
Rated current	: 10 AX
Rated voltage	: 250 V~
Pattern no.	: 6+6
Method of mounting	: flush-type, screw- or claw-fixing
Markings	: -tradenname, series-indication and electrical ratings on the base -tradenname and type reference for the cover on this part

Product data – type 170-726/**-61505/-**

Terminals : screw terminals

Product data – type 170-726r/**-61505/-**

Terminals : screwless terminals

TESTS**Test requirements**

EN 60669-1:2018

Test result

The test results are laid down in DEKRA test file 224284900.

Additional information

This installation switch is intended to be used with the covers of the Serie A, B, C, D, E, F or G.

These covers have been constructed as follows:

Serie A

Duoshell (bottom shell: PC/ASA / top shell: zamac, PC/ASA)

Serie B

Monoshell: (PC/ASA)

Serie C

Duoshell (bottom shell: PC/ASA / top shell: inox, metal, forbo, plexi, aluminium, brass, PU+PA, PU)

Serie D

Duoshell (bottom shell: PC/ASA / top shell: bamboo, aluminium)

Serie E

Monoshell (PC/ASA)

Serie F

Housings for surface mounting ((PC-ASA)

Serie G

(PF, optional top shell: PU, resin+sand)

Remark:

This certificate is also based on the SGS CEBEC CB Test Certificate BE-8233

This certificate replaces certificate 2131478.03 which we herewith declare invalid and

This certificate replaces certificate No. 2181988.04 which we herewith declare invalid.

Conclusion

The examination proved that all requirements were met.

Factory location

Niko N.V.

Industriepark West 40

9100 Sint-Niklaas, Belgium