

# CERTIFICATE OF CONFORMITY

<b><u>Product:</u></b>	contactors, auxiliary-
<b><u>Tested by request of</u></b>	ABB Stotz-Kontakt GmbH Eppelheimer Strasse 82 69123 HEIDELBERG Germany
<b><u>Manufactured at (name and place)</u></b>	ABB Stotz-Kontakt GmbH Eppelheimer Strasse 82 69123 HEIDELBERG Germany
	ABB Bulgaria EOOD - Rakovski Branch / BULGARIA, 4142 Village of Stryama, Region of Plovdiv, Municipality of Rakovski, Rakovski Industrial Zone, 14 Industrial Road 1, nr.14-18
	AVIST EOOD / Ilarion Makariopolski Str. 5 2850 Petrich, Bulgaria
<b><u>Trade mark (if any):</u></b>	ABB
<b><u>Model/Type Ref:</u></b>	ESB16..N, ESB20..N, EN20..N, ESB25..N and EN25..N with ESB-PLK24, ESB40..N, EN40..N and ESB63..N with ESB-PLK40/63, EH04-xxN
<b><u>Ratings and principal characteristics:</u></b>	/
<b><u>Additional information (if any) :</u></b>	for HVAC applications employing A2L refrigerants with a maximum burning velocity of 6,7 cm/s (corresponding to R-32)

A sample of the product has been tested and found to be in conformity with :

Annex JJ of IEC 60335-2-40:2018

as shown in the test report(s) 63201104

This Certificate of Conformity is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standard. It does not imply an assessment of the whole production. This Certificate of Conformity has been issued in accordance with the SGS CEBEC certification program CPRStd003, which is available on request. Conformity of the produced products with the specimen tested remains on the full responsibility of the manufacturer.

Brussels, 10/01/2023  
C. LANA,  
Certification Manager

This document is issued by the company under its [General Conditions of Certification Services of SGS Belgium NV](http://www.sgs.com/terms_and_conditions.htm) accessible at [http://www.sgs.com/terms\\_and\\_conditions.htm](http://www.sgs.com/terms_and_conditions.htm).  
Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.