

产品认证证书

II型自愿认证

证书编号: CQC2017010304993563

发证日期: 2021年07月01日

有效期至: 2031年07月01日

委托人名称 ABB Stotz-Kontakt GmbH
及注册地址 Eppelheimer Strasse 82 69123 Heidelberg Germany

制造商名称 ABB Stotz-Kontakt GmbH
及注册地址 Eppelheimer Strasse 82 69123 Heidelberg Germany

生产企业名称 ABB Stotz-Kontakt GmbH
及生产地址 Eppelheimer Strasse 82 69123 Heidelberg Germany

产品名称和系列、规格、型号 接触器
ESB40-xxN, ESB63-xxN, EN40-xxN; 详见附件

产品标准和技术要求 GB/T 14048.4-2020

认证模式 产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

本证书为变更证书, 证书首次颁发日期: 2020年09月02日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



授权签字人

签发

陈昕

谢肇煦



中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0077199

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2017010304993563

Valid from: Jul.01,2021

Valid until: Jul.01,2031

NAME AND REGISTERED ADDRESS OF THE APPLICANT ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

NAME AND LOCATION OF THE FACTORY ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

PRODUCT NAME, MODEL AND SPECIFICATION Contactor
ESB40-xxN, ESB63-xxN, EN40-xxN ; See the appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS GB/T 14048.4-2020

TYPE OF CERTIFICATION SCHEMES Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

Date of original issued: Sep.02,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

陈昕

SIGNATURE

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

Tel: +86 10 83886666

C(2) 0077199

产品认证证书

II型自愿认证

证书编号: CQC2017010304993563

第 1 页 共 3 页

本证书及附件应同时使用, 信息查验说明见证书页

纸号: 77199

ESB40-xxN, ESB63-xxN, EN40-xxN; 型号解释详见附件;
Ui: 500V;
Uimp: 6kV;
Ith: 63A(ESB63-xxN), 40A(ESB40-xxN, EN40-xxN);
ESB40-xxN, EN40-xxN: AC-1: Ue/Ie: AC400V/40.0A(NO),
AC400V/30.0A(NC);
ESB63-xxN: AC-1: Ue/Ie: AC400V/63.0A(NO), AC400V/30.0A(NC);
ESB40-xxN, EN40-xxN: AC-3: Ue/Ie: AC400V/22.0A(NO);
ESB63-xxN: AC-3: Ue/Ie: AC400V/30.0A(NO);
ESB40-xxN, EN40-xxN: DC-1: Ue/Ie: DC220V/1.0A(NO);
DC-3: Ue/Ie: DC220V/0.3A(NO);
ESB63-xxN: DC-1: Ue/Ie: DC220V/1.1A(NO);
DC-3: Ue/Ie: DC220V/0.3A(NO);
Us: 12V, 24V, 42V, 48V, 110V, 230V, 240V, 400V, 415V 50/60Hz/DC;
IP20;
极数: 4P;
配用辅助触头: (EH04-11N, EH04-20N);
1NO1NC, 2NO
Ith: 6A;
AC-15: Ue/Ie: 120V/6A(NO/NC), 240V/4A(NO/NC),
415V/1A(NC), 3A(NO); 500V/1A(NC), 2A(NO).



中国质量认证中心



产品认证证书

II型自愿认证

证书编号: CQC2017010304993563

第 2 页 共 3 页

本证书及附件应同时使用, 信息查验说明见证书页

纸号: 77199

型号解释:

Full type 型号		ESB63-40N-DC-B-01									
		1 (ESB)	-	2 (63)	-	3 (40)	4 (N)	-	5 (DC-B)	-	6 (01)
Position 位置	product 产品	√	√	√	√	√	√	√	√	√	
	package label 标签	√	√	√	√	√	√	√	√	√	√

1. Model name 接触器名称

ESB - standard model 标准型, 自动操作

EN - with additional manual operation 手动/自动操作

2. Basic type 40 or 63 基本型号

3. Contact variants of the contactor 主触点类型

- 40 4 NO 4 常开
- 22 2 NO / 2 NC 2 常开, 2 常闭
- 20 2 NO 2 常开
- 30 3 NO 3 常开
- 31 3 NO / 1 NC 3 常开, 1 常闭
- 02 2 NC 2 常闭



中国质量认证中心



产品认证证书

II型自愿认证

证书编号: CQC2017010304993563

第 3 页 共 3 页

本证书及附件应同时使用, 信息查验说明见证书页

纸号: 77199

4. ESB series suffix 工厂代号

N - upgraded version N 升级版

5. optional for marketing or customer, letter, number and symbol, DC-B

市场或客户的选项, 用字母, 数字和符号标识, DC-B

Blank- without optional 空白 无选项

6. Coil code 线圈代号

V ac/dc 电压	Coil type 线圈代号
12	14
24	01
42	02
48	03
110	04
230	06
240	05
400	07
415	08



中国质量认证中心

