

IEC

IECEE



Ref. Certif. No.

CN71568

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Pilot device

Name and address of the applicant

ABB Xinhui Low Voltage Switchgear Co.,Ltd.
Jinguzhou Industrial Development Zone, Xinhui District, Jiangmen
City, Guangdong Province, P.R.China

Name and address of the manufacturer

ABB Xinhui Low Voltage Switchgear Co.,Ltd.
Jinguzhou Industrial Development Zone, Xinhui District, Jiangmen
City, Guangdong Province, P.R.China

Name and address of the factory

ABB Electrification Sweden AB, Motor Starting & Safety
Motorgrand 20, 72161 Vasteras, Sweden

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Ui: 690V (except MDB), 250V (MDB);Uimp:6kV;Ith:10A;AC-12:
Ue/Ie:230V/10A; AC-15:
Ue/Ie:120V/8.0A,230V/6.0A,400V/4.0A,690V/2.0A; DC-13:
Ue/Ie:24V/5.0A,125V/0.55A,250V/0.27A; IP Code: MCB: IP20,
Degrees of protection of the operators on the specified panel are IP66

Trademark (if any)

ABB

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

MCB*_****, MCBH*_****, MP**_***_**, MP*_7***,
MPM**_***_**, MPM*_***_**, M2SS*_***_**, M3SS*_***_**,
M2SSK*_***_**, M3SSK*_***_**, ML*_****, ML1-7***,
ML9_****, MTS*_***_**, MPD*_***_**, MPE**_***_**,
MP9_****, MJS*_***_**, ME***_****, MDB-1001;

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2020;IEC 60947-5-1:2024

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2024CQC-119980

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>

Date: Apr.22,2025

Signature:

谢肇旭

Xie ZhaoXu