



产品认证证书

证书编号: CQC2009010304365509

申请人名称及地址

ABB AB, Control Products
SE-721 61 Vasteras Sweden

制造商名称及地址

ABB AB, Control Products
SE-721 61 Vasteras Sweden

生产企业名称及地址

ABB 新会低压开关有限公司 (V005372)
广东省江门市新会区今古洲工业开发区

产品名称和系列、规格、型号

辅助触点

CAL18-11, CAL18-11B; Ui:690V;
Uimp:6kV;lth:16A;AC-15:Ue/le:AC127V/6A,230/240V/4A,400/440V/3A,500/690V/2A;DC-13:Ue/le:DC24
V/6A,48V/2.8A,72V/1A,125V/0.55A,250V/0.3A;防护等级:IP20.

产品标准和技术要求

GB/T14048.5-2017

认证模式

型式试验+获证后监督

上述产品符合 CQC11-462142-2019 认证规则的要求, 特发此证。

发证日期: 2020年08月14日 有效期至: 2023年11月06日
证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

主任: _____

陆梅



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C 0353257



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2009010304365509

NAME AND ADDRESS OF THE APPLICANT

ABB AB,Control Products
SE-721 61 Vasteras Sweden

NAME AND ADDRESS OF THE MANUFACTURER

ABB AB,Control Products
SE-721 61 Vasteras Sweden

NAME AND ADDRESS OF THE FACTORY

ABB Xinhui Low Voltage Switchgear Co., Ltd. (V005372)
Jinguzhou Industrial Development Zone, Xinhui District, Jiangmen City, Guangdong Province, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

Auxiliary Contact
CAL18-11, CAL18-11B; Ui:690V;
Uimp:6kV;lth:16A;AC-15:Ue/le:AC127V/6A,230/240V/4A,400/440V/3A,500/690V/2A;DC-13:Ue/le:DC24V/6A,48V/2.8A,72V/1A,125V/0.55A,250V/0.3A;Levels of Protection:IP20.

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.5-2017

TYPE OF CERTIFICATION SCHEMES

Type testing+Follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462142-2019 .

Valid from: Aug.14,2020

Valid until: Nov.06,2023

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

President: _____

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nanshuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0353257