中国国家强制性产品认证证书

证书编号：2024010304645692

认证委托人名称及地址

ABB Electrification Sweden AB Motor Starting & Safety
Motorgrand 20, 72161 Vasteras, Sweden

生产者名称及地址

ABB Electrification Sweden AB Motor Starting & Safety
Motorgrand 20, 72161 Vasteras, Sweden

生产企业名称及地址

ABB Electrification Sweden AB Motor Starting & Safety
Motorgrand 20, 72161 Vasteras, Sweden

产品名称和系列、型号、规格

直流接触器
GF875-20-**-**, GF1050-20-**-**, GF1325-20-**-**, GF875B-20-**-**,
GF1050B-20-**-**, GF1325B-20-**-**；见附页

产品标准和技术要求

GB/T 14048.4-2020

上述产品符合《强制性产品认证实施规则　低压电器　低压元器件》（CNCA-C03-02:2024）的要求，特发此证。

发证日期：2024 年 10 月 23 日　**有效期至：**2029 年 06 月 19 日

本证书为变更证书，证书首次颁发日期：2024 年 06 月 20 日
证书信息和有效性可扫描下方二维码或登录发证机构网站查验，
也可在认监委网站（www.cnca.gov.cn）查询。

签发：谢肇煦

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司

中国国家强制性产品认证证书

证书编号：2024010304645692

GF875-20-**-**, GF1050-20-**-**, GF1325-20-**-**, GF875B-20-**-**,
GF1050B-20-**-**, GF1325B-20-**-**
Ui：1500V;
Uimp：8kV;
Ith：875A,1050A,1325A;
DC-1：Ue/Ie：1500V/210A;
DC-PV3:Ue/Ie:1500V/875A(GF875(B)-20-**-**),
1500V/1050A(GF1050(B)-20-**-**);
DC-PV3：Ue/Isc1：1500V/210A(GF875(B)-20-**-**, GF1050(B)-20-**-**);
极数：2P 外形;
Us：24-60V 50/60Hz, DC; 48-130V 50/60Hz, DC; 100-250V 50/60Hz, DC;
配用辅助触头:(外置)
侧面装辅助触点 CAL20 零个/一个/二个，每个包含常开和常闭触点各一对;
CCC 证书编号：2024010305661589
Ith：16A;
Ui：690V;
AC-15：127V/6A, 220-240V/4A, 280-440V/3A, 500-690V/2A;
DC-13：24V/3A, 48V/1.5A, 72V/1A, 125V/0.55A, 250V/0.3A;
1NO1NC, 2NO2NC;

本页为证书附页，应与证书主页同时使用。

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司

中国国家强制性产品认证证书

证书编号：2024010304645692

型号的解释：

Example: GF875-20-11-53				
1 (GF875)	2 (20)	3 (11)	4 (53)	

1 = Name of series and size of contactor 接触器系列名称及大小

GF875 = Basic model 基本型号
GF1050 = Basic model 基本型号
GF1325 = Basic model 基本型号
GF875B = For rolling stock applications 机车应用
GF1050B = For rolling stock applications 机车应用
GF1325B = For rolling stock applications 机车应用

2: Number of main contacts

20= 2 NO- and 0 NC-contacts 2 常开

3: Number of NO and NC auxiliary contacts 辅助触头(CAL20-11)

00 = without auxiliary contact 无辅助触头
11 = 1 NO- and 1 NC-contacts (side mounted 侧装 CAL20-11)
22 = 2 NO- and 2 NC-contacts (side mounted, 侧装 2 pieces CAL20-11)

4: Control supply voltage code 线圈代号

51: Us = 24-60V 50/60Hz d.c.
52: Us = 48-130V 50/60Hz d.c.
53: Us = 100-250V 50/60Hz d.c.

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE
中国质量认证中心有限公司
http://www.cqc.com.cn 北京市丰台区南四环西路188号九区5号楼 100070 电话：+86 10 83886666

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2024010304645692

NAME AND ADDRESS OF THE APPLICANT

ABB Electrification Sweden AB Motor Starting & Safety
Motorgrand 20, 72161 Vasteras, Sweden

NAME AND ADDRESS OF THE MANUFACTURER

ABB Electrification Sweden AB Motor Starting & Safety
Motorgrand 20, 72161 Vasteras, Sweden

NAME AND LOCATION OF THE FACTORY

ABB Electrification Sweden AB Motor Starting & Safety
Motorgrand 20, 72161 Vasteras, Sweden

PRODUCT NAME,MODEL AND SPECIFICATION

DC Contactor
GF875-20-**-**, GF1050-20-**-**, GF1325-20-**-**, GF875B-20-**-**, GF1050B-20-**-**, GF1325B-20-**-** ; See the appendix

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.4-2020

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Oct.23,2024 **Valid until:** Jun.19,2029

Date of original issued: Jun.20,2024

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).

SIGNATURE: 谢肇煦

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2024010304645692

Appendix: Page 1 of 2

GF875-20-**-**, GF1050-20-**-**, GF1325-20-**-**, GF875B-20-**-**,
GF1050B-20-**-**, GF1325B-20-**-**
Ui: 1500V;
Uimp: 8kV;
Ith: 875A,1050A,1325A;
DC-1: Ue/Ie: 1500V/210A;
DC-PV3:Ue/Ie:1500V/875A(GF875(B)-20-**-**),
1500V/1050A(GF1050(B)-20-**-**);
DC-PV3: Ue/Isc1: 1500V/210A(GF875(B)-20-**-**, GF1050(B)-20-**-**);
Poles: 2P Shape;
Us: 24-60V 50/60Hz, DC; 48-130V 50/60Hz, DC; 100-250V 50/60Hz, DC;
Auxiliary contacts:(External)
Side mounted auxiliary contacts CAL20 zero/one/two, each containing a pair of normally open and normally closed contacts;
CCC Certificate number: 2024010305661589
Ith: 16A;
Ui: 690V;
AC-15: 127V/6A, 220-240V/4A, 280-440V/3A, 500-690V/2A;
DC-13: 24V/3A, 48V/1.5A, 72V/1A, 125V/0.55A, 250V/0.3A;
1NO1NC, 2NO2NC;

This page is attached to the certificate and should be used at the same time as the certificate page.

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2024010304645692

Type description:

Example: GF875-20-11-53				
1 (GF875)	2 (20)	3 (11)	4 (53)	

1 = Name of series and size of contactor 接触器系列名称及大小

GF875 = Basic model 基本型号
GF1050 = Basic model 基本型号
GF1325 = Basic model 基本型号
GF875B = For rolling stock applications 机车应用
GF1050B = For rolling stock applications 机车应用
GF1325B = For rolling stock applications 机车应用

2: Number of main contacts

20= 2 NO- and 0 NC-contacts 2 常开

3: Number of NO and NC auxiliary contacts 辅助触头(CAL20-11)

00 = without auxiliary contact 无辅助触头
11 = 1 NO- and 1 NC-contacts (side mounted 侧装 CAL20-11)
22 = 2 NO- and 2 NC-contacts (side mounted, 侧装 2 pieces CAL20-11)

4: Control supply voltage code 线圈代号

51: Us = 24-60V 50/60Hz d.c.
52: Us = 48-130V 50/60Hz d.c.
53: Us = 100-250V 50/60Hz d.c.

This page is attached to the certificate and should be used at the same time as the certificate page.