



中国国家强制性产品认证证书

证书编号: 2018010304129269

委托人名称、地址

ABB France

2 rue d'Arsonval 69680 Chassieu France

生产者(制造商)名称、地址

ABB France

2 rue d'Arsonval 69680 Chassieu France

生产企业名称、地址

ABB Bulgaria EOOD - Rakovski branch

BULGARIA, 4142 Village of Stryama, Region of Plovdiv, Municipality of Rakovski, Rakovski Industrial Zone, 14 Industrial Road 1, nr,14-18

产品名称和系列、规格、型号

交流接触器

AE50-30, TAE50-30, AE63-30, AE75-30, TAE75-30; 详情见附件

产品标准和技术要求

GB/T 14048.4-2010

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求,
特发此证。

发证日期: 2020 年 08 月 07 日有效期至: 2023 年 11 月 06 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2018 年 11 月 06 日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询

经中国合格评定国家认可委员会认可 CNAS C001-P



主任:

陆楠



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2018010304129269

NAME AND ADDRESS OF THE APPLICANT

ABB France
2 rue d'Arsonval 69680 Chassieu France

NAME AND ADDRESS OF THE MANUFACTURER

ABB France
2 rue d'Arsonval 69680 Chassieu France

NAME AND ADDRESS OF THE FACTORY

ABB Bulgaria EOOD – Rakovski branch
BULGARIA, 4142 Village of Stryama, Region of Plovdiv, Municipality of Rakovski, Rakovski
Industrial Zone, 14 Industrial Road 1, nr.14-18

PRODUCT NAME, MODEL AND SPECIFICATION

AC Contactor
AE50-30, TAE50-30, AE63-30, AE75-30, TAE75-30; See the appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.4-2010

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification (REFNO.CNCA-C03-02:2014).

Valid from: Aug.07,2020 **Valid until:** Nov.06,2023

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Nov.06,2018

The certificate information is available through CNCA's website: www.cnca.gov.cn

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附 录

第 1 页 共 2 页

证书编号: 2018010304129269

纸 号: 2658604

AE50-30, TAE50-30, AE63-30, AE75-30, TAE75-30
U_{imp}: 8kV;
U_i: 1000V;
AE50-30, TAE50-30:
I_{th}: 100A;
AC-1: U_e/I_e: 690V/100A,
AC-3, AC-4: U_e/I_e: 220-230-240V/53A, 380-400V/50A, 415V/50A, 440V/45A,
500V/45A, 690V/35A,
AC-8a: U_e/I_e: 400V/63A,
AE63-30:
I_{th}: 125A;
AC-1: U_e/I_e: 690V/115A,
AC-3, AC-4: U_e/I_e: 220-230-240V/65A, 380-400V/65A, 415V/65A, 440V/65A,
500V/55A, 690V/43A,
AC-8a: U_e/I_e: 400V/85A,
AE75-30, TAE75-30:
I_{th}: 125A;
AC-1: U_e/I_e: 690V/125A,
AC-3, AC-4: U_e/I_e: 220-230-240V/75A, 380-400V/75A, 415V/75A, 440V/70A,
500V/65A, 690V/46A,
AC-8a: U_e/I_e: 400V/95A,
U_s: AE: DC24V, DC48V, DC110V, DC220V,
TAE: DC17-32V, DC50-90V, DC77-143V, DC152-254V,
IP10;
极数: 3P;
配用的辅助触头: (CAL5-11)
I_{th}: 16A;
AC-15: U_e/I_e: 24~127V/6A, 220~240V/4A, 380~440V/3A, 500~690V/2A;
DC-13: U_e/I_e: 24V/6A, 48V/2.8A, 72V/1A, 110~125V/0.55A, 220~250V/0.3A;
1N01NC

注: 此附录与证书同时使用时有效。



主 任:

陆 楠



中国质量认证中心



中国国家强制性产品认证证书

附 录

证书编号: 2018010304129269

第 2 页 共 2 页

纸 号: 2658604

型号解释:

Example 例如: TAE75-30-11-68				
TAE	75	-30	-11	-68
I	II	III	IV	V

I - Name of series 系列名称

TAE series with large coil voltage 宽电压线圈

AE series with standard coil voltage 标准电压线圈

II - Size of contactor 大小

50,63,75

III - Number of main contacts 主触头数量

30 = 3 NO- and 0 NC-contacts

IV - Number of auxiliary contacts 辅助触头数量

00 = No auxiliary pole provided.

11 = 1 NO- and 1 NC-contacts, side mounting CAL5-11

V - Coil code 线圈代号

Product 产品	Control voltage 控制电压	Coil code 线圈代号
AE	24V dc	81
AE	48V dc	83
AE	110V dc	86
AE	220V dc	88
TAE	17-32V dc	51
TAE	50-90V dc	55
TAE	77-143V dc	62
TAE	152-254V dc	68

注: 此附录与证书同时使用时有效。



主 任:

陆 楠



中国质量认证中心