

产品认证证书

II型自愿认证

证书编号: CQC2018010304129269

发证日期: 2022年03月22日

有效期至: 2032年03月21日

委托人名称 及注册地址	ABB France 11 Rue d' Arsonval 69680, Chassieu, FRANCE
制造商名称 及注册地址	ABB France 11 Rue d' Arsonval 69680, Chassieu, FRANCE
生产企业名称 及生产地址	ABB Bulgaria EOOD – Rakovski branch District Plovdiv, municipality Stryama, village Stryama 4142, Industrial Zone Rakovski, industrial road 1, nr. 14-18.
产品名称和系列、 规格、型号	交流接触器 AE50-30, TAE50-30, AE63-30, AE75-30, TAE75-30 ; 详见附件
产品标准和技术要求	GB/T 14048.4-2020
认证模式	产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

本证书为变更证书, 证书首次颁发日期: 2020年08月21日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



授权签字人

陈昕

签发

谢肇煦

中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0151692

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2018010304129269

Valid from: Mar.22,2022

Valid until: Mar.21,2032

NAME AND REGISTERED ADDRESS OF THE APPLICANT	ABB France 11 Rue d' Arsonval 69680, Chassieu, FRANCE
NAME AND REGISTERED ADDRESS OF THE MANUFACTURER	ABB France 11 Rue d' Arsonval 69680, Chassieu, FRANCE
NAME AND LOCATION OF THE FACTORY	ABB Bulgaria EOOD – Rakovski branch District Plovdiv, municipality Stryama, village Stryama 4142, Industrial Zone Rakovski, industrial road 1, nr. 14-18.
PRODUCT NAME, MODEL AND SPECIFICATION	AC Contactor AE50-30, TAE50-30, AE63-30, AE75-30, TAE75-30 ; See the appendix
THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS	GB/T 14048.4-2020
TYPE OF CERTIFICATION SCHEMES	Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

Date of original issued: Aug.21,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

陈昕

SIGNATURE

谢肇煦

CHINA QUALITY CERTIFICATION CENTRE



产品认证证书

II型自愿认证

证书编号: CQC2018010304129269

第1页 共2页

本证书及附件应同时使用, 信息查验说明见证书页

纸号: 151692

AE50-30, TAE50-30, AE63-30, AE75-30, TAE75-30

Uimp:8kV;

Ui: 1000V;

AE50-30, TAE50-30:

Ith:100A;

AC-1:Ue/Ie:690V/100A,

AC-3,AC-4:Ue/Ie:220-230-240V/53A,380-400V/50A,415V/50A,440V/45A,

500V/45A,690V/35A,

AC-8a:Ue/Ie:400V/63A,

AE63-30:

Ith:125A;

AC-1:Ue/Ie:690V/115A,

AC-3,AC-4:Ue/Ie:220-230-240V/65A,380-400V/65A,415V/65A,440V/65A,

500V/55A,690V/43A,

AC-8a:Ue/Ie:400V/85A,

AE75-30, TAE75-30:

Ith:125A;

AC-1:Ue/Ie:690V/125A,

AC-3,AC-4:Ue/Ie:220-230-240V/75A,380-400V/75A,415V/75A,440V/70A,

500V/65A,690V/46A,

AC-8a:Ue/Ie:400V/95A,

Us: AE:DC24V,DC48V,DC110V,DC220V,

TAE:DC17-32V,DC50-90V,DC77-143V,DC152-254V,

IP10;

极数: 3P;

配用的辅助触头:(CAL5,CA5)

Ith:16A;

AC-15:Ue/Ie: 24~127V/6A, 220~240V/4A, 380~440V/3A, 500~690V/2A;

DC-13:Ue/Ie: 24V/6A, 48V/2.8A, 72V/1A, 110~125V/0.55A, 220~250V/0.3A;

1NO1NC



中国质量认证中心



产品认证证书

II型自愿认证

证书编号: CQC2018010304129269

第 2 页 共 2 页

本证书及附件应同时使用, 信息查验说明见证书页

纸号: 151692

型号解释:

Example 例如: TAE75-30-11-68				
TAE	75	-30	-11	-68
I	II	III	IV	V

I - Name of series 系列名称

AE series with standard coil voltage 标准电压线圈

TAE series with large coil voltage 宽电压线圈

II - Size of contactor 大小

50, 63, 75

III - Number of main contacts 主触头数量

30 = 3 NO- and 0 NC-contacts

IV - Number of auxiliary contacts 辅助触头数量

00 = No auxiliary pole provided.

11 = 1 NO- and 1 NC-contacts, side mounting CAL5-11

V - Coil code 线圈代号

Control voltage	Coil code
DC	
24	81
48	83
110	86
220	88
17-32	51
50-90	55
77-143	62
152-254	68



中国质量认证中心

