



DET NORSKE VERITAS

TYPE APPROVAL CERTIFICATE

CERTIFICATE NO. E-11280

This is to certify that the
Motor Starter

with type designation(s)
MS 132 / MO 132

Manufactured by
ABB Stotz-Kontakt GmbH
HEIDELBERG, Germany

is found to comply with
Det Norske Veritas' Rules for Classification of Ships, High Speed & Light Craft and Det Norske Veritas' Offshore Standards
IEC 60947-2
IEC 60947-4-1

Application
For installations inside switchboards / enclosures onboard ships and offshore units


Rated Voltage (V)	690 AC
Rated Current (A)	0.1 - 32
Frequency (Hz)	40 - 60

Høvik, 2011-09-06
for Det Norske Veritas AS

This Certificate is valid until
2013-12-31


Marit Laumann
Head of Section


DNV local office:
Essen


Nicolay Horn
Surveyor
Sveer

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.
If any person suffers loss or damage which is proved to have been caused by any negligent act or omission of Det Norske Veritas, then Det Norske Veritas shall pay compensation to such person for his proved direct loss or damage. However, the compensation shall not exceed an amount equal to ten times the fee charged for the service in question, provided that the maximum compensation shall never exceed USD 2 million. In this provision "Det Norske Veritas" shall mean the Foundation Det Norske Veritas as well as all its subsidiaries, directors, officers, employees, agents and any other acting on behalf of Det Norske Veritas.



Certificate No.: E-11280
 File No.: 823.60
 Job Id.: 262.1-007664-2

Product description

Motor protection circuit breaker type: MS 132 / MO 132 with the following auxiliary devices (MO 132 thermal tripping function deactivated):

Current limiter: S803x-SCL-SR
 Aux. Switch front mounting: HKF1-11
 Aux. Switch attached at right: HK1-11, HK1-20, HK1-02
 Aux. Switch attached at right with lead contacts: HK1-20L
 Signal Switch: SK1-11, SK1-20, SK1-02
 Short circuit Signal Switch: CK1-11, CK1-20, CK1-02
 Undervoltage release: UA1
 Shunt release: AA1

Rated Voltage U_e : 690* V AC
 U_{imp} = 6 kV
 Rated frequency: 40 - 60 Hz
 Utilisation category: AC3

Tripping values, rated short circuit capacity:

Type	Thermal tripping setting ranges (A)	Rated current I_n / conventional free air thermal current (A)	Rated short circuit instantaneous short-circuit current setting (A)	Rated short circuit capacity $I_{cs} = I_{cu}$ at $U_e=400V$ (kA)	Rated short circuit capacity $I_{cs} = I_{cu}$ at $U_e=690V$ (kA)	Rated short circuit capacity with current limiter* $I_{cs} = I_{cu}$ at $U_e=690V$ (kA)
MS 132-0.16	0.1 - 0.16	0.16	1.25 - 1.87	100	100	-
MS 132-0.25	0.16 - 0.25	0.25	1.95 - 2.92	100	100	-
MS 132-0.4	0.25 - 0.4	0.4	3.12 - 4.68	100	100	-
MS 132-0.63	0.4 - 0.63	0.63	4.91 - 7.37	100	100	-
MS 132-1.0	0.63 - 1	1.0	9.20 - 13.8	100	100	-
MS 132-1.6	1 - 1.6	1.6	14.7 - 22.1	100	100	-
MS 132-2.5	1.6 - 2.5	2.5	23.0 - 34.5	100	100	-
MS 132-4.0	2.5 - 4	4.0	40.0 - 60.0	100	3	50
MS 132-6.3	4 - 6.3	6.3	63.0 - 94.5	100	3	50
MS 132-10	6.3 - 10	10	120 - 180	100	3	50
MS 132-16	10 - 16	16	192 - 288	50	3	50
MS 132-20	16 - 20	20	240 - 360	50	3	50
MS 132-25	20 - 25	25	300 - 450	50	3	50
MS 132-32	25 - 32	32	384 - 576	25	3	50

* With current limiter S803x-series

Rated voltage auxiliary contacts U_e : 600 / 690 V AC

Application/Limitation

Motor starter with thermal and magnetic release. Applicable for use in an IT (ship) net up to 690 V.

Type Approval documentation

Technical info:
 ABB Data sheet "Manual Motor Starter MS 132."

Test reports:
 Paconsult report no. 09-2475 dated 2009-07-03. SGS reports 58495801/00 to 58495801/15 & 58495802/00 to 58495802/12 issued 2009-07-13. Test report P2649E from ABB according to IEC 60 947-2 dated 03.08.2011. Test report P2997E from ABB according to IEC60947-4-1 and IEC 60 947-2 dated 08.06.2011.



Certificate No.: E-11280
File No.: 823.60
Job Id.: 262.1-007664-2

Tests carried out

Type tests according to IEC 60947-2: Sequence I and II and Annex H and IEC 60947-4-1 Sequence I, II, III and V.
Environmental tests in accordance to DNV SFC no. 2.4 / IACS E10: Vibration test, Humidity, Dry heat test, Low temperature test, EMC tests (emission & immunity), High voltage test and Insulation resistance test.

Marking of product

ABB Stotz – Type designation – Voltage – Current – Breaking capacity.

Certificate Retention Survey

The scope of the retention/renewal survey is to verify that the conditions stipulated for the type approval is complied with and that no alterations are made to the product design or choice of materials.

The main elements of the survey are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Production Sample Tests (PST) and Routines (RT) checked (if not available tests according to PST and RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Survey to be performed at least every second year.

END OF CERTIFICATE