



中国国家强制性产品认证证书

证书编号: 2024010307682150

认证委托人名称及地址

LEGRAND FRANCE

159 RUE JEAN JOANNON - ZI DES TROIS MOULINS - 06606 ANTIBES - FRANCE

生产者名称及地址

LEGRAND FRANCE

159 RUE JEAN JOANNON - ZI DES TROIS MOULINS - 06606 ANTIBES - FRANCE

生产企业名称及地址

罗格朗低压电器(无锡)有限公司

江苏省无锡市新吴区锡梅路88号

产品名称和系列、型号、规格

剩余电流动作断路器

411128, 411129, 411131, 411132, 411133, 411134, 411121, 411122, 411124, 411125, 411126, 411127, 413737, 413738, 413739, 413740, 413741, 413742, 413737A, 413738A, 413739A, 413740A, 413741A, 413742A; Ue: AC240V; Ui: 250V; Uimp: 4kV; In: 6A, 10A, 16A, 20A, 25A, 32A; 瞬时脱扣类型: C; Ics=Icn: 6kA; IΔ n: 10mA, 30mA/A 型, 30mA/AC 型; 漏电脱扣器类型: 电子式; IΔ m: 4500A; 极数: 1P+N(1个保护极, N极可开闭); 适用频率: 50/60Hz.

产品标准和技术要求

GB/T 16917.1-2014; GB/T 16917.22-2008

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》
(CNCA-C03-02:2024)的要求, 特发此证。

发证日期: 2024年08月26日 有效期至: 2029年08月25日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验,
也可在认监委网站(www.cnca.gov.cn)查询。



签发:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2024010307682150

NAME AND ADDRESS OF THE APPLICANT

LEGRAND FRANCE
159 RUE JEAN JOANNON - ZI DES TROIS MOULINS - 06606 ANTIBES - FRANCE

NAME AND ADDRESS OF THE MANUFACTURER

LEGRAND FRANCE
159 RUE JEAN JOANNON - ZI DES TROIS MOULINS - 06606 ANTIBES - FRANCE

NAME AND LOCATION OF THE FACTORY

Legrand Low Voltage Electrical(Wuxi)Co., Ltd.
No.88 Ximei Road, Xinwu District, Wuxi City, Jiangsu Province, P.R.China

PRODUCT NAME,MODEL AND SPECIFICATION

Residual Current Circuit Breaker With Over Current Protection

411128, 411129, 411131, 411132, 411133, 411134, 411121, 411122, 411124, 411125, 411126, 411127, 413737,
413738, 413739, 413740, 413741, 413742, 413737A, 413738A, 413739A, 413740A, 413741A, 413742A ; Ue: AC240V;
Ui: 250V; Uimp: 4kV; In: 6A, 10A, 16A, 20A, 25A, 32A; Type of Instantaneous Tripping Current : C; Ics=Icn: 6kA ; IΔ n:
10mA, 30mA/A, 30mA /AC; Electronic Residual Current Tripping Unit; IΔ m: 4500A; Poles: 1P+N(With one protective
poles, Switched N pole); 50/60Hz.

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 16917.1-2014; GB/T 16917.22-2008

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Aug.26,2024

Valid until: Aug.25,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to
the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

