

产品认证证书

II型自愿认证

证书编号: CQC2016010309922935

发证日期: 2022年02月15日

有效期至: 2031年09月23日

委托人名称	ABB Stotz-Kontakt GmbH
及注册地址	Eppelheimer Strasse 82 69123 Heidelberg Germany
制造商名称	ABB Stotz-Kontakt GmbH
及注册地址	Eppelheimer Strasse 82 69123 Heidelberg Germany
生产企业名称	ABB Bulgaria EOOD
及生产地址	1, Varna Str., 2850 Petrich, Bulgaria
产品名称和系列、 规格、型号	热过载继电器 TF140DU(型号解释详见附件); Ui:690V;Ue:690V;Ie:66-90,80-110,100-135,110-142A;脱扣级别:10A;极数:3P;IP20; 配用的辅助触头:(本体)Ith:6A(NO),10A(NC);AC-15:NO:Ue/Ie:240V/1.5A,440V/1A,500V/1A;AC-15:NC:Ue/Ie:240V/3A,440V/1A,500V/1A; DC-13:NO:Ue/Ie:24V/1.25A,125V/0.25A,250V/0.04A;DC-13:NC:Ue/Ie:24V/1.25A,125V/0.25A,250V/0.12A;1NO1NC
产品标准和技术要求	GB/T 14048.4-2020
认证模式	产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

本证书为变更证书, 证书首次颁发日期: 2020年09月02日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站(www.cnca.gov.cn)查验证书信息



授权签字人

签发

陈昕

谢肇煦



中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0138150

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2016010309922935

Valid from: Feb.15,2022

Valid until: Sep.23,2031

**NAME AND REGISTERED
ADDRESS OF THE APPLICANT**

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

**NAME AND REGISTERED
ADDRESS OF THE
MANUFACTURER**

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

**NAME AND LOCATION
OF THE FACTORY**

ABB Bulgaria EOOD
1, Varna Str., 2850 Petrich, Bulgaria

**PRODUCT NAME, MODEL
AND SPECIFICATION**

Thermal Overload Relays
TF140DU; Ui:690V;Ue:690V;Ie:66-90,80-110,100-135,110-142A;Trip Class:10A;Poles:3P;IP20;
Attached Auxiliary
Contacts:Ith:6A(NO),10A(NC);AC-15:NO:Ue/Ie:240V/1.5A,440V/1A,500V/1A;AC-15:NC:Ue/Ie:240
V/3A,440V/1A,500V/1A;
DC-13:NO:Ue/Ie:24V/1.25A,125V/0.25A,250V/0.04A;DC-13:NC:Ue/Ie:24V/1.25A,125V/0.25A,250
V/0.12A;1NO1NC

**THE STANDARDS AND
TECHNICAL REQUIREMENTS
FOR THE PRODUCTS**

GB/T 14048.4-2020

**TYPE OF CERTIFICATION
SCHEMES**

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

Date of original issued: Sep.02,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

陈昕

SIGNATURE

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86 10 83886666

C(2) 0138150

产品认证证书

II型自愿认证

附 录

证书编号: CQC2016010309922935

第 1 页 共 1 页

纸 号: 138150

型号解释:

$\frac{\text{TF}}{1} \quad \frac{140}{2} \quad \frac{\text{D}}{3} \quad \frac{\text{U}}{4} - \frac{142}{5} - \frac{\text{V1000}}{6}$

1. Series Name for Thermal Overload Relay for AF contactor series
2. Frame size 140
3. phase failure protection
4. Reset manual or automatic
5. Upper setting range
6. Blank: Standard version
-V1000: Optional to indicate the ATEX version

注: 此附录与证书同时使用时有效。



中国质量认证中心

