

# CERTIFICATE

## FOR EUROPEAN PRODUCT SAFETY

Reference No. SE-S-2001689

### Socket-outlet

**Type designation:** \*\*\*-67835, \*\*\*-67845

**Certificate holder:** NIKO N.V.  
Industriepark West 40  
9100 St Niklaas  
Belgium

**The product complies with the standard(s):** IEC 60884-1:2002+A1+A2  
SS 428 08 34:2013+T1+R1

**Date of expiry:** 10 June, 2025

Additional information in Appendix

**Certification Body:** Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

**Signed:**  **Date:** 10 June, 2020

Leif Mattsson

## APPENDIX:

Reference No. SE-S-2001689

### Technical Data:

Type designation	***-67835, ***-67845
Rated voltage (V)	250V~
Rated current (A)	16A
IP-Class	20
Standard sheet	III
Trademark	niko
Test Report	2012502STO-001
Product information	***-67835: Flush-type socket outlet 2P+E, two-fold, with shutters, IP20, with screwless-terminals. ***-67845: Flush-type socket outlet 2P+E, two-fold, with shutters, IP20, with screwless-terminals.

The difference between the type is that the cover of type \*\*\*-67835 is flatter than type \*\*\*-67845 and also the socket is different

### Manufacturing Sites:

NIKO N.V.  
Industriepark West 40  
9100 St Niklaas  
Belgium

The instruction for use shall be written in a language acceptable according to the national regulation in the country where the product is to be used.

### Certification Body:

Intertek Semko AB, Product Certification

**Place:** Kista - Stockholm

### Signed:



**Date:** 10 June, 2020

Leif Mattsson