

IEC**IECEE**

TM

Ref. Certif. No.

CN72311

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product

Thermal Overload Relay

Name and address of the applicant

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

Name and address of the manufacturer

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

Name and address of the factory

*Note: When more than one factory, please report on page 2*ABB Xinhui Low Voltage Switchgear Co.,Ltd.
Jinguzhou Industrial Development Zone, Xinhui Region,
Jiangmen City, Guangdong Province, P.R.China

Ratings and principal characteristics

See the Appendix

Trademark (if any)

ABB

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

TF65, TF96;

Additional information (if necessary may also be
reported on page 2)A sample of the product was tested and found
to be in conformity with

IEC 60947-1:2020;IEC 60947-4-1:2023

As shown in the Test Report Ref. No. which
forms part of this Certificate

00901-CB2025CQC-122516

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Jun.16,2025

Signature:

Xie ZhaoXu



TF65, TF96

Uimp: 8kV;

Ui: 690V;

Ue: AC690V;

TF65: Ie: 22-28A, 25-33A, 30-40A, 36-47A, 44-53A, 50-60A, 57-67A, 64-72A;

TF96: Ie: 40-51A, 48-60A, 57-68A, 65-78A, 75-87A, 84-96A;

Tripping class: 10;

Pole: 3P;

IP code: IP20;

Auxiliary contacts (body):

1NO1NC;

Ith:6A;

NC:

AC-15: Ue/Ie: 120V/240V/3A, 440V/500V/0.75A, 600V/0.6A;

DC-13: Ue/Ie: 24V/1.25A, 125V/0.55A, 250V/0.27A, 500V/0.15A, 600V/0.1A;

NO:

AC-15: Ue/Ie: 120V/240V/440V/500V/0.50A;

DC-13: Ue/Ie: 24V/1.25A, 125V/0.55A, 250V/0.27A, 500V/0.15A, 600V/0.1A

Page 1 of 1

Additional information (if necessary)

Date:

Jun.16,2025

Signature:

谢肇煦
Xie ZhaoXu