



Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

Manufacturer	ABB AG – STOTZ-KONTAKT
Address	Eppelheimer Str. 82, Heidelberg, 69123, Germany
Place of Production	ABB BULGARIA EOOD 1 Varna str., Petrich, 2850, Bulgaria
Place of Production	ABB INDIA LIMITED Basavanahalli Kasaba Hobli, Nelamangala, Taulk, Bangalore Rural, 562123, India
Type	Relays - Thermal & Magnetic With Oil Dash Pot
Description	Thermal overload relays
Trade Name	TA25DU, TA42DU, TA75DU, TA80DU, TA110DU, TA200DU
Application	Marine, offshore and industrial applications for use in environmental categories ENV1 and ENV2 as defined in Lloyd's Register's Type Approval System, Test Specification Number 1 – 2002.
Specified Standard	EN 60947-1:2007/A1:2011/A2:2014

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Thorsten Wolff

Electrical & Control - Senior Specialist to
Lloyd's Register EMEA
A member of the Lloyd's Register group

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



Type Approval Certificate

EN 60947-4-1:2019/AC:2020-05
EN 60947-5-1:2017/AC:2020-05

Ratings	Types	Voltage	Setting Range
	TA25DU	690 V	0.16 – 32A
	TA42DU	690 V	18 – 42A
	TA75DU	690 V	18 – 80A
	TA80DU	690 V	29 – 80A
	TA110DU	690 V	65 – 110A
	TA200DU	690 V	66 – 200A

Additional Tests Low temperature test (-25°C)

This certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid Certificate.

Previous Version: LR2009222TA

The Design Appraisal Document TSO-25-047555/TW and its supplementary Type Approval Terms and Conditions form part of this Certificate.

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.