

产品认证证书

II型自愿认证

证书编号: CQC2019010303193580

发证日期: 2021年03月19日

有效期至: 2024年06月13日

委托人名称 ABB Stotz-Kontakt GmbH
及注册地址 Eppelheimer Strasse 82 69123 Heidelberg Germany

制造商名称 ABB Stotz-Kontakt GmbH
及注册地址 Eppelheimer Strasse 82 69123 Heidelberg Germany

生产企业名称 ABB Bulgaria EOOD – Rakovski branch
及生产地址 BULGARIA, 4142 Village of Stryama, Region of Plovdiv, Municipality of Rakovski,
Rakovski Industrial Zone, 14 Industrial Road 1, nr,14-18

产品名称和系列、规格、型号 中间继电器
MCR, MCR...-RAIL ; 具体参数和型号解释详见附件

产品标准和技术要求 GB/T 14048.5-2017

认证模式 产品型式试验+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



授权签字人: 主任:

陈昕 陆楠

中国质量认证中心



PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2019010303193580

Valid from: Mar.19,2021

Valid until: Jun.13,2024

NAME AND REGISTERED ADDRESS OF THE APPLICANT	ABB Stotz-Kontakt GmbH Eppelheimer Strasse 82 69123 Heidelberg Germany
NAME AND REGISTERED ADDRESS OF THE MANUFACTURER	ABB Stotz-Kontakt GmbH Eppelheimer Strasse 82 69123 Heidelberg Germany
NAME AND LOCATION OF THE FACTORY	ABB Bulgaria EOOD – Rakovski branch BULGARIA, 4142 Village of Stryama, Region of Plovdiv, Municipality of Rakovski, Rakovski Industrial Zone, 14 Industrial Road 1, nr,14-18
PRODUCT NAME, MODEL AND SPECIFICATION	Mini Contactor Relay MCR, MCR...-RAIL ; See the Appendix
THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS	GB/T 14048.5-2017
TYPE OF CERTIFICATION SCHEMES	Type Testing of Product + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.
The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNED BY:

PRESIDENT:

CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86 10 83886666

C(2) 0017298

产品认证证书

II型自愿认证

附 录

第 1 页 共 3 页

证书编号: CQC2019010303193580

纸 号: 17298

MCR, MCR...-RAIL

Ui:750V;

Uimp:6kV;

AC-15:Ue/Ie:120V/6A,240V/6A,400V/4A,500V/2.5A,690V/1.5A;

DC-13:Ue/Ie:24V/5A,48V/3.5A,125V/1.2A,250V/0.6A,440V/0.25A;

Ith:16A;

Us:24V,48V,120V,220-230V,240V 50/60Hz,115-127V 50Hz,208-220V 60Hz,

110-115V 50Hz/110-120V 60Hz,220-240V 50Hz/277V 60Hz,

380-400V 50Hz/440V 60Hz,415-440V 50Hz/480V 60Hz,

500V 50Hz/600V 60Hz,

24V,48V,110V,125V,220V,12V,33V,72V DC;

IP20

注: 此附录与证书同时使用时有效。



中国质量认证中心

产品认证证书

II型自愿认证

附 录

第 2 页 共 3 页

证书编号: CQC2019010303193580

纸 号: 17298

型号解释:

Explanation in English

MC	R	C	0	40	A	T	D	-RAIL
Model	Relay	AC/DC	Number of main poles	Auxiliary Contacts	ABB marking	Terminal	Coil voltage	Special Ordering No.

Model: MC = Mini-contactor series

Relay: R = Relay.

Coil voltage AC/DC: A= Alternating current, C = Direct current (normal Consumption), K = Direct Current 2W Consumption, I = Direct Current 1.2 W Consumption

Number of main poles: 0 = None (Auxiliary contactor).

Auxiliary Contacts:

40 = 4 Normally open + 0 Normally closed

31 = 3 Normally open + 1 Normally closed

22 = 2 Normally open + 2 Normally closed

13 = 1 Normally open + 3 Normally closed (not available in MCRK and MCRI)

04 = 0 Normally open + 4 Normally closed (not available in MCRK and MCRI)

GE marking: A = ABB marking

Terminal: T = screw terminal, R = ring terminal

Coil voltage: see test report 00901-A2019CCC0303-3108720 table 1 & 2

Special Ordering No.: "-RAIL" is a Special Ordering Number for Railway Customer, "-RAIL" products are exactly the same with normal products which have no "RAIL" mark

注: 此附录与证书同时使用时有效。



中国质量认证中心

产品认证证书

II型自愿认证

附 录

第 3 页 共 3 页

证书编号: CQC2019010303193580

纸 号: 17298

中文型号解释

MC	R	C	0	40	A	T	D	-RAIL
系列号	继电器	线圈电压 AC/DC	主触头 对数	辅助触头 组合	品牌	接线 端子	线圈 电压	特殊订货代码

系列号: MC = 迷你接触器系列

继电器: R = 继电器.

线圈电压 AC/DC: A = 交流, C = 直流(正常功耗), K = 直流 2W 功耗, I = 直流 1.2 W 功耗

主触头对数: 0 = 无 (中间继电器).

辅助触头组合: (产品正面用 40E, 31E, 22E, 13E, 04E 表示)

40 = 4 常开+0 常闭

31 = 3 常开+1 常闭

22 = 2 常开+2 常闭

13 = 1 常开+3 常闭 (MCRK 和 MCRI 不适用)

04 = 0 常开+4 常闭 (MCRK 和 MCRI 不适用)

品牌: A = ABB 品牌

接线端子: T = 螺纹端子, R = 环形端子

线圈电压: 见试验报告 00901-A2019CCC0303-3108720 表 1 & 2

特殊订货代码: “-RAIL” 是为轨道交通及铁路用户设定的特殊订货号, 带“-RAIL” 的产品和不带“-RAIL” 的产品完全一致

注: 此附录与证书同时使用时有效。



中国质量认证中心