

25P-1604: Radiator connection nickel-plated 1100mm copper pipe 16x15CU



Commercial information

Deze messing pers bochtaansluiting voor radiator is vernikkeld en omvat eveneens een vernikkelde koperen buis van 1100mm.

Basic unit dimensions

Height	94 mm
Length	1,112 mm
Width	22 mm
Net weight	0.477 kg

Certificates

ATG, DVGW Wasser, ETA, KIWA, ÖVGW Wasser, WRAS, KOMO, STF, ÖN EN 21003-2/-3, GOST-R, ITC, TSU, QB (CSTBat), AFNOR, ACS, PZH, DNV-GL, EMI

Applications

Potable water, Heating, Compressed air, Cooling, Sanitary

Solutions

Building installations, Industry, Utility, Shipbuilding

Technical characteristics

Material connection 1	Brass	Bend radius	16 Millimetre
Material quality connection 1	CuZn40Pb2 (CW617N)	Outer pipe diameter connection 1	16 Millimetre
Surface protection connection 1	Nickel-plated	Outer pipe diameter connection 2	15 Millimetre
Material connection 2	Copper	Length	1112 Millimetre
Material quality connection 2	CuZn40Pb2 (CW617N)	Length of connection 1	1100 Millimetre
Surface protection connection 2	Nickel-plated	Working length connection 1	1100 Millimetre
Shape	Bend	Length of connection 2	86 Millimetre
Reducing	✗	Working length connection 2	86 Millimetre
Eccentric	✗	Wrench width union nut	0 Millimetre
System specific	✓	Medium temperature (continuous)	-10 70 Degrees celsius
Connection 1	Press sleeve	Max. operating pressure at 20 °C	16 Bar
Contour code connection 1	TH	Standard Dimension Ratio (SDR)	0
Connection 2	Soldered end		
Main colour fitting	Grey		
Material sealing	Ethylene-propylene diene monomer rubber (EPDM)		
With buffer stud	✓		
High tensile strength	✗		
With thermal insulation	✗		
Ring stiffness class	Other		
With sealing rings/gaskets	✓		
Capped	✗		
With drain valve	✗		
With de-aerator	✗		
FM quality mark	✗		
LPCB quality mark	✗		
ULC quality mark	✗		
UL quality mark	✗		
DIN-CERTCO certificate	✗		
VdS quality mark	✗		
With approval for TÜV	✗		
DVGW quality mark for gas	✗		
DVGW quality mark for water	✗		
KIWA certified	✓		
Gastec QA mark	✗		
KOMO certified	✗		
Type approval according to BBR/EKS	✗		