

CERTIFICATE

Issued to:
Applicant:
EATON; CEAG Notlichtsysteme GmbH
Senator-Schwartz-Ring 26
59494 Soest, Germany

Licensee:
EATON; CEAG Notlichtsysteme GmbH
Senator-Schwartz-Ring 26
59494 Soest, Germany

Product : Self-contained luminaires for emergency lighting with LED light source
Trade name(s) : EATON, EATON CEAG, EATON Crompton, EATON JSB, EATON LUMINOX or EATON MENVIER
Type(s)/model(s) : GuideLed 10811 CGLine+, GuideLed 10812 CGLine+, GuideLed 10821 CGLine+, GuideLed 10822 CGLine+, GuideLed 10823 CGLine+, GuideLed 10824 CGLine+, GuideLed 10825 CGLine+, GuideLed 10826 CGLine+, GuideLed 11811 CGLine+, GuideLed 11812 CGLine+, GuideLed 11821 CGLine+, GuideLed 11822 CGLine+, GuideLed 11823 CGLine+, GuideLed 11824 CGLine+, GuideLed 11825 CGLine+ and GuideLed 11826 CGLine+

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard(s) EN 60598-1:2015, EN 60598-1:2015/A1:2018, EN 60598-2-22:2014 and EN 60598-2-22:2014/A1:2020
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 990758


DEKRA hereby grants the right to use the ENEC certification mark.

The ENEC certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the ENEC certification agreement.

This certificate is issued on 6 June 2021 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 88-119231

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



K Xu
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: Self-contained luminaires for emergency lighting with LED light source
Trade name(s)	: EATON, EATON CEAG, EATON Crompton, EATON JSB, EATON LUMINOX or EATON MENVIER
Type(s)/model(s)	: GuideLed 10811 CGLine+, GuideLed 10812 CGLine+, GuideLed 10821 CGLine+, GuideLed 10822 CGLine+, GuideLed 10823 CGLine+, GuideLed 10824 CGLine+, GuideLed 10825 CGLine+, GuideLed 10826 CGLine+, GuideLed 11811 CGLine+, GuideLed 11812 CGLine+, GuideLed 11821 CGLine+, GuideLed 11822 CGLine+, GuideLed 11823 CGLine+, GuideLed 11824 CGLine+, GuideLed 11825 CGLine+ and GuideLed 11826 CGLine+
Rated voltage / nature of supply	: 220-240 Vac
Rated frequency	: 50/60 Hz
Ambient temperature (ta)	: -5...+30 °C (for self-contained maintained), 0...+35 °C (for self-contained non-maintained)

Product data – type GuideLed 10811 CGLine+

Rated input power	: 4,1 W
Degree of protection	: IP20
Class	: II
Description	: 20 m wall surface mounted, single sided

Product data – type GuideLed 10812 CGLine+

Rated input power	: 4,1 W
Degree of protection	: IP40
Class	: I
Description	: 20 m wall recessed mounted, single sided

Product data – type GuideLed 10821 CGLine+

Rated input power	: 5,1 W
Degree of protection	: IP40
Class	: II
Description	: 20 m ceiling surface mounting, double sided

Product data – type GuideLed 10822 CGLine+

Rated input power	: 5,1 W
Degree of protection	: IP40
Class	: II
Description	: 20 m ceiling surface mounting with pendulum suspension (tube 0,5m), double sided

Product data – type GuideLed 10823 CGLine+

Rated input power	: 5,1 W
Degree of protection	: IP40
Class	: II
Description	: 20 m ceiling surface mounting with pendulum suspension (tube 1,5m), double sided

Product data – type GuideLed 10824 CGLine+

Rated input power : 5,1 W
Degree of protection : IP20
Class : I
Description : 20 m ceiling recessed mounting, double sided

Product data – type GuideLed 10825 CGLine+

Rated input power : 5,1 W
Degree of protection : IP40
Class : II
Description : 20 m ceiling surface mounting with cable suspension, double sided

Product data – type GuideLed 10826 CGLine+

Rated input power : 5,1 W
Degree of protection : IP20
Class : II
Description : 20 m ceiling recessed mounting with cable suspension, double sided

Product data – type GuideLed 11811 CGLine+

Rated input power : 4,7 W
Degree of protection : IP20
Class : II
Description : 30 m wall surface mounted, single sided

Product data – type GuideLed 11812 CGLine+

Rated input power : 4,7 W
Degree of protection : IP40
Class : I
Description : 30 m wall recessed mounted, single sided

Product data – type GuideLed 11821 CGLine+

Rated input power : 6,3 W
Degree of protection : IP40
Class : II
Description : 30 m ceiling surface mounting, double sided

Product data – type GuideLed 11822 CGLine+

Rated input power : 6,3 W
Degree of protection : IP40
Class : II
Description : 30 m ceiling surface mounting
with pendulum suspension (tube 0,5m), double sided

Product data – type GuideLed 11823 CGLine+

Rated input power : 6,3 W
Degree of protection : IP40
Class : II
Description : 30 m ceiling surface mounting
with pendulum suspension (tube 1,5m), double sided

Product data – type GuideLed 11824 CGLine+

Rated input power : 6,3 W
Degree of protection : IP20
Class : I
Description : 30 m ceiling recessed mounting, double sided

Product data – type GuideLed 11825 CGLine+

Rated input power : 6,3 W
Degree of protection : IP40
Class : II
Description : 30 m ceiling surface mounting with cable suspension, double sided

Product data – type GuideLed 11826 CGLine+

Rated input power : 6,3 W
Degree of protection : IP20
Class : II
Description : 30 m ceiling recessed mounting with cable suspension, double sided

TESTS**Test requirements**

EN 60598-1:2015
EN 60598-1:2015/A1:2018
EN 60598-2-22:2014
EN 60598-2-22:2014/A1:2020

Test result

The test results are laid down in DEKRA test file 342281500.

Additional information

- Supply connection: screwless terminal
- With integral LED module (non-replaceable light source)

The integrated LED module is tested as part of the appliance and fulfil the requirements of EN IEC 62031:2020.

This certificate replaces certificate No. 71-103152 REV.1 which we hereby declare invalid.

The list of components is laid down in test report 3422815.50.

Conclusion

The examination proved that all requirements were met.

Factory locations

EATON; CEAG Notlichtsysteme GmbH
Senator-Schwartz-Ring 26
59494 Soest, Germany

SC Cooper Industries Romania SRL
Zona Industrială Vest Str. III, Nr. 12
310510 Arad, Romania