


IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Emergency lighting with LED light source
Name and address of the applicant	COOPER SECURITE SAS Parc Européen d' Entreprise RII Rue Beethoven, BP 10184, 63204 Riom France
Name and address of the manufacturer	COOPER SECURITE SAS Parc Européen d' Entreprise RII Rue Beethoven, BP 10184, 63204 Riom France
Name and address of the factory	<input checked="" type="checkbox"/> Additional information on page 2 EATON; CEAG Notlichtsysteme GmbH Senator-Schwartz-Ring 26 59494 Soest Germany
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	230 Vac, 50/60Hz, ta=5..35°C, IP65, IK08, Class I
Trademark (if any)	EATON
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	46811 LED 1-3H CGLINE+, 46811 LED HYG 1-3H CGLINE+
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60598-1:2014, IEC 60598-1:2014/AMD1:2017, IEC 60598-2-22:2014, IEC 60598-2-22:2014/AMD1:2017 National differences: EU Group Differences 2231887.50
As shown in the Test Report Ref. No. which forms part of this Certificate	

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Additional factory

SC Cooper Industries Romania SRL
Zona Industriala Vest
Str. III, Nr.12
310510 Arad
Romania

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands



A handwritten signature in blue ink, appearing to read 'H.R.M. Barends', written over the printed name.