

CERTIFICATE

Issued to:
Applicant:
EATON; CEAG Notlichtsysteme GmbH
Senator-Schwartz-Ring 26
59494 Soest, Germany

Licensee:
EATON; CEAG Notlichtsysteme GmbH
Senator-Schwartz-Ring 26
59494 Soest, Germany

Product : Centrally supplied luminaire for emergency lighting with LED light source
Trade name(s) : EATON CEAG, EATON Crompton, EATON JSB or EATON MENVIER
Type(s)/model(s) : IP65LEDE230-y, IP65LEDE230CG-y, IP65LEDE230EC-y, IP65LEDEX230-y,
IP65LEDEX230CG-y, IP65LEDEX230EC-y, IP65LEDO230-y,
IP65LEDO230CG-y and IP65LEDO230EC-y

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard(s) EN 60598-1:2015, EN 60598-1:2015/A1:2018, EN 60598-2-22:2014 and EN 60598-2-22:2014/A1:2020
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 990758


DEKRA hereby grants the right to use the ENEC certification mark.

The ENEC certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the ENEC certification agreement.

This certificate is issued on 7 February 2022 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 88-116717 REV.1

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



H.R.M. Barends
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: Centrally supplied luminaire for emergency lighting with LED light source
Trade name(s)	: EATON CEAG, EATON Crompton, EATON JSB or EATON MENVIER
Type(s)/model(s)	: IP65LEDE230-y, IP65LEDE230CG-y, IP65LEDE230EC-y, IP65LEDEX230-y, IP65LEDEX230CG-y, IP65LEDEX230EC-y, IP65LEDO230-y, IP65LEDO230CG-y and IP65LEDO230EC-y
Model	: i-P65
Degree of protection	: IP65
Description	: Centrally supplied luminaire for emergency lighting with LED light source for surface mounting (wall or ceiling)

Product data – type IP65LEDE230CG-y, IP65LEDEX230CG-y and IP65LEDO230CG-y

Rated voltage and frequency	: 220-240 Vac; 50/60 Hz; 176-275 Vdc
Rated input power	: 3,6 W
Class	: II
Ambient temperature range (ta)	: -15°C...40°C
Description	: CG-S monitoring

Product data – type IP65LEDE230-y, IP65LEDE230EC-y, IP65LEDEX230-y, IP65LEDEX230EC-y, IP65LEDO230-y and IP65LEDO230EC-y

Rated voltage and frequency	: 230 Vac; 50/60Hz
Rated input power	: 3,0 W
Class	: I
Ambient temperature range (ta)	: 0°C...40°C
Description	: unmonitored / EC version: Easichck 1.5 monitoring

TESTS**Test requirements**

EN 60598-1:2015
EN 60598-1:2015/A1:2018
EN 60598-2-22:2014
EN 60598-2-22:2014/A1:2020

Test result

The test results are laid down in DEKRA test file 342606800.

Additional information

- supply connection: Screw terminal
- with integral LED control gear with SELV output
- with integral LED module (non -replaceable light source)

Type description: y - suffix code for trade name:

no suffix = EATON JSB
G = EATON CEAG
C = EATON Crompton
M = EATON MENVIER

This certificate replaces certificate No. 88-116717 which we hereby declare invalid.

The list of components is laid down in test report 3426068.50.

Conclusion

The examination proved that all requirements were met.

Factory locations

EATON; CEAG Notlichtsysteme GmbH
Senator-Schwartz-Ring 26
59494 Soest, Germany

Digital Lighting (Dongguan) Company Ltd.
Xinmin District, Chang'An Town
523879 Dong Guan City Guangdong, China

SC Cooper Industries Romania SRL
Zona Industrială Vest Str. III, Nr. 12
310510 Arad, Romania

Eaton Electrical Systems Limited
Spinners Road
Doncaster DN2 4LT, United Kingdom

Cooper Securite SAS
Parc Européen d'Entreprise RII Rue Beethoven - BP 10184
63204 Riom, France

Eaton Industries Morocco
Zone Franche d'Exportation Midparc Nouaceur
20300 Casablanca, Morocco