



Certificate

of Conformity

LOVAG-Certificate No.: IT 18.129 Page 1 of 1

This Certificate applies only to the apparatus verified. The responsibility for conformity of any apparatus having the same designation with that verified rests with the manufacturer or responsible vendor.

This certificate has been prepared according to LOVAG (Low Voltage Agreement Group) Objectives and Operating Principles of mutual recognition. The responsible certification body as a member of LOVAG issues a Certificate of Conformity with the above mentioned Standard(s) following the exclusive use of LOVAG Verification instruction wherever applicable.

Only integral reproduction of this Certificate or reproductions of this page accompanied by any page(s) on which are stated the verifications performed and the assigned rated characteristics of the apparatus verified, are permitted without written permission from the LOVAG Signatory responsible for this Certificate

Apparatus: Low-voltage assembly

415 V (U_n) - 6 kV (U_{imp}) - 630 A (I_{nA}) - 36 kA (I_{cc}) - 50 Hz (f) - IP40/43 - IK 08

Designation Type:

XL3 S 630 Arrangement 148

Manufacturer: Legrand SA

128, Avenue du Marechal du Lattre de Tassigny

87045 Limoges Cedex - France

Applicant:

Legrand SA

128. Avenue du Marechal du Lattre de Tassigny

87045 Limoges Cedex - France

Verified by:

ACAE Laboratory: IB01 Varese (Italy)

The apparatus, constructed in accordance with the description mentioned in the Report listed in this Certificate has been subjected to the series of proving verifications in accordance with IEC 61439-2 Ed.2.0 (2011-08) and EN 61439-2 (2011-10):

- 10.2.5 Lifting

The results are shown in the Report in accordance to LOVAG. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the characteristics assigned by the manufacturer as stated below:

Lifting - 300 kg 1 section (with 4 eyebolts)

- 500 kg 2 sections (with 8 eyebolts and L shape beams)

This document includes: Test Report No.1528

Issue Date: 2018.10.16



Responsible Certification Body: ACAE Via Tito Livio, 5 – 24123 – BERGAMO (Italy)

> Authorized Signature: Virginio Scarioni Date: 2018.10.24

MOD 007 pag 1 Revisione 07