

CERTIFICATE

Issued to:
Applicant:
Niko N.V.
Industriepark West 40
9100 Sint-Niklaas, Belgium

Licensee:
Niko N.V.
Industriepark West 40
9100 Sint-Niklaas, Belgium

Product : Two-pole fixed socket-outlet with earthing-contact
Trade name(s) : NIKO
Type(s)/model(s) : ***_67815, ***_67825, ***_67835, ***_67845 and ***_67865

The product and any acceptable variation thereof as specified in the Annex to this certificate and the documents referred to therein.

DEKRA hereby declares that the above-mentioned product has been certified based on:

- a type test according to NEN-IEC 60884-1:2019, NEN-IEC 60884-1:2019/A1:2019, NEN-IEC 60884-1:2019/A2:2019 and NEN 1020:2019
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 6069948


DEKRA hereby grants the right to use the DEKRA Mark.

The DEKRA Mark may be applied to the product as specified in this certificate for the duration and under the conditions of the DEKRA Mark certification agreement.

This certificate is issued on 6 March 2026 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-172713

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



H.R.M. Barends
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



71-172713

DEKRA Mark is the new KEMA-KEUR

The DEKRA Mark certificate for this product is to all intents and purposes equivalent to a KEMA-KEUR certificate, the other certification mark used by DEKRA and should be valued and used as such. DEKRA Mark is gradually replacing KEMA-KEUR.

For more information please check: [Introducing DEKRA Mark](#)

SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: Two-pole fixed socket-outlet with earthing-contact
Trade name(s)	: NIKO
Type(s)/model(s)	: ***_67815, ***_67825, ***_67835, ***_67845 and ***_67865
Rated current	: 16 A
Rated voltage	: 250 V~
Standard sheet	: III of CEE7
Design	: two-fold
Method of mounting	: flush-type
Cover	: singular cover plate of thermoplastic material
Terminals	: screwless terminals
Earthing	: with side earthing-contacts
Markings	: -tradename, series-indication and electrical ratings on the socket-outlet

TESTS**Test requirements**

NEN-IEC 60884-1:2019
NEN-IEC 60884-1:2019/A1:2019
NEN-IEC 60884-1:2019/A2:2019
NEN 1020:2019

Test result

The test results are documented in DEKRA test file 217422600, 225032500.

Conclusion

The examination has confirmed that all requirements were met.

Factory location

Niko N.V.
Industriepark West 40
9100 Sint-Niklaas, Belgium