
Data Sheet | Item Number: 221-501

Mounting carrier; for Ex applications; 221 Series - 4 mm²; for DIN-35 rail mounting/

screw mounting; light gray

https://www.wago.com/221-501







Color: Iight gray

Physical data	Phy	/sical	l data
---------------	-----	--------	--------

i nysicai data	
Width	17.5 mm / 0.689 inches
Height	67.2 mm / 2.646 inches
Depth from upper-edge of DIN-rail	25.5 mm / 1.004 inches

Mechanical data

	Mounting type	DIN-35 rail Screw mount
--	---------------	----------------------------

Suitable for 2-, 3- and 5-conductor 221 Series Ex Splicing Connectors (4 mm²)

Material data

Information on material specifications can be found here
light gray
Polyamide (PA66)
V0
0.292 MJ
9.7 g

Commercial data	
eCl@ss 10.0	27-14-11-92
eCl@ss 9.0	27-14-11-92
ETIM 8.0	EC002848
ETIM 7.0	EC002848
PU (SPU)	50 (10) pcs
Packaging type	Box
Country of origin	CN
GTIN	4055143753449
Customs tariff number	39269097900

Data Sheet | Item Number: 221-501

https://www.wago.com/221-501



Environmental Product Compliance

RoHS Compliance Status Compliant, No Exemption

Approvals / Certificates

Approvals for hazardous areas



Approval	Standard	Certificate Name
AEx Underwriters Laboratories Inc.	UL 60079	E185892 (AEx eb IIC resp. Ex eb IIC)
IECEx Physikalisch Technische Bundesanstalt	IEC 60079	IECEx PTB 18.0045U (Ex eb IIC Gb, Ex eb I Mb)
INMETRO TÜV Rheinland do Brasil Ltda.	IEC 60079	TÜV 19.1781 U

Downloads

Environmental Product Compliance

Compliance Search

Environmental Product Compliance 221-501



Documentation

Bid Text			
221-501	21.05.2019	xml 2.81 KB	<u>↓</u>
221-501	21.05.2019	docx 14.44 KB	$\underline{\downarrow}$
ausschreiben.de 221-501			<u>↓</u>

CAD/CAE-Data

CAD data

2D/3D Models 221-501

CAE data

EPLAN Data Portal 221-501

ZUKEN Portal 221-501





1 Compatible Products

1.1 Optional Accessories

1.1.1 Marking

1.1.1.1 Marking strip



Item No.: 210-833

Marking strips; 25 m on roll; 6 mm wide; plain; Self-adhesive; white

Installation Notes

Conductor termination



Removing a conductor.



Inserting a connector into the mounting



Removing a connector from the mounting carrier.



Mounting type (440 V)
Using spacers between the connectors.



Mounting type (440 V) Vertical mounting on DIN-35 rail



Mounting type (440 V) Horizontal screw mounting on a flat surface



Mounting type (440 V) Mounting the carrier via non-conductive screws.



Mounting type (275 V)
No spacers are used between the connectors.



Mounting type (275 V)
Mounting the carrier using conductive screws.

Data Sheet | Item Number: 221-501

https://www.wago.com/221-501



Testing



Easily test inserted connectors in the carrier – however they are mounted.

 $\label{thm:condition} \textbf{Subject to changes. Please also observe the further product documentation!}$