

Installation MODBus Set GA5903

Function: This wire set is a tool to make communication through Modbus possible. The set can be applied to all heaters equipped with an EBM 966 control board and enables a connection between the Modbus Interface and the heater.

Installation:

Connection to the control board:

- Insert the 4-pole plug of the cable supplied into terminal J16 of the control board.



Connection to heater's terminal support:

- Screw the white connector supplied somewhere on the terminal support or let it hang loose.
- Attach the sticker underneath the connector as illustrated in the picture.
- Connect the yellow wire to **A/+**
- Connect the white wire to **B/-**
- Connect the green wire to **PE (GND)**

